



RANGPO FIRE STATION
SIKKIM FIRE & EMERGENCY SERVICE
[27.17°N, 88.53°E]

SL.No. 17 /F&ES/RPO/20.25

Date: 22/07/20.25

BR. No 2526N-11006-4567.

NO OBJECTION CERTIFICATE

Certified that the premises of DUGA. GOVT. SEC. SCHOOL
At DUGA has been inspected by the Fire & Emergency Service.
Sikkim in respect of implementation of inbuilt Fire Fighting Fire prevention/ Escape measure and
declares the premises fit in respect of Fire Safety.

The Fire & Emergency service, Sikkim has No objection in its occupation/Utilization for the
purpose of RENEWAL.

1. The entrance and Exit passage shall be kept free from any obstruction.
2. No loose or naked electric wiring shall be permitted in the premises
3. No leakage Damaged container containing highly inflammable liquid or solids shall be store in the premises.
4. Use of naked light for cooking or heating on the premises shall be/ is strictly prohibited.
5. That 2 nos. Fire Extinguisher of DCP/ABC/CO2 4 KGs. Capacity shall be installed and maintain one bucket of clean water and sand shall be kept in the premises & serviceable all the time.

This NOC Is valid for one year from the date of issue.

Officer In-Charge
Fire & Emergency Service
Rangpo, East Sikkim.

To,
M/S, Mr. DUGA. GOVT. SEC. SCHOOL
DUGA.
DIST-PAKYONG.

OFFICER INCHARGE
RANGPO FIRE STATION
EAST, SIKKIM