PROJECT MANUAL - VR-DEMO-BID-001 (SYNTHETIC)

TABLE OF CONTENTS

01 10 00 Summary
03 30 00 Cast-In-Place Concrete
05 12 00 Structural Steel Framing
23 05 00 Common Work Results For Hvac
26 05 19 Low-Voltage Electrical Power Conductors And Cables
26 05 33 Raceways And Boxes For Electrical Systems
26 51 00 Interior Lighting
31 23 00 Excavation And Fill

SECTION 01 10 00 - SUMMARY

PART 1 - GENERAL

1.1 Work covered: compressor shelter, pipe rack and site works.

1.2 Allowance No. 1: USD 25,000 for owner-directed testing.

1.3 Liquidated damages apply at USD 2,500 per calendar day.

1.4 Contractor obtains the building permit; owner pays permit fees.

1.5 Prevailing wage rates apply to all site labor.

PART 2 - PRODUCTS

2.1 As specified above and as shown on the drawings.

PART 3 - EXECUTION

3.1 Install in accordance with manufacturer instructions.

END OF SECTION 01 10 00

SECTION 03 30 00 - CAST-IN-PLACE CONCRETE

PART 1 - GENERAL

1.1 Concrete 4,000 psi at 28 days.

1.2 Testing by owner's testing agency.

1.3 Submittals: mix designs, reinforcement shop drawings.

PART 2 - PRODUCTS

2.1 As specified above and as shown on the drawings.

PART 3 - EXECUTION

3.1 Install in accordance with manufacturer instructions.

END OF SECTION 03 30 00

SECTION 05 12 00 - STRUCTURAL STEEL FRAMING

PART 1 - GENERAL

1.1 ASTM A992 wide-flange shapes.

1.2 Shop primer except members to be galvanized.

1.3 High-strength bolts ASTM F3125 Grade A325.

1.4 Erection drawings required.

PART 2 - PRODUCTS

2.1 As specified above and as shown on the drawings.

PART 3 - EXECUTION

3.1 Install in accordance with manufacturer instructions.

END OF SECTION 05 12 00

SECTION 23 05 00 - COMMON WORK RESULTS FOR HVAC

PART 1 - GENERAL

1.1 Equipment supports and vibration isolation.

1.2 Test and balance by others under separate contract.

PART 2 - PRODUCTS

2.1 As specified above and as shown on the drawings.

PART 3 - EXECUTION

3.1 Install in accordance with manufacturer instructions.

END OF SECTION 23 05 00

SECTION 26 05 19 - LOW-VOLTAGE ELECTRICAL POWER CONDUCTORS AND CABLES

PART 1 - GENERAL

1.1 Copper THHN/THWN-2 conductors.

1.2 Megger testing of all feeders.

PART 2 - PRODUCTS

2.1 As specified above and as shown on the drawings.

PART 3 - EXECUTION

3.1 Install in accordance with manufacturer instructions.

END OF SECTION 26 05 19

SECTION 26 05 33 - RACEWAYS AND BOXES FOR ELECTRICAL SYSTEMS

PART 1 - GENERAL

1.1 Rigid galvanized steel conduit exposed.

1.2 PVC-coated conduit in corrosive areas.

PART 2 - PRODUCTS

2.1 As specified above and as shown on the drawings.

PART 3 - EXECUTION

3.1 Install in accordance with manufacturer instructions.

END OF SECTION 26 05 33

SECTION 26 51 00 - INTERIOR LIGHTING

PART 1 - GENERAL

1.1 LED fixtures, 5,000 K, wet-location rated.

1.2 Alternate No. 1: LED high-bay upgrade.

1.3 Spare lamps and drivers: 5 percent, minimum one of each type.

PART 2 - PRODUCTS

2.1 As specified above and as shown on the drawings.

PART 3 - EXECUTION

3.1 Install in accordance with manufacturer instructions.

END OF SECTION 26 51 00

SECTION 31 23 00 - EXCAVATION AND FILL

PART 1 - GENERAL

1.1 Compaction to 95 percent standard Proctor.

1.2 Rock excavation: unit price per cubic yard.

1.3 Disposal of unsuitable material off site.

PART 2 - PRODUCTS

2.1 As specified above and as shown on the drawings.

PART 3 - EXECUTION

3.1 Install in accordance with manufacturer instructions.

END OF SECTION 31 23 00