

B-32 Earthing & Bonding Verification

ITR-FORM-B-32 Rev A 2026-03-02

Page 1

1. Purpose

Record of the earthing & bonding verification for one tag or subsystem. Complete every step; a failed step is raised as a punch item before the sheet is signed.

2. Sign-off

Completed by the contractor, verified by the completions engineer and, where the form requires it, signed by a second person.

Step	Check	Acceptance	Result
1	Earth conductor size per drawing	Correct	
2	Earth resistance to grid	< 1.0	
3	Bonding straps across flanges fitted	Fitted	
4	Connections tight and protected	Secure	