

B-41 Instrument Installation & Calibration

ITR-FORM-B-41 Rev A 2026-03-02

Page 1

1. Purpose

Record of the instrument installation & calibration for one tag or subsystem. Complete every step; a failed step is raised as a punch item before the sheet is signed.

2. Sign-off

Completed by the contractor, verified by the completions engineer and, where the form requires it, signed by a second person.

Step	Check	Acceptance	Result
1	Installed per hook-up detail	Correct	
2	Tag number and range verified	Match datasheet	
3	Calibration at 0 percent	< 0.5	
4	Calibration at 50 percent	< 0.5	
5	Calibration at 100 percent	< 0.5	
6	Impulse lines leak tested and sloped	Pass	
7	Loop wiring terminated and tagged	Complete	
8	Calibration certificate attached	Attached	