

B-42 Relief Valve Set Pressure Test

ITR-FORM-B-42 Rev A 2026-03-02

Page 1

1. Purpose

Record of the relief valve set pressure test for one tag or subsystem. Complete every step; a failed step is raised as a punch item before the sheet is signed.

2. Sign-off

Completed by the contractor, verified by the completions engineer and, where the form requires it, signed by a second person.

Step	Check	Acceptance	Result
1	Nameplate set pressure verified	Per PSV list	
2	Pop pressure - first lift	+/- 3%	
3	Reseat pressure	Per API 527	
4	Seat tightness test	Pass	
5	Test certificate and seal fitted	Sealed	