Model fidelity and its impact on power grid resource planning under high renewable penetration

by

Daniel Xavier Wolbert

A Thesis
Presented to the Graduate Committee
of Lehigh University
in Candidacy for the Degree of
Master of Science
in
Industrial and Systems Engineering

Lehigh University
05/2106

Approved and recommended for acceptance as a thesis in partial fulfilment of the requirements for the degree of Master of Science.

Daniel Xavier Wolbert
Model fidelity and its impact on power grid resource planning under high renewable penetration

05/06/2016

Tamas Terlaky, Thesis Director, Chair
(Must Sign with Blue Ink)

Accepted Date

Committee Members

Robert H. Storer

Contents

List of Tables

List of Figures

Chapter 1

Introduction

Variable Energy Resources (usually refereed as VERs) plays an important role in the energy grid nowadays. It is expected that in 2020, x% of all average consumed power in United States comes from them. One of important characteristics of them is the unpredictable behaviour for demand. With the deregulation of the energy market and the decarbonization rules, the grid operators have the challenge to plan efficiently their non-renewable resources (such as oil, coal and gas) in order to keep the grid in security and operational parameters while running the grid at a minimal cost. This work analyses the classical LP version of Economic Dispatch (known as ED) and a MIP instance of Unit Commitment(UC) under different operational constraints and VERs penetration scenarios.

Chapter 2

Literature Review

The first optimal power flow formulation was proposed by ¡put the guy here in 1962¿

Connolly et al. reviews 68 tools to power grid planning with renewable resources, discussing at the end goals, limitations and features of 37 tools [3]. The authors emphasize that, although all the tools are essential to an accurate power planning with renewable resources, there is no perfect tool, and it should be chosen accordingly to project goals, data limitations, horizon and other features. Yamin discusses different techniques to solve the unit commitment and economic dispatch problems, categorizing them in deterministic, heuristic or stochastic, pointing out the computational challenges and the quality of results for each one of them [18]. Padhy formulates the unit commitment as a general optimization problem and presents a bibliographical survey of the main techniques in the last 30 years, from exhaustive methods such as priority listing, dynamic programming, mixed integer-programming until complex heuristics like fuzzy programming, genetic algorithms and evolutionary programming, emphasizing that these one were not exhaustively tested yet.

Models can be classified according to different features, that include:

1. Time frame: decade, year, hour, sub hour
2. Scale: global, national, regional, local
3. Deterministic vs stochastic

4. Optimization vs Simulation

5. Algorithmic vs Heuristic

Cain et al. categorizes the general power flow according to 3 major categories: Power Flow (PF), Economic Dispatch (ED) and Optimal Power Flow (OPF) and describe them based on the assumptions and operational constraints, as shown in table 2.1 [2].

In Kassakian et al. report, the authors points new trends and challenges for electric grid management. It discusses the impact of VER's

Under a scenario where renewable resources have a considerable penetration in the power system, it is necessary to study their impact. Deane et al. studies the impact of UC and ED results at different solving temporal resolutions under one year, on a scenario of high wind penetration [4]. The author discusses that sub-hourly resolutions can deal more accurately with non-thermal inflexibilities, renewable demand variabilities and ramping behaviours than one-hour resolution. This difference is evaluated again in this thesis.

This project covers the LP Economic Dispatch problem and the MIP Unit Commitment.

Table 2.1: Optimal power flow categories [2]

Category	Name	Constraints					Costs
		Voltage		Transmission	Contingency	Losses	Generator
		Angle	Magnitude				
OPF	ACOPF	x	x	x		x	x
OPF	DCOPF			x	x	x	x
OPF	DOPF	x	x	x		x	
OPF	SCED	x		x	x	x	x
OPF	SCOPF	x	x	x	x	x	x
PF	PF		x			x	x
ED	ED					x	x

More details of AC and DC power flows are presented in appendix

Chapter 3

Development

3.1 Data

3.2 Models

This thesis covers the Economic Dispatch and Unit Commitment models, developed exhaustively in the literature.

3.2.1 Indices and Sets

$g \in \mathcal{G}$	Set of generators
$b \in \mathcal{B}$	Set of buses
$g \in \mathcal{G}^{NR}$	Subset of non-renewable generators
$g \in \mathcal{G}^{R}$	Subset of renewable generators
$gt \in \mathcal{GT}$	Set of generator types
$u \in \mathcal{U}$	Set of unit groups
$l \in \mathcal{L}$	Set of transmission lines
$rr \in \mathcal{RR}$	Set of reserve requirements
$rp \in \mathcal{RP}$	Set of reserve products
$t \in \mathcal{T}$	Set of time periods
$g \in \mathcal{G}^{\lfloor}$	Set of generators in each bus b

3.2.2 Parameters

$D_{b,t}$	Load at bus b in time t
C_g	Generation cost for generator g ($ / MW) t
S_g	Start-up cost for generator g
R_g^{up}	Ramp up limit for generator g
R_g^{down}	Ramp down limit for generator g
G_g^{max}	Maximum generation capacity for generator g
G_g^{min}	Minimum generation capacity for generator g
T_l^{min}	Minimum transmission of transmission line l
T_l^{max}	Maximum transmission of transmission line l
$P_{g,t}^{R}$	Power generation of renewable generator g in time t

Note 1: The generation of renewable resources are not in the decision variables. The developed models only decides the generation for non-renewable resources. Therefore the generation is considered a deterministic parameter, not a variable in the model.

3.2.3 Variables

$P_{g,t}^{NR}$	Power generation of non-renewable generator g in time t (MW)
$T_{i,j,t}$	Power transmitted from bus i to bus j in time t (MW)
$T_{i,j,t}^{loss}$	Power loss in transmission from bus i to bus j in time t (MW)
$S_{g,t}$	On/off status of generator g at time n
$S_{g,t}^{on}$	Start-up status of generator g at time n
$S_{g,t}^{off}$	Shut-down status of generator g at time n
$V_{b,t}^{-}$	Under generation slack variable at each bus b in time t
$V_{b,t}^{+}$	Over generation slack variable at each bus b in time t

3.2.4 Economic Dispatch Models

The economic dispatch model satisfies the load and transmission requirements at a minimum cost, following operational requirements such as generation, transmission and ramp limits. In this model, we assume that the commitment decisions has been already made.

Simple Economic Dispatch Model

$$min \quad \sum_{t\in T}\sum_{g\in G^{NR}} P^{NR}_{g,t}C_g + \sum_{t\in T}\sum_{b\in B} V^{-}_{b,t} + \sum_{t\in T}\sum_{b\in B} V^{+}_{b,t} \tag{3.1a}$$

$$s.t. \quad \sum_{t\in T} P^{NR}_{g,t} + \sum_{t\in T} P^{R}_{g,t} + \sum_{t\in T} V^{-}_{b,t} = \sum_{t\in T} D_{b,t} + \sum_{t\in T} V^{+}_{b,t} \ \forall t \in T \tag{3.1b}$$

$$P^{NR}_{g,t} - P^{NR}_{g,t-1} \leq R^{up}_{g} \qquad \forall t \in T, g \in \mathcal{G}^R \tag{3.1c}$$

$$P^{NR}_{g,t-1} - P^{NR}_{g,t} \leq R^{down}_{g} \qquad \forall t \in T, g \in \mathcal{G}^R \tag{3.1d}$$

$$G^{min}_{g} \leq P^{NR}_{g,t} \leq G^{max}_{g} \qquad \forall t \in T, g \in \mathcal{G}^R \tag{3.1e}$$

The constraint 3.1b states the energy balance in every time. The constraints 3.1d and 3.1c states that every generator has to obey the ramp limits. The constraint 3.1e states the generation limits for each generator. The use of slack variables $V^{-}_{b,t}$ and $V^{+}_{b,t}$ is necessary to always have feasible solutions, and it is important for scenarios where there is a huge renewable penetrations, when there's an abrupt variation of generation and there is a over or under generation.

Economic Dispatch with Transmission Constraints

In this case, the model has to consider transmission limits and losses, without transmission costs associated. The objective function 3.1a remains the same, and the constraints 3.1c, 3.1d and 3.1e are als used. The constraint 3.1b is replaced by

$$\sum_{g\in G^b} P^{NR}_{g,t} + \sum_{g\in G^b} P^{R}_{g,t} + \sum_{b^{in}\in B} T_{b^{in},b,t} + V^{-}_{b,t} = D_{b,t} + V^{+}_{b,t} + \sum_{b^{out}\in B} T_{b,b^{out},t} \ \forall b \in B, t \in t \tag{3.2a}$$

$$T^{min}_{l} \leq T_{b^{in},b^{out},t} \leq T^{max}_{l} \qquad \forall b \in B, t \in t \tag{3.2b}$$

Constraint 3.2a guarantees that the energy balance is always satisfied for every bus: everything that is generated and received from other buses should be equal to what is loaded and sent throughout the line with the respective losses. If this balance is not satisfied then it is represented in the slack variables. (TODO: put lossed in the equation). The constraint 3.2b defines the transmission bounds for each line.

Economic dispatch model with unit commitment constraints

This optimization model is a mixed-integer linear program (MILP). This model includes decision variables to capture "on" and "off" decisions for thermal generators in each time period. The objective function must be modifies to account for start up and shut down costs with thermal generators.

3.3 Implementation

Here write about how it was implemented, in AIMMS, put some running times in a table, some images, put a brief description about what is AIMMS and why it is used, and etc. If I cite this one, will it apear? [1].

Chapter 4

Analysis

In the analysis make all the scenario runs, describe the data.

Chapter 5

Conclusion

Appendix A

Power Systems Operation Background

Appendix B

Data and Analysis

Bibliography

[1] D. Bertsimas, E. Litvinov, X. A. Sun, Jinye Zhao, and Tongxin Zheng. Adaptive robust optimization for the security constrained unit commitment problem. *Power Systems, IEEE Transactions on*, 28(1):52–63, 2013. ID: 1.

[2] Mary B. Cain, Richard P. Oneill, and Anya Castillo. History of optimal power flow and formulations. *Federal Energy Regulatory Commission*, 2012.

[3] David Connolly, Henrik Lund, Brian Vad Mathiesen, and Martin Leahy. A review of computer tools for analysing the integration of renewable energy into various energy systems. *Applied Energy*, 87(4):1059–1082, 2010.

[4] J. P. Deane, G. Drayton, and B. P. Gallachir. The impact of sub-hourly modelling in power systems with significant levels of renewable generation. *Applied Energy*, 113:152–158, 1 2014.

[5] E. B. Fisher, R. P. O'Neill, and M. C. Ferris. Optimal transmission switching. *Power Systems, IEEE Transactions on*, 23(3):1346–1355, 2008. ID: 1.

[6] L. L. Garver. Power generation scheduling by integer programming-development of theory. *Power Apparatus and Systems, Part III.Transactions of the American Institute of Electrical Engineers*, 81(3):730–734, 1962. ID: 1.

[7] Jeremy Hargreaves, Elaine K. Hart, Ryan Jones, and Arne Olson. Reflex: An adapted production simulation methodology for flexible capacity planning. *Power Systems, IEEE Transactions on*, 30(3):1306–1315, 2015.

[8] Chioke Harris, Jeremy P. Meyers, and Michael E. Webber. A unit commitment study of the application of energy storage toward the integration of renewable generation. *Journal of Renewable and Sustainable Energy*, 4(1):013120, 2012.

[9] John G. Kassakian, Richard Schmalensee, G. Desgroseilliers, Timothy D. Heidel, K. Afridi, AM Farid, JM Grochow, WW Hogan, HD Jacoby, and JL Kirtley. The future of the electric grid. *Massachusetts Institute of Technology, Tech.Rep*, 2011.

[10] A. Khodaei and M. Shahidehpour. Transmission switching in security-constrained unit commitment. *IEEE Transactions on Power Systems*, 25(4): 1937–1945, 2010. ID: 1.

[11] C. O'Dwyer and D. Flynn. Using energy storage to manage high net load variability at sub-hourly time-scales. *IEEE Transactions on Power Systems*, 30 (4):2139–2148, 2015. ID: 1.

[12] James Ostrowski, Miguel F. Anjos, and Anthony Vannelli. Tight mixed integer linear programming formulations for the unit commitment problem. *IEEE Transactions on Power Systems*, 27(1):39, 2012.

[13] Narayana Prasad Padhy. Unit commitment-a bibliographical survey. *Power Systems, IEEE Transactions on*, 19(2):1196–1205, 2004.

[14] B. Palmintier and M. Webster. Impact of unit commitment constraints on generation expansion planning with renewables. In *Power and Energy Society General Meeting, 2011 IEEE*, pages 1–7, 2011. ISBN 1944-9925. ID: 1.

[15] Hadi Saadat. *Power system analysis*. WCB/McGraw-Hill, 1999.

[16] Hossein Safaei and David W. Keith. How much bulk energy storage is needed to decarbonize electricity? *Energy and Environmental Science*, 8(12):3409–3417, 2015.

[17] Walter Short, Patrick Sullivan, Trieu Mai, Matthew Mowers, Caroline Uriarte, Nate Blair, Donna Heimiller, and Andrew Martinez. Regional energy deployment system (reeds). *Contract*, 303:275–3000, 2011.

[18] Hatim Y Yamin. Review on methods of generation scheduling in electric power systems. *Electric Power Systems Research*, 69(2):227–248, 2004.

[19] Yuan Zhiqiang, Hou Zhijian, and Jiang Chuanwen. Economic dispatch and optimal power flow based on chaotic optimization. In *Power System Technology, 2002. Proceedings. PowerCon 2002. International Conference on*, volume 4, pages 2313–2317 vol.4, 2002. ID: 1.

[20] H. Zhong, Q. Xia, Y. Wang, and C. Kang. Dynamic economic dispatch considering transmission losses using quadratically constrained quadratic program method. *IEEE Transactions on Power Systems*, 28(3):2232–2241, 2013. ID: 1.