

Convolutional Neural Network Approach to Devise Controller

Yunlong Dong

School of Automation

Huazhong University of Science and Technology

Email: dyl@hust.edu.cn

Xiangdi Liu

School of Automation

Huazhong University of Science and Technology

Email: lxd@hust.edu.cn

Abstract—PID controller is widely used in many fields. The input sequence and output sequence of a well-parameterized PID controller are transformed into a matrix presented in images, and a Every-Timestep data augmentation algorithm is operated. This paper propose a image to image Convolutional Neural Networks(CNN) structure to learn the PID controller, which firstly incorporating the successful methods in Computer Vision to control field. The simulation is performed using Matlab/Simulink and Keras[3]. The simulation demonstrates that the CNN controller is capable in performance.

I. INTRODUCTION

In practice PID controller is the mostly used common control algorithm in many fields. PID controller has very simple structure and if parameters tuned well can achieve high performance. Neural Network(NN) was proposed to compose a PID controller[9][10][11]. Neural Network is an information processing structure abstracted by the biological structure, consisting of processing element interconnected together with unidirectional signal channels called connections[1]. As the neural network has three advantages, has been widely used in pattern classification, system identification, image processing and other fields. First, Neural Network are data-driven self-adaptive methods. Second, they are universal functional approximators in that they can approximate any function. Third, Neural Networks are powerful nonlinear models, which makes them flexible in handling real world relationships. Over the last few years, machine learning algorithms have led to more efficient methods and traditional neural network has developed different structures for different problems. Cheon[2] proposed a deep learning method to learn the PID controller.

This study combines the images processing in Computer Vision with the control field, and propose a CNN controller to replace the PID controller. The simulation is performed using Matlab/Simulink and the detail of traditional PID controller and CNN controller was discussed.

This paper is organized as fellows. CNN is described in section II. In section III, Devise Controller is explained. The comparison details between the proposed CNN controller and traditional PID controller are presented with the simulation results are shown in section IV. Finally, a conclusion follows in section V.

II. CONVOLUTIONAL NEURAL NETWORK

Convolutional Neural Network(CNN) is a kind of structural variation of traditional neural network, utilizing layers with convolutional filters that are applied to extract features. After Alex Krizhevsky used Deep Convolutional Neural Networks in ImageNet classification problem[5], machine learning researcher reach a consensus that general CNN structure composed of convolution layer, pooling layer and fully connected layer. The structure is shown in Fig 1[5].

Originally invented for computer version[6], CNN models have subsequently been shown to be effective for many different problems including, Simultaneous Localization and Mapping(SLAM)[8], Decision Making[4] and Automatic Driving[1].

The Convolutional Neural Network(CNN) plays a significant role in image classification[5], image caption[12], image semantic segmentation[7] and so on. CNN can directly learn from raw images and automatically extract the feature which usually outperform handcrafted feature engineering. CNN uses filters to extract feature from high dimensional sensory data(especially images) and have reached enormous success in many fields.

III. DEVISE CONTROLLER

A. Traditional PID controller

To devise a novel controller, a traditional PID controller was first proposed to be the baseline. A well-parameterized PID controller was the target we want to mimic. The PID controller calculates the output in the following rule(continuous time) (1), where the k_p, k_i, k_d are the parameter to be settled in practice, e stands for the error in feedback control loop. The control scheme is showed in Fig 2.

$$u = k_p \times e + k_i \times \int e dt + k_d \times \frac{de}{dt} \quad (1)$$

The PID controller calculates the output based on the error sequence $\{e(0), e(1), e(2), \dots, e(T)\}$ in the rule(Discrete time) (2). Kangbeom Cheon[2] used a Deep Believe Network to learn the PID controller's input and output, but they do not analysis the underlying principle in PID controller. The PID controller in fact consists of three filter, proportional, integrate, differential. Using the powerful efficiency of Deep learning




Fig. 1. CNN structure




Fig. 2. PID control scheme

methods, the map between PID controller input and output can be easily learned via supervising learning. The learning scheme is shown in Fig 3.

$$u(k) = k_p \times e(k) + k_i \times \Delta t \sum_{i=0}^K e(i) + k_d \times \frac{e(k) - e(k-1)}{\Delta t} \quad (2)$$




Fig. 3. learning scheme

B. Transfer to Image

The error sequence $\{e(0), e(1), e(2), \dots, e(T)\}$ is the input of our learning algorithm(Deep learning methods). Instead of directly dropping the Sequence to the model, We analysis

the sequence first. The sequence is obviously as time sequence which implies the system response in time domain. The RNN[??] like models are capable of dealing with such sequence. But the time sequence is just a One-Dimensional relationship, we want further exploration. So we transform the error sequence to a matrix which has a spatial structure, which can contain more information. We samples 20s time(the default terminated time) in error with sample time 0.01s to get a 2000 length sequence. Then the Sequence is transformed into a 40×50 matrix called **error plane**. The same process was done in the output of PID controller called **u plane**. For visualization convenience, The matrix(One channel) are shown with colorful format in Fig 4.




Fig. 4. error plane(left), u plane(right)

As can be clearly seen, there is a pattern in the error plane and u plane. The u plane is like the blurry error plane. We can treat the sequence like image. There are many well-developed theory, models and algorithm processing images[?]. Now we transfer the learning controller problem to a image to image supervising learning problem.

C. Devise CNN controller

The architecture used to devise the controller is shown in Fig 5. The architecture has purely convolutional layers. The output of the CNN controller should have the same size with the input, so there no no pooling layers and Flatten layers . The first layer has $32 \ 3 \times 3$ filters with relu activation function, the second layer has the same filters as the first layer, and the




Fig. 5. The CNN controller architecture.

last layer have $1 \times 3 \times 3$ filter with relu activation function to make the output of CNN has size 40×50 .

Two-Dimensional convolutional operation can be written in eqn (3), where K is the filter with size $k_r \times k_c$, $In(s, t)$, $out(s, t)$ are the input and output of the convolutional operation with size $N_c \times N_r$ respectively. Through convolutional operation, the CNN is able to capture the relationship and maps between error plane and u plane. Semantic, we want the filter to learn the pid calculating rule eqn (2).

$$Out(s, t) = \sum_{m=0}^{k_r-1} \sum_{n=0}^{k_c-1} K(m, n) \times In(s-m, t-n) \quad (3)$$

s.t. $0 \leq s \leq N_r - 1, 0 \leq t \leq N - c - 1$

D. Training

In practice the whole length of error sequence is not able to obtain, cause the length of error increases as the controlling time passing. In general, in time step $k, k < 2000$, the error sequence is $\{e(0), e(1), e(2), \dots, e(k)\}$. We fullfill the sequence to length of 2000 with zeros to obtain $\{e(0), e(1), e(2), \dots, e(k), 0, 0, \dots\}$. In training we only gather the full-length error plane and u plane, in other words, only one pair of data is available. In controlling loop, every time step should obey the rule(???), so the error plane and u plane can be split in every time step to generate a called **Every-Timestep error-u** dataset. The detail goes in **Algorithm 1**. *error, u* are the error and u sequence with length T (default terminated time). Once the augmented dataset has been obtained. A mini-batch Stochastic Gradient Descent optimizer with *learning_rate* = 0.1, *batch_size* = 32, *momentum* = 0.9, *epochs* = 10 is used to train the CNN. Keras [3] was used to achieve these stuff. The results are shown in Fig 6. We use 70% of dataset to train and the rest 30% to test, and proving that overfitting did not appear. The visualization of training performance is shown in Fig 7.




Fig. 6. training results




Fig. 7. training visualization

Algorithm 1 Every-Timestep($error, u, T$)

```
1:  $error\_gen = Zeros[T, T]$ 
2:  $u\_gen = Zeros[T, T]$ 
3: for  $i = 1$  to  $T$  do
4:    $error\_gen[i, 1 : i] = error[1 : i]$ 
5:    $u\_gen[i, 1 : i] = u[1 : i]$ 
6: end for
7: return  $\{error\_gen, u\_gen\}$ 
```

IV. EVALUATION

In evaluation, we first parameterized a traditional PID controller in Simulink to simulate. The closed loop is shown in Fig 8. Then we replace the PID controller with our proposed CNN controller. Simulating in 2s. The comparing results of step response are shown in Fig 9. The CNN controller perform




Fig. 8. simulink model




Fig. 9. simulink model

almost the same with PID controller even a little more smooth.

V. CONCLUSION

In this paper, a Convolutional Neuron Networks controller was devised as an approach to replace the PID controller. So far this paper is the first to combine images with control, incorporating the successful methods in Computer Vision to control field, and propose a image to image CNN to learn the controller. The simulation demonstrates that the CNN controller is capable. We only apply the most used architecture CNN in this control problem, it is believing that there must be more architecture widely used in Computer Vision suitable to play a significant role in control field.

ACKNOWLEDGMENT

This research was supported by Ye Yuan, Professor of Control Theory, School of Automation, State Key Lab of Digital Manufacturing Equipment and Technology, Huazhong University of Science and Technology.

REFERENCES

- [1] Mariusz Bojarski, Davide Del Testa, Daniel Dworakowski, Bernhard Firner, Beat Flepp, Praseen Goyal, Lawrence D Jackel, Mathew Monfort, Urs Muller, Jiakai Zhang, et al. End to end learning for self-driving cars. *arXiv preprint arXiv:1604.07316*, 2016. 1
- [2] Kangbeom Cheon, Jaehoon Kim, Moussa Hamadache, and Dongik Lee. On replacing pid controller with deep learning controller for dc motor system. *Journal of Automation and Control Engineering Vol*, 3(6), 2015. 1
- [3] Francois Chollet. keras. <https://github.com/fchollet/keras>, 2015. 1, 3
- [4] Alessandro Giusti, Jérôme Guzzi, Dan C Cireşan, Fang-Lin He, Juan P Rodríguez, Flavio Fontana, Matthias Faessler, Christian Forster, Jürgen Schmidhuber, Gianni Di Caro, et al. A machine learning approach to visual perception of forest trails for mobile robots. *IEEE Robotics and Automation Letters*, 1(2):661–667, 2016. 1
- [5] Alex Krizhevsky, Ilya Sutskever, and Geoffrey E Hinton. Imagenet classification with deep convolutional neural networks. In F. Pereira, C. J. C. Burges, L. Bottou, and K. Q. Weinberger, editors, *Advances in Neural Information Processing Systems 25*, pages 1097–1105. Curran Associates, Inc., 2012. 1
- [6] Yann LeCun, Yoshua Bengio, et al. Convolutional networks for images, speech, and time series. 1
- [7] Jonathan Long, Evan Shelhamer, and Trevor Darrell. Fully convolutional networks for semantic segmentation. In *Proceedings of the IEEE Conference on Computer Vision and Pattern Recognition*, pages 3431–3440, 2015. 1
- [8] Tayyab Naseer, Michael Ruhnke, Cyrill Stachniss, Luciano Spinello, and Wolfram Burgard. Robust visual slam across seasons. In *Intelligent Robots and Systems (IROS), 2015 IEEE/RSJ International Conference on*, pages 2529–2535. IEEE, 2015. 1
- [9] F Shahraki, MA Fanaei, and AR Arjomandzadeh. Adaptive system control with pid neural networks. *Chemical Engineering Transactions*, (17):1395–1400, 2009. 1
- [10] Huailin Shu and Youguo Pi. Pid neural networks for time-delay systems. *Computers & Chemical Engineering*, 24(2):859–862, 2000. 1
- [11] Huailin Shu and Youguo Pi. Decoupled temperature control system based on pid neural network. *networks*, 1:8, 2005. 1
- [12] Kelvin Xu, Jimmy Ba, Ryan Kiros, Kyunghyun Cho, Aaron Courville, Ruslan Salakhudinov, Rich Zemel, and Yoshua Bengio. Show, attend and tell: Neural image caption generation with visual attention. In *International Conference on Machine Learning*, pages 2048–2057, 2015. 1