

Door Config Report

Door Config Report

Number of records found: 46.

Name	Value
BT 120A F11 Elev Lobby	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	15
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	

Name	Value
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon

Name	Value
Hardware	
Reader	BT 120A F11 Elev Lob Reader1 (Subpanel:0 Reader:1)
Alternate Reader	
Door Position	BT 120A F11 Elev Lobby DPOS (Subpanel:0 Input:1)
Strike	BT 120A F11 Elev Lobb Strike (Subpanel:0 Output:1)
Rex #1	BT 120A F11 Elev Lobby REX1 (Subpanel:0 Input:2)
Rex #2	
BT 121A NW Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SB Panel
Address	39
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30

Name	Value
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	

Name	Value
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 121A NW Garage Do Reader1 (Subpanel:0 Reader:1)
Alternate Reader	
Door Position	BT 121A NW Garage Door DPOS (Subpanel:0 Input:1)
Strike	BT 121A NW Garage Doo Strike (Subpanel:0 Output:1)
Rex #1	BT 121A NW Garage Door REX1 (Subpanel:0 Input:2)
Rex #2	
BT 121B NE Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	16
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	

Name	Value
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes

Name	Value
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 121B NE Garage Do Reader1 (Subpanel:0 Reader:2)
Alternate Reader	
Door Position	BT 121B NE Garage Door DPOS (Subpanel:0 Input:3)
Strike	BT 121B NE Garage Doo Strike (Subpanel:0 Output:2)
Rex #1	BT 121B NE Garage Door REX1 (Subpanel:0 Input:4)
Rex #2	
BT 121C SE Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	26
Access Type	Single

Name	Value
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	

Name	Value
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 121C SE Garage Do Reader1 (Subpanel:1 Reader:1)
Alternate Reader	
Door Position	BT 121C SE Garage Door DPOS (Subpanel:1 Input:1)
Strike	BT 121C SE Garage Doo Strike (Subpanel:1 Output:1)
Rex #1	BT 121C SE Garage Door REX1 (Subpanel:1 Input:2)
Rex #2	
BT 130A SW Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	

Name	Value
Installed	Yes
Panel	L02-SB Panel
Address	40
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	

Name	Value
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 130A SW Garage Do Reader1 (Subpanel:0 Reader:2)
Alternate Reader	
Door Position	BT 130A SW Garage Door DPOS (Subpanel:0 Input:3)
Strike	BT 130A SW Garage Doo Strike (Subpanel:0 Output:2)
Rex #1	BT 130A SW Garage Door REX1 (Subpanel:0 Input:4)
Rex #2	
BT 220A F12 Elev Lobby	

Name	Value
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	27
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	

Name	Value
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 220A F12 Elev Lob Reader1 (Subpanel:1 Reader:2)
Alternate Reader	

Name	Value
Door Position	BT 220A FI2 Elev Lobby DPOS (Subpanel:1 Input:3)
Strike	BT 220A FI2 Elev Lobb Strike (Subpanel:1 Output:2)
Rex #1	BT 220A FI2 Elev Lobby REX1 (Subpanel:1 Input:4)
Rex #2	
BT 221A NW Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SB Panel
Address	41
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1

Name	Value
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	

Name	Value
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 221A NW Garage Do Reader1 (Subpanel:1 Reader:1)
Alternate Reader	
Door Position	BT 221A NW Garage Door DPOS (Subpanel:1 Input:1)
Strike	BT 221A NW Garage Doo Strike (Subpanel:1 Output:1)
Rex #1	BT 221A NW Garage Door REX1 (Subpanel:1 Input:2)
Rex #2	
BT 221B NE Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	28
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30

Name	Value
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	

Name	Value
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 221B NE Garage Do Reader1 (Subpanel:2 Reader:1)
Alternate Reader	
Door Position	BT 221B NE Garage Door DPOS (Subpanel:2 Input:1)
Strike	BT 221B NE Garage Doo Strike (Subpanel:2 Output:1)
Rex #1	BT 221B NE Garage Door REX1 (Subpanel:2 Input:2)
Rex #2	
BT 221C SE Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	29
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN

Name	Value
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	

Name	Value
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 221C SE Garage Do Reader1 (Subpanel:2 Reader:2)
Alternate Reader	
Door Position	BT 221C SE Garage Door DPOS (Subpanel:2 Input:3)
Strike	BT 221C SE Garage Doo Strike (Subpanel:2 Output:2)
Rex #1	BT 221C SE Garage Door REX1 (Subpanel:2 Input:4)
Rex #2	
BT 230A SW Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SB Panel

Name	Value
Address	42
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	

Name	Value
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 230A SW Garage Do Reader1 (Subpanel:1 Reader:2)
Alternate Reader	
Door Position	BT 230A SW Garage Door DPOS (Subpanel:1 Input:3)
Strike	BT 230A SW Garage Doo Strike (Subpanel:1 Output:2)
Rex #1	BT 230A SW Garage Door REX1 (Subpanel:1 Input:4)
Rex #2	
BT 2F Stair 1	
Configuration and Communication Settings	
Alt Name	

Name	Value
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	30
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	

Name	Value
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 2F Stair 1 Reader1 (Subpanel:3 Reader:1)
Alternate Reader	
Door Position	BT 2F Stair 1 DPOS (Subpanel:3 Input:1)
Strike	BT 2F Stair 1 Strike (Subpanel:3 Output:1)
Rex #1	BT 2F Stair 1 REX1 (Subpanel:3 Input:2)

Name	Value
Rex #2	
BT 320A F13 Elev Lobby	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	31
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	

Name	Value
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	

Name	Value
Reader	BT 320A FI3 Elev Lob Reader1 (Subpanel:3 Reader:2)
Alternate Reader	
Door Position	BT 320A FI3 Elev Lobby DPOS (Subpanel:3 Input:3)
Strike	BT 320A FI3 Elev Lobb Strike (Subpanel:3 Output:2)
Rex #1	BT 320A FI3 Elev Lobby REX1 (Subpanel:3 Input:4)
Rex #2	
BT 321A NW Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SB Panel
Address	43
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5

Name	Value
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0

Name	Value
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 321A NW Garage Do Reader1 (Subpanel:2 Reader:1)
Alternate Reader	
Door Position	BT 321A NW Garage Door DPOS (Subpanel:2 Input:1)
Strike	BT 321A NW Garage Doo Strike (Subpanel:2 Output:1)
Rex #1	BT 321A NW Garage Door REX1 (Subpanel:2 Input:2)
Rex #2	
BT 321B NE Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	32
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5

Name	Value
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	

Name	Value
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 321B NE Garage Do Reader1 (Subpanel:4 Reader:1)
Alternate Reader	
Door Position	BT 321B NE Garage Door DPOS (Subpanel:4 Input:1)
Strike	BT 321B NE Garage Doo Strike (Subpanel:4 Output:1)
Rex #1	BT 321B NE Garage Door REX1 (Subpanel:4 Input:2)
Rex #2	
BT 321C SE Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	33
Access Type	Single
Door mode	Card or PIN

Name	Value
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes

Name	Value
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 321C SE Garage Do Reader1 (Subpanel:4 Reader:2)
Alternate Reader	
Door Position	BT 321C SE Garage Door DPOS (Subpanel:4 Input:3)
Strike	BT 321C SE Garage Doo Strike (Subpanel:4 Output:2)
Rex #1	BT 321C SE Garage Door REX1 (Subpanel:4 Input:4)
Rex #2	
BT 330A SW Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes

Name	Value
Panel	L02-SB Panel
Address	44
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	

Name	Value
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 330A SW Garage Do Reader1 (Subpanel:2 Reader:2)
Alternate Reader	
Door Position	BT 330A SW Garage Door DPOS (Subpanel:2 Input:3)
Strike	BT 330A SW Garage Doo Strike (Subpanel:2 Output:2)
Rex #1	BT 330A SW Garage Door REX1 (Subpanel:2 Input:4)
Rex #2	
BT 3F Stair 1	

Name	Value
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	34
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	

Name	Value
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 3F Stair 1 Reader1 (Subpanel:5 Reader:1)
Alternate Reader	
Door Position	BT 3F Stair 1 DPOS (Subpanel:5 Input:1)

Name	Value
Strike	BT 3F Stair 1 Strike (Subpanel:5 Output:1)
Rex #1	BT 3F Stair 1 REX1 (Subpanel:5 Input:2)
Rex #2	
BT 420A FI4 Elev Lobby	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	35
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1

Name	Value
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	

Name	Value
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 420A F14 Elev Lob Reader1 (Subpanel:5 Reader:2)
Alternate Reader	
Door Position	BT 420A F14 Elev Lobby DPOS (Subpanel:5 Input:3)
Strike	BT 420A F14 Elev Lobb Strike (Subpanel:5 Output:2)
Rex #1	BT 420A F14 Elev Lobby REX1 (Subpanel:5 Input:4)
Rex #2	
BT 421A NW Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SB Panel
Address	45
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30

Name	Value
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	

Name	Value
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 421A NW Garage Do Reader1 (Subpanel:3 Reader:1)
Alternate Reader	
Door Position	BT 421A NW Garage Door DPOS (Subpanel:3 Input:1)
Strike	BT 421A NW Garage Doo Strike (Subpanel:3 Output:1)
Rex #1	BT 421A NW Garage Door REX1 (Subpanel:3 Input:2)
Rex #2	
BT 421B NE Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	36
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN

Name	Value
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	

Name	Value
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 421B NE Garage Do Reader1 (Subpanel:6 Reader:1)
Alternate Reader	
Door Position	BT 421B NE Garage Door DPOS (Subpanel:6 Input:1)
Strike	BT 421B NE Garage Doo Strike (Subpanel:6 Output:1)
Rex #1	BT 421B NE Garage Door REX1 (Subpanel:6 Input:2)
Rex #2	
BT 421C SE Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel

Name	Value
Address	37
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	

Name	Value
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 421C SE Garage Do Reader1 (Subpanel:6 Reader:2)
Alternate Reader	
Door Position	BT 421C SE Garage Door DPOS (Subpanel:6 Input:3)
Strike	BT 421C SE Garage Doo Strike (Subpanel:6 Output:2)
Rex #1	BT 421C SE Garage Door REX1 (Subpanel:6 Input:4)
Rex #2	
BT 430A SW Garage Door	
Configuration and Communication Settings	
Alt Name	

Name	Value
Location	
Door Policy	
Installed	Yes
Panel	L02-SB Panel
Address	46
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	

Name	Value
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT 430A SW Garage Do Reader1 (Subpanel:3 Reader:2)
Alternate Reader	
Door Position	BT 430A SW Garage Door DPOS (Subpanel:3 Input:3)
Strike	BT 430A SW Garage Doo Strike (Subpanel:3 Output:2)

Name	Value
Rex #1	BT 430A SW Garage Door REX1 (Subpanel:3 Input:4)
Rex #2	
BT 4F Stair 1	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L02-SA Panel
Address	38
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	

Name	Value
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	

Name	Value
Reader	BT 4F Stair 1 Reader1 (Subpanel:7 Reader:1)
Alternate Reader	
Door Position	BT 4F Stair 1 DPOS (Subpanel:7 Input:1)
Strike	BT 4F Stair 1 Strike (Subpanel:7 Output:1)
Rex #1	BT 4F Stair 1 REX1 (Subpanel:7 Input:2)
Rex #2	
BT G001A (1) Parking Garage Rdr1	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SB Panel
Address	17
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5

Name	Value
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0

Name	Value
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT G001A (1) Parking Reader1 (Subpanel:0 Reader:1)
Alternate Reader	
Door Position	BT G001A (1) Parking Gar DPOS (Subpanel:0 Input:1)
Strike	BT G001A (1) Parking Strike (Subpanel:0 Output:1)
Rex #1	BT G001A (1) Parking Gar REX1 (Subpanel:0 Input:2)
Rex #2	
BT G001A (2) Parking Garage Rdr2	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SB Panel
Address	18
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5

Name	Value
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	

Name	Value
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT G001A (2) Parking Reader1 (Subpanel:0 Reader:2)
Alternate Reader	
Door Position	BT G001A (2) Parking Gar DPOS (Subpanel:0 Input:3)
Strike	BT G001A (2) Parking Strike (Subpanel:0 Output:2)
Rex #1	BT G001A (2) Parking Gar REX1 (Subpanel:0 Input:4)
Rex #2	
BT G53A SW Garage Door	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SB Panel
Address	19
Access Type	Single
Door mode	Card or PIN

Name	Value
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes

Name	Value
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT G53A SW Garage Do Reader1 (Subpanel:1 Reader:1)
Alternate Reader	
Door Position	BT G53A SW Garage Door DPOS (Subpanel:1 Input:1)
Strike	BT G53A SW Garage Doo Strike (Subpanel:1 Output:1)
Rex #1	BT G53A SW Garage Door REX1 (Subpanel:1 Input:2)
Rex #2	
BT G54A SW Staff Corridor	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes

Name	Value
Panel	L00-SB Panel
Address	20
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes

Name	Value
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT G54A SW Staff Cor Reader1 (Subpanel:1 Reader:2)
Alternate Reader	
Door Position	BT G54A SW Staff Corrido DPOS (Subpanel:1 Input:3)
Strike	BT G54A SW Staff Corr Strike (Subpanel:1 Output:2)
Rex #1	BT G54A SW Staff Corrido REX1 (Subpanel:1 Input:4)
Rex #2	
BT G57A North Garage Door	
Configuration and Communication Settings	

Name	Value
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SB Panel
Address	21
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	

Name	Value
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT G57A North Garage Reader1 (Subpanel:2 Reader:1)
Alternate Reader	
Door Position	BT G57A North Garage Doo DPOS (Subpanel:2 Input:1)
Strike	BT G57A North Garage Strike (Subpanel:2 Output:1)

Name	Value
Rex #1	BT G57A North Garage Doo REX1 (Subpanel:2 Input:2)
Rex #2	
BT G57B Outdoor Bay Lounge	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SB Panel
Address	22
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	

Name	Value
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	

Name	Value
Reader	BT G57B Outdoor Bay Reader1 (Subpanel:2 Reader:2)
Alternate Reader	
Door Position	BT G57B Outdoor Bay Loun DPOS (Subpanel:2 Input:3)
Strike	BT G57B Outdoor Bay L Strike (Subpanel:2 Output:2)
Rex #1	BT G57B Outdoor Bay Loun REX1 (Subpanel:2 Input:4)
Rex #2	
BT G65A NW Airlock Garage Side	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SB Panel
Address	23
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5

Name	Value
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0

Name	Value
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT G65A NW Airlock G Reader1 (Subpanel:3 Reader:1)
Alternate Reader	
Door Position	BT G65A NW Airlock Garag DPOS (Subpanel:3 Input:1)
Strike	BT G65A NW Airlock Ga Strike (Subpanel:3 Output:1)
Rex #1	BT G65A NW Airlock Garag REX1 (Subpanel:3 Input:2)
Rex #2	
BT G65B NW Airlock Hall Side	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SB Panel
Address	24
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5

Name	Value
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	

Name	Value
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT G65B NW Airlock H Reader1 (Subpanel:3 Reader:2)
Alternate Reader	
Door Position	BT G65B NW Airlock Hall DPOS (Subpanel:3 Input:3)
Strike	BT G65B NW Airlock Ha Strike (Subpanel:3 Output:2)
Rex #1	BT G65B NW Airlock Hall REX1 (Subpanel:3 Input:4)
Rex #2	
BT ST4-V SW Stair Vestibule	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SB Panel
Address	25
Access Type	Single
Door mode	Card or PIN

Name	Value
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes

Name	Value
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	BT ST4-V SW Stair Ve Reader1 (Subpanel:4 Reader:1)
Alternate Reader	
Door Position	BT ST4-V SW Stair Vestib DPOS (Subpanel:4 Input:1)
Strike	BT ST4-V SW Stair Ves Strike (Subpanel:4 Output:1)
Rex #1	BT ST4-V SW Stair Vestib REX1 (Subpanel:4 Input:2)
Rex #2	
G Stair 2	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes

Name	Value
Panel	L00-SA Panel
Address	13
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes

Name	Value
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G Stair 2 Reader1 (Subpanel:6 Reader:1)
Alternate Reader	
Door Position	G Stair 2 DPOS (Subpanel:6 Input:1)
Strike	G Stair 2 Strike (Subpanel:6 Output:1)
Rex #1	G Stair 2 REX1 (Subpanel:6 Input:2)
Rex #2	
G Stair 5	
Configuration and Communication Settings	

Name	Value
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	14
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	

Name	Value
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G Stair 5 Reader1 (Subpanel:6 Reader:2)
Alternate Reader	
Door Position	G Stair 5 DPOS (Subpanel:6 Input:3)
Strike	G Stair 5 Strike (Subpanel:6 Output:2)

Name	Value
Rex #1	G Stair 5 REX1 (Subpanel:6 Input:4)
Rex #2	
G10B Garage Airlock	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	1
Access Type	Single
Door mode	Card or PIN
Lock Function	None
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	No

Name	Value
Always Mask Held	No
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	No
Deny duress	No
Don't pulse door strike on REX	Yes
Require two card control	No
Door Forced Filter	No
Log all access as used	No
Detailed events	Yes
Enable cipher mode	No
Use Shunt Relay	No
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	No
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	

Name	Value
Reader	G10B Garage Airlock Reader1 (Subpanel:0 Reader:1)
Alternate Reader	
Door Position	G10B Garage Airlock DPOS (Subpanel:0 Input:1)
Strike	G10B Garage Airlock Strike (Subpanel:0 Output:1)
Rex #1	G10B Garage Airlock REX1 (Subpanel:0 Input:2)
Rex #2	
G11 Garage to G06	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	2
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5

Name	Value
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0

Name	Value
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G11 Garage to G06 Reader1 (Subpanel:0 Reader:2)
Alternate Reader	
Door Position	G11 Garage to G06 DPOS (Subpanel:0 Input:3)
Strike	G11 Garage to G06 Strike (Subpanel:0 Output:2)
Rex #1	G11 Garage to G06 REX1 (Subpanel:0 Input:4)
Rex #2	
G12B Walkway Airlock	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	3
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5

Name	Value
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	

Name	Value
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G12B Walkway Airlock Reader1 (Subpanel:1 Reader:1)
Alternate Reader	
Door Position	G12B Walkway Airlock DPOS (Subpanel:1 Input:1)
Strike	G12B Walkway Airlock Strike (Subpanel:1 Output:1)
Rex #1	G12B Walkway Airlock REX1 (Subpanel:1 Input:2)
Rex #2	
G30A Loading Dock Outside	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	4
Access Type	Single
Door mode	Card or PIN
Lock Function	

Name	Value
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	

Name	Value
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G30A Loading Dock Ou Reader1 (Subpanel:1 Reader:2)
Alternate Reader	
Door Position	G30A Loading Dock Outsidi DPOS (Subpanel:1 Input:3)
Strike	G30A Loading Dock Out Strike (Subpanel:1 Output:2)
Rex #1	G30A Loading Dock Outsidi REX1 (Subpanel:1 Input:4)
Rex #2	
G30C Loading Dock Inside	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel

Name	Value
Address	5
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	

Name	Value
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G30C Loading Dock In Reader1 (Subpanel:2 Reader:1)
Alternate Reader	
Door Position	G30C Loading Dock Inside DPOS (Subpanel:2 Input:1)
Strike	G30C Loading Dock Ins Strike (Subpanel:2 Output:1)
Rex #1	G30C Loading Dock Inside REX1 (Subpanel:2 Input:2)
Rex #2	
G31A Trash Collection Outside	
Configuration and Communication Settings	
Alt Name	

Name	Value
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	6
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	

Name	Value
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G31A Trash Collectio Reader1 (Subpanel:2 Reader:2)
Alternate Reader	
Door Position	G31A Trash Collection Ou DPOS (Subpanel:2 Input:3)
Strike	G31A Trash Collection Strike (Subpanel:2 Output:2)
Rex #1	G31A Trash Collection Ou REX1 (Subpanel:2 Input:4)

Name	Value
Rex #2	
G32B Holding Area Entrance	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	7
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	

Name	Value
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	

Name	Value
Reader	G32B Holding Area En Reader1 (Subpanel:3 Reader:1)
Alternate Reader	
Door Position	G32B Holding Area Entran DPOS (Subpanel:3 Input:1)
Strike	G32B Holding Area Ent Strike (Subpanel:3 Output:1)
Rex #1	G32B Holding Area Entran REX1 (Subpanel:3 Input:2)
Rex #2	
G39 Demarc	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	8
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5

Name	Value
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0

Name	Value
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G39 Demarc Reader1 (Subpanel:3 Reader:2)
Alternate Reader	
Door Position	G39 Demarc DPOS (Subpanel:3 Input:3)
Strike	G39 Demarc Strike (Subpanel:3 Output:2)
Rex #1	G39 Demarc REX1 (Subpanel:3 Input:4)
Rex #2	
G41 Slider to Beach	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	9
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5

Name	Value
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	

Name	Value
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G41 Slider to Beach Reader1 (Subpanel:4 Reader:1)
Alternate Reader	
Door Position	G41 Slider to Beach DPOS (Subpanel:4 Input:1)
Strike	G41 Slider to Beach Strike (Subpanel:4 Output:1)
Rex #1	G41 Slider to Beach REX1 (Subpanel:4 Input:2)
Rex #2	
G60A Fire Service	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	10
Access Type	Single
Door mode	Card or PIN
Lock Function	

Name	Value
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	

Name	Value
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G60A Fire Service Reader1 (Subpanel:4 Reader:2)
Alternate Reader	
Door Position	G60A Fire Service DPOS (Subpanel:4 Input:3)
Strike	G60A Fire Service Strike (Subpanel:4 Output:2)
Rex #1	G60A Fire Service REX1 (Subpanel:4 Input:4)
Rex #2	
G61 Fire Command	
Configuration and Communication Settings	
Alt Name	
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel

Name	Value
Address	11
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	
Door Processing Attributes	
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	

Name	Value
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G61 Fire Command Reader1 (Subpanel:5 Reader:1)
Alternate Reader	
Door Position	G61 Fire Command DPOS (Subpanel:5 Input:1)
Strike	G61 Fire Command Strike (Subpanel:5 Output:1)
Rex #1	G61 Fire Command REX1 (Subpanel:5 Input:2)
Rex #2	
G62 Exit Passageway	
Configuration and Communication Settings	
Alt Name	

Name	Value
Location	
Door Policy	
Installed	Yes
Panel	L00-SA Panel
Address	12
Access Type	Single
Door mode	Card or PIN
Lock Function	
Offline Door Mode	Card or PIN
Custom Mode	
Custom Schedule	
Access Time	5
Extended Access	10
Held Open Time	30
Extended Held Open Time	60
Held Pre-Alarm	5
Masked Forced Schedule	
LED Mode	1
Masked Held Schedule	
Always Mask Forced	
Always Mask Held	
Strike Mode	Cut short when open
Into Area	
Out of area	

Name	Value
Log grants right away	
Deny duress	
Don't pulse door strike on REX	Yes
Require two card control	
Door Forced Filter	
Log all access as used	
Detailed events	Yes
Enable cipher mode	
Use Shunt Relay	
Do Not Log Rex Transactions	Yes
Report Double Swipe Events	
Anti-Passback Settings	
APB Mode	
APB Delay	
PIN Settings	
PIN Timeout	0
PIN Attempts	0
Card Formats	
Card Formats	Corporate 1000 - 35 bit H10301 - 26 bit Wiegand FC 42 H10306 - 34 bit Wiegand HID10304 - 37 bit U100013 - 56 bit Avigilon
Hardware	
Reader	G62 Exit Passageway Reader1 (Subpanel:5 Reader:2)
Alternate Reader	
Door Position	G62 Exit Passageway DPOS (Subpanel:5 Input:3)
Strike	G62 Exit Passageway Strike (Subpanel:5 Output:2)
Rex #1	G62 Exit Passageway REX1 (Subpanel:5 Input:4)

Name	Value
Rex #2	