

ROUGH-IN REQUIREMENTS												
SYMBOL	ATTRIBUTE	DESCRIPTION	SHARED SERVICES				PATHWAY FEED	BACK BOX	BOX COVER/RING	MOUNTING	DETAIL REFERENCE	NUMBERED COMMENTS
			TEL	AV	ELEC	SEC						
		CARD READER, STANDARD				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	FLUSH IN WALL, 42" AFF TO CENTER	1 / 76.12	1, 3
	IL	CARD READER, INTEGRATED LOCK ASSEMBLY				•	-	-	N/A		11 / 76.12	1, 3
	M	CARD READER, MULLION MOUNT				•	(1) 3/4" CONDUIT			MULLION MOUNTED 42" AFF TO CENTER	2 / 76.12	1, 3
	P	CARD READER, PEDESTAL MOUNT				•	(1) 3/4" CONDUIT			PEDESTAL MOUNTED 42" TO CENTER	12 / 76.13	1, 3
		MAGNETIC DOOR CONTACT, CONCEALED				•	(1) 3/4" CONDUIT			FLUSH MOUNTED. SEE INSTALLATION DETAILS		1, 3
	WG	MAGNETIC DOOR CONTACT, SURFACE MOUNT, WIDE GAP				•	(1) 3/4" CONDUIT			SURFACE MOUNTED. SEE INSTALLATION DETAILS		1, 3
		DOOR HOLD OPEN RELEASE DEVICE				•	(1) 3/4" CONDUIT			REFER TO INSTALLATION DETAILS AND MANUFACTURER INSTALLATION MANUAL FOR MOUNTING INSTRUCTIONS		1, 3
		LOCAL AUDIBLE ALARM				•	(1) 3/4" CONDUIT	THREE GANG SUPER DEEP BOX	THREE GANG	FLUSH IN WALL, 42" AFF TO CENTER	3 / 76.12	1, 3
	CE	VIDEO CAMERA, FIXED, CEILING MOUNT, ELEVATOR				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	REFER TO INSTALLATION DETAILS AND MANUFACTURER INSTALLATION MANUAL FOR MOUNTING INSTRUCTIONS	1 / 76.10	1, 3
	CFA	VIDEO CAMERA, FIXED, CEILING MOUNT, ACCESSIBLE				•	N/A				2 / 76.10	1, 3
	CP	VIDEO CAMERA, FIXED, CEILING PENDANT MOUNT				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	TWO GANG	CEILING PENDANT MOUNT	4 / 76.10	1, 3
	TS	VIDEO CAMERA, FIXED, TRAY MOUNT				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	TWO GANG	TRAY MOUNT	7 / 76.10	1, 3
	WF	VIDEO CAMERA, FIXED, WALL MOUNT, FLUSH				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	REFER TO T0.05 FOR MOUNTING DETAILS	5 / 76.10	1, 3, 10
	WS	VIDEO CAMERA, FIXED, WALL MOUNT, SURFACE				•	(1) 1/2" CONDUIT		ONE GANG	REFER TO T0.05 FOR MOUNTING DETAILS	6 / 76.10	1, 3, 10
	CFA	VIDEO CAMERA, DUAL IMAGER, CEILING MOUNT, ACCESSIBLE				•	N/A	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	FLUSH MOUNTED TO CEILING	2 / 76.10	1, 3
	CP	VIDEO CAMERA, DUAL IMAGER, CEILING PENDANT MOUNT				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	TWO GANG	CEILING PENDANT MOUNT	4 / 76.10	1, 3
	WA	VIDEO CAMERA, DUAL IMAGER, WALL ARM MOUNT				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	REFER TO INSTALLATION DETAILS AND MANUFACTURER INSTALLATION MANUAL FOR MOUNTING INSTRUCTIONS	9 / 76.10	1, 3, 10
	CFA	VIDEO CAMERA, 270-FIXED, CEILING MOUNT, ACCESSIBLE				•	N/A			REFER TO T0.05 FOR MOUNTING DETAILS	2 / 76.10	1, 3
	CFI	VIDEO CAMERA, 270-FIXED, CEILING MOUNT, INACCESSIBLE				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	TWO GANG	FLUSH MOUNTED TO CEILING	3 / 76.10	1, 3
	CP	VIDEO CAMERA, 270-FIXED, CEILING PENDANT MOUNT				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	TWO GANG	CEILING PENDANT MOUNT	4 / 76.10	1, 3
	SCA	VIDEO CAMERA, 270-FIXED, CORNER WALL ARM MOUNT WITH BRACKET				•	(1) 3/4" CONDUIT	2-GANG BELL BOX		REFER TO T0.05 FOR MOUNTING DETAILS	8 / 76.10	1, 3, 10
	WA	VIDEO CAMERA, 270-FIXED, WALL ARM MOUNT WITH BRACKET				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	REFER TO T0.05 FOR MOUNTING DETAILS	9 / 76.10	1, 3, 10
	WF	VIDEO CAMERA, 270-FIXED, WALL MOUNT, FLUSH				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	REFER TO T0.05 FOR MOUNTING DETAILS	5 / 76.10	1, 3, 10
	WS	VIDEO CAMERA, 270-FIXED, WALL MOUNT, SURFACE				•	(1) 1/2" CONDUIT		ONE GANG	REFER TO T0.05 FOR MOUNTING DETAILS	6 / 76.10	1, 3, 10
	CFA	VIDEO CAMERA, 360-FIXED, CEILING MOUNT, ACCESSIBLE				•	N/A			FLUSH MOUNTED TO CEILING	2 / 76.10	1, 3
	CFI	VIDEO CAMERA, 360-FIXED, CEILING MOUNT, INACCESSIBLE				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	FLUSH MOUNTED TO CEILING	3 / 76.10	1, 3
	SCA	VIDEO CAMERA, 360-FIXED, WALL ARM CORNER MOUNT WITH BRACKET				•	(1) 3/4" CONDUIT	2-GANG BELL BOX		REFER TO T0.05 FOR MOUNTING DETAILS AND T6.10B FOR ADDITIONAL CONDUIT DETAILS	8 / 76.10	1, 3, 10
		GLASS BREAK SENSOR, WALL MOUNT				•	(1) 3/4" CONDUIT	SQUARE BOX, 5" SQ X 2 7/8" D	ONE GANG	SURFACE MOUNTED, 10" AFF	2 / 76.11	1, 3
		KEY PAD				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	FLUSH IN WALL, 42" AFF TO CENTER	1 / 76.14	1, 3
		MOTION DETECTOR, WALL MOUNT				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	SURFACE MOUNTED, 10" AFF	2 / 76.11	1, 3
	V	INTERCOM, PEDESTAL MOUNT WITH VIDEO				•	(1) 3/4" CONDUIT	MANUFACTURER FLUSH BACK BOX	N/A	REFER TO INSTALLATION DETAILS	10 / 76.12	1, 3
	BLV	INTERCOM, WALL MOUNT BLUE LIGHT ASSISTANCE UNIT WITH VIDEO				•	(2) 3/4" CONDUITS	MANUFACTURER FLUSH BACK BOX	N/A	REFER TO INSTALLATION DETAILS AND MANUFACTURER INSTALLATION MANUAL FOR MOUNTING INSTRUCTIONS	4 / 76.11	1, 3, 6
	V	INTERCOM, WALL MOUNT WITH VIDEO				•	(1) 3/4" CONDUIT	MANUFACTURER FLUSH BACK BOX	N/A	REFER TO T6.12T6.13 FOR MOUNTING DETAILS	5 / 76.13	1, 3
		GLASS BREAK SENSOR, CEILING MOUNT				•	(1) 3/4" CONDUIT	SQUARE BOX, 4" SQ X 2 1/8" D	ONE GANG	FLUSH MOUNTED TO CEILING	1 / 76.11	1, 3

- GENERAL COMMENTS:
- A. OUTLET HEIGHTS SHOWN IN THIS SCHEDULE ARE DEFAULT. REFER TO ARCHITECTURAL DRAWINGS, PARTICULARLY ELEVATIONS, TO CONFIRM ROUGH-IN HEIGHTS. ALSO REFER TO TELECOM PLANS, WHICH MAY SPECIFY A DIFFERENT HEIGHT PER INSTANCE.
- B. PROVIDE BLANK INSERTS IN UNUSED KNOCKOUTS.
- C. AT RATED BARRIERS, PROVIDE FIRESTOPPING/SEALING AROUND BOXES WHERE REQUIRED TO MAINTAIN RATING.
- D. WHEN OUTLET BACK BOXES FACE OPPOSITE SIDES OF A FRAMED WALL, INSTALL BOXES WITH AT LEAST ONE STUD BAY OR WITH 24 INCHES OF SEPARATION.
- E. LOCATE TELECOM OUTLETS ADJACENT AND AT THE SAME HEIGHT AS THE CORRESPONDING ELECTRICAL OUTLET. SHARED BACK BOX MOUNTING BRACKETS ARE ACCEPTABLE.
- OUTLETS/DEVICE CONDUIT REQUIREMENTS:
- F. PROVIDE A DEDICATED CONDUIT STUB PER OUTLET BOX. DO NOT Daisy-CHAIN OUTLET BOXES.
- G. PROVIDE A MINIMUM CONDUIT BEND RADIUS OF SIX TIMES THE INSIDE DIAMETER OF THE CONDUIT.
- H. PROVIDE A PULL BOX AFTER TWO 90-DEGREE BENDS OR 180-DEGREES OF TURNS. THE CONDUIT STUB-OUT INTO CEILING SPACE DOES NOT COUNT AS A BEND.
- I. ALLOWABLE CONSOLIDATION OF OUTLETS/DEVICE CONDUITS: THE CONSOLIDATED CONDUIT CAPACITY MUST EQUAL TO OR BE GREATER THAN THE AGGREGATE CAPACITY OF THE CONDUITS. PROVIDE A PULL BOX FOR CONDUIT CONSOLIDATION.
- J. PROVIDE A MINIMUM 12" X 12" X 4" PULL BOX FOR OUTLETS/DEVICE CONSOLIDATION POINTS.
- K. PROVIDE A PULL STRING IN EACH CONDUIT RUN. LEAVE WORKING SLACK IN THE PULL STRING AT EACH END; TIE OFF SLACK TO PREVENT RECOIL (BACK INTO THE CONDUIT).
- L. WHEN THE OUTLETS/DEVICE CONDUIT STUBS OUTSIDE THE ROOM IN WHICH THE OUTLET RESIDES, PROVIDE A LABEL ON THE CONDUIT STUB.
- NUMBERED COMMENTS:
1. PROVIDE CONDUIT STUB FROM ACCESSIBLE CEILING SPACE TO BOX; GENERALLY, TURN CONDUIT OUT WITHIN THE SAME ROOM. AVOID PENETRATING RATED BARRIERS - IF A PENETRATION THROUGH A RATED BARRIER IS REQUIRED, THEN MEET THROUGH PENETRATIONS REQUIREMENTS. PROVIDE A PULL STRING PER CONDUIT.
2. PROVIDE CONDUIT FROM ACCESSIBLE CEILING INTO ELEVATOR MACHINE ROOM AND CONNECT TO ELEVATOR CONTROL PANEL. CONDUITS MAY BE CONSOLIDATED AT A BACK BOX (SEE CONSOLIDATION REQUIREMENTS ON T0.02). COORDINATE INSTALLATION WITH THE ELEVATOR INSTALLATION.
3. COORDINATE THE INSTALLATION WITH SPECIALTY EQUIPMENT INSTALLATION (I.E. SECURITY, FIRE ALARM, INCLUDING OUTLET TYPE, INSTALLATION CONFIGURATION (LOCATION, HEIGHT, ETC.), AND CONNECTION TO EQUIPMENT).
4. PROVIDE CONTINUOUS CONDUIT FROM EQUIPMENT/SYSTEM CONTROL PANEL TO NEAREST TELECOMMUNICATIONS PRIMARY PATHWAY. PROVIDE A PULL STRING PER CONDUIT.
5. INSTALL BACK BOX ADJACENT TO POWER OUTLET. COORDINATE INSTALLATION WITH THE ELECTRICAL INSTALLATION. SHARED BOX BRACKETS ARE ACCEPTABLE.
6. OUTLET/BOX SHARED WITH ELECTRICAL. REFER TO ELECTRICAL DRAWINGS FOR OUTLET TYPE AND INSTALLATION REQUIREMENTS. COORDINATE INSTALLATION WITH THE ELECTRICAL INSTALLATION.
7. MOUNT BACK BOX TO THE SIDE OF THE WAP BRACKET.
8. PRIOR TO ROUGH-IN, VERIFY WITH THE SYSTEM VENDOR BACK BOX AND COVERING TYPE AND SIZE REQUIREMENTS. THE BOX AND COVERING TYPE AND SIZES LISTED IN THIS SCHEDULE ARE DEFAULT.
9. BOND BACK BOX TO APPROVED GROUND.
10. MOUNT EXTERIOR WALL-MOUNTED CAMERAS AT 10'-0" AFF UNLESS OTHERWISE NOTED. MOUNT INTERIOR WALL-MOUNTED CAMERAS AT 8'-0" AFF UNLESS OTHERWISE NOTED.



STAMP



DRW STAMP

REV	DATE	DESCRIPTION
1	05/15/2024	ISSUED FOR DEVELOPMENT
2	06/17/2024	ISSUED FOR CONSTRUCTION
3	07/01/2024	ISSUED FOR CONSTRUCTION
4	07/01/2024	ISSUED FOR CONSTRUCTION
5	07/01/2024	ISSUED FOR CONSTRUCTION
6	07/01/2024	ISSUED FOR CONSTRUCTION
7	07/01/2024	ISSUED FOR CONSTRUCTION
8	07/01/2024	ISSUED FOR CONSTRUCTION
9	07/01/2024	ISSUED FOR CONSTRUCTION
10	07/01/2024	ISSUED FOR CONSTRUCTION

ST. IGNATIUS COLLEGE PREPARATORY

SCHEDULE - ROUGH-IN

T0.03

2001 37th Ave, San Francisco, CA 94116