



敬业钢铁有限公司
Jingye Iron and Steel Co., Ltd.
质量证明书
Mill Test Certificate



中国认可
产品
PRODUCT
CNAS C162-P

GPC 18 P1 0002 R0 L 162 15 P1 0034 R0 L

订货单位 Customer			敬业钢铁有限公司						产品名称 Commodity				钢筋混凝土用钢：热轧带肋钢筋 STEEL REINFORCED CONCRETE: HOT ROLLED RIBBED BARS												
收货单位 Consignee			敬业钢铁有限公司						装车作业单编号 Loading Job No.				LT2502160131			质保书编号 Certificate No.			250216R00026						
执行标准 Standard			GB 1499. 2-2024						签发日期 Date of Issue				2025/02/16			合同编号 Contract No.			ZR250216015						
牌号 Grade			HRB400E						车号 Truck No.				冀 A04409D			发货日期 Date of Delivery			2025/02/16						
生产许可证编号 Permission No.			(冀)XK05-001-00001						交货状态 Delivery State				热轧 Hot rolled												
项次 ITEM No.	轧制批号 LOT No.	炉号 HEAT No.	规格 DIMENSION (mm)	件数 PCS	重量 Weight (t)	熔炼成分 Smelting Composition%										拉伸试验 x1 TENSILE TEST			最大 力总 延伸 Agt%	强 屈 比	屈 标 比	弯 曲 试 验 (反弯)	重 量 偏 差	金相 试验	
						C	Si	Mn	P	S	V	Cr	Nb	Ceq	屈服 RelY.S	抗拉 RmT.S	伸长 EL								
						⁻² X10	⁻² X10	⁻² X10	⁻³ X10	⁻³ X10	⁻³ X10	⁻³ X10	⁻³ X10	⁻² X10	MPa	MPa	%								
001	X125020073008	25A01930	Φ18 * 12000	18	56.16	21	36	132	29	31	27	26	4	46	430	595	23	13.9	1.37	1.09	合格	合格	合格		
															445	605	23	14.3	1.35	1.11	合格	合格	合格		
合计(TOTAL)				18	56.16																				
注释 NOTE		Y. S 屈服强度=Yield Strength T. S 抗拉强度=Tensile Strength E. L 断后伸长率=Percentage Elongation After Fracture >3mm 取短比例 式样, ≤3mm 取定标距 80mm. 最大力总延伸率 Agt%=Total elongation at maximum force.										强屈比=Tensile/yield strength ratio 屈标比=Yield Strength / Globe Standard's Yield Strength 弯曲试验(反弯)=Bending Test 弯曲角度=Angle Of Bend										重量偏差=Weight Tolerance			
备注 REMARK		测试单位和有关测试是按产品标准执行, 以上产品符合相关标准要求。请用户按产品批号验收, 如有质量异议请填写好质量异议函, 并将实物妥善保管好, 切勿动用。 TESTING UNITS AND RELEVANT TESTINGS COMPLY WITH PRODUCT STANDARDS, AND THE PRODUCTS ABOVE MEET THE RELEVANT STANDARDS. PLEASE LET CUSTOMER ACCEPT CARGO ACCORDING TO THE PRODUCT LOT NUMBER, IF THERE IS QUALITY CLAIM, PLEASE SEND US OFFICIAL LETTER WITH QUALITY CLAIM. PLEASE DO NOT USE THE PRODUCT AND KEEP THE PRODUCT SAFELY IN KIND.										于 辉 HUI YU			计量质检部部长 General manager, department of product testing			<div>敬业钢铁有限公司 Jingye Iron and Steel Co., Ltd.</div> <div>质量检验专用章 Quality inspection dedicated seal</div> <div>(1)</div>							