

Modeling and Estimation of Demand Responsive Loads


Scott Moura

Assistant Professor
Civil & Environmental Engineering
University of California, Berkeley

Institute of Cyber-Systems and Control
Zhejiang University


Hangzhou, China
August 29, 2013





Source: United Nations, DESA, Population Division. World Urbanization Prospects.

World Energy Consumption




Source: Vaclav Smil Estimates from Energy Transitions

Integrating Renewables


Ambitious targets:

- CA: 33% renewables by 2020
- US: 20% wind penetration by 2030
- Denmark: 50% wind penetration by 2025
- China: 15% renewables by 2020

Power Market Supply/Demand




Supply




Demand

Power Market Supply/Demand




Supply




Demand

Power Market Supply/Demand

Reality: Renewables are variable!



Supply



Demand

The Cost of Renewables w/o doing something “SMART”

Increased variability is THE problem!

Assuming 33% RE penetration, and current practices,
the following reserve capacity must be added [Helman 2010]:

- Load following: 2.3 GW → 4.4 GW
- Regulation: 227 MW → 1.4 GW


Added costs due to reserves at 15% renewable penetration

- \$2.50 - \$5 per MW of renewable generation [EWITS study, NREL, 2010]


Additional dirty and expensive reserves defeats benefits!

Power Market Supply/SMART Demand

Goal: Actual Demand with Demand Response (DR)



Supply



Demand

Outline

1 Modeling and Estimation for DR Loads

- Modeling Aggregations via PDEs
- State Estimation
- Parameter Identification
- UC Campus Implementation

2 PEV-Grid Integration

3 Summary

Outline

1 Modeling and Estimation for DR Loads

- Modeling Aggregations via PDEs
- State Estimation
- Parameter Identification
- UC Campus Implementation

2 PEV-Grid Integration

3 Summary

The DR Problem

Needs: Monitor & actuate (very) large populations of flexible loads

The DR Problem

Needs: Monitor & actuate (very) large populations of flexible loads

Obstacle: Scalability, sensing/control infrastructure

The DR Problem

Needs: Monitor & actuate (very) large populations of flexible loads

Obstacle: Scalability, sensing/control infrastructure

Definition (Thermostatically Controlled Loads):

Systems controlled by on-off actuation, e.g. HVAC, water heaters, freezers

The DR Problem

Needs: Monitor & actuate (very) large populations of flexible loads

Obstacle: Scalability, sensing/control infrastructure

Definition (Thermostatically Controlled Loads):

Systems controlled by on-off actuation, e.g. HVAC, water heaters, freezers

Some Interesting Facts

Thermostatically
Controlled Loads
(TCLs)

50% of U.S. electricity consumption is TCLs
11% of thermostats are programmed
Comfort is loosely coupled with control

The DR Problem

Needs: Monitor & actuate (very) large populations of flexible loads

Obstacle: Scalability, sensing/control infrastructure

Definition (Thermostatically Controlled Loads):

Systems controlled by on-off actuation, e.g. HVAC, water heaters, freezers

Some Interesting Facts


Thermostatically
Controlled Loads
(TCLs)

50% of U.S. electricity consumption is TCLs
11% of thermostats are programmed
Comfort is loosely coupled with control


The Punchline

Exploit flexibility of TCLs to decrease energy waste

Modeling TCLs



Modeling TCLs



$$\dot{T}_i(t) = \frac{1}{R_i C_i} [T_\infty - T_i(t) - s_i(t) R_i P_i], \quad i = 1, 2, \dots, N$$
$$s_i \in \{0, 1\}$$

Modeling Aggregated TCLs

Main Idea: Convert 1000+ ODEs into two coupled linear PDEs

Modeling Aggregated TCLs


Main Idea: Convert 1000+ ODEs into two coupled linear PDEs

$$\begin{array}{l|l} u(T, t) & \# \text{TCLs / } ^\circ\text{C, in COOL state, @ temp } T, \text{ time } t \\ v(T, t) & \# \text{TCLs / } ^\circ\text{C, in HEAT state, @ temp } T, \text{ time } t \end{array}$$

Modeling Aggregated TCLs

Main Idea: Convert 1000+ ODEs into two coupled linear PDEs

$$\begin{array}{l|l} u(T, t) & \# \text{TCLs / } ^\circ\text{C, in COOL state, @ temp } T, \text{ time } t \\ v(T, t) & \# \text{TCLs / } ^\circ\text{C, in HEAT state, @ temp } T, \text{ time } t \end{array}$$



Modeling Aggregated TCLs

Main Idea: Convert 1000+ ODEs into two coupled linear PDEs

$$\begin{array}{l|l} u(T, t) & \# \text{TCLs / } ^\circ\text{C, in COOL state, @ temp } T, \text{ time } t \\ v(T, t) & \# \text{TCLs / } ^\circ\text{C, in HEAT state, @ temp } T, \text{ time } t \end{array}$$

Flux of TCLs in HEAT state:

#TCLs / sec

$$\psi(T, t) = v(T, t) \frac{dT}{dt}(t) = \frac{1}{RC} [T_\infty - T(t)] v(T, t)$$

Modeling Aggregated TCLs

Main Idea: Convert 1000+ ODEs into two coupled linear PDEs


$u(T, t)$	# TCLs / °C, in COOL state, @ temp T , time t
$v(T, t)$	# TCLs / °C, in HEAT state, @ temp T , time t

Flux of TCLs in HEAT state:

#TCLs / sec

$$\psi(T, t) = v(T, t) \frac{dT}{dt}(t) = \frac{1}{RC} [T_\infty - T(t)] v(T, t)$$

Control volume:



Modeling Aggregated TCLs

Main Idea: Convert 1000+ ODEs into two coupled linear PDEs


$$\begin{array}{l|l} u(T, t) & \# \text{TCLs / } ^\circ\text{C, in COOL state, @ temp } T, \text{ time } t \\ v(T, t) & \# \text{TCLs / } ^\circ\text{C, in HEAT state, @ temp } T, \text{ time } t \end{array}$$

Flux of TCLs in HEAT state:

#TCLs / sec


$$\psi(T, t) = v(T, t) \frac{dT}{dt}(t) = \frac{1}{RC} [T_\infty - T(t)] v(T, t)$$

Control volume:




$$\begin{aligned} \frac{\partial v}{\partial t}(T, t) &= \lim_{\delta T \rightarrow 0} \left[\frac{\psi(T + \delta T, t) - \psi(T, t)}{\delta T} \right] \\ &= \frac{\partial \psi}{\partial T}(T, t) \\ &= -\frac{1}{RC} [T_\infty - T(t)] \frac{\partial v}{\partial T}(T, t) + \frac{1}{RC} v(T, t) \end{aligned}$$

PDE Model of Aggregated TCLs



PDE Model of Aggregated TCLs



$$u_t(T, t) = \alpha \lambda(T) u_T(T, t) + \alpha u(T, t)$$


$$v_t(T, t) = -\alpha \mu(T) v_T(T, t) + \alpha v(T, t)$$

$$u(T_{\max}, t) = q_1 v(T_{\max}, t)$$

$$v(T_{\min}, t) = q_2 u(T_{\min}, t)$$

Video of 1,000 TCLs

PDE Model of Aggregated TCLs



$$u_t(T, t) = \alpha \lambda(T) u_T(T, t) + \alpha u(T, t)$$

$$v_t(T, t) = -\alpha \mu(T) v_T(T, t) + \alpha v(T, t)$$

$$u(T_{\max}, t) = q_1 v(T_{\max}, t)$$

$$v(T_{\min}, t) = q_2 u(T_{\min}, t)$$

Original Idea: Malhame and Chong, Trans. on Automatic Control (1985)
Remark: Assumes homogeneous populations

Modeling Heterogeneous Aggregated TCLs

Reality: TCL populations are heterogeneous

e.g. variable heat capacity, power, deadband sizes

Video of 1,000 heterogeneous TCLs

Modeling Heterogeneous Aggregated TCLs

Reality: TCL populations are heterogeneous

e.g. variable heat capacity, power, deadband sizes

$$u_t(T, t) = \alpha\lambda(T)u_T(T, t) + \alpha u(T, t) + \beta u_{TT}(T, t)$$

$$v_t(T, t) = -\alpha\mu(T)v_T(T, t) + \alpha v(T, t) + \beta v_{TT}(T, t)$$

$$u(T_{\max}, t) = q_1 v(T_{\max}, t), \quad u_T(T_{\min}, t) = -v_T(T_{\min}, t)$$

$$v(T_{\min}, t) = q_2 u(T_{\min}, t), \quad v_T(T_{\max}, t) = -u_T(T_{\max}, t)$$

Modeling Heterogeneous Aggregated TCLs

Reality: TCL populations are heterogeneous

e.g. variable heat capacity, power, deadband sizes

$$u_t(T, t) = \alpha\lambda(T)u_T(T, t) + \alpha u(T, t) + \beta u_{TT}(T, t)$$

$$v_t(T, t) = -\alpha\mu(T)v_T(T, t) + \alpha v(T, t) + \beta v_{TT}(T, t)$$

$$u(T_{\max}, t) = q_1 v(T_{\max}, t), \quad u_T(T_{\min}, t) = -v_T(T_{\min}, t)$$

$$v(T_{\min}, t) = q_2 u(T_{\min}, t), \quad v_T(T_{\max}, t) = -u_T(T_{\max}, t)$$


Proposition: The total number of TCLs is conserved over time.

$$Q(t) = \int_{T_{\min}}^{T_{\max}} u(T, t) dT + \int_{T_{\min}}^{T_{\max}} v(T, t) dT$$

$$\frac{dQ}{dt}(t) = 0, \quad \forall t$$

Video Evolution of Heterogeneous PDE

Model Comparison



The State Estimation Problem

Question: Possible to monitor TCLs with minimal sensing infrastructure?

The State Estimation Problem

Question: Possible to monitor TCLs with minimal sensing infrastructure?

Answer: YES! Use state estimation.

The State Estimation Problem


Question: Possible to monitor TCLs with minimal sensing infrastructure?

Answer: YES! Use state estimation.

Problem Statement

Estimate states $u(T, t)$, $v(T, t)$ from measurements of HVAC on/off signals

Finite-dimensional system:



The State Estimation Problem


Question: Possible to monitor TCLs with minimal sensing infrastructure?

Answer: YES! Use state estimation.

Problem Statement

Estimate states $u(T, t)$, $v(T, t)$ from measurements of HVAC on/off signals

Infinite-dimensional system:



PDE State Estimator

Heterogeneous PDE Model: (u, v)

$$u_t(x, t) = \alpha\lambda(x)u_x + \alpha u + \beta u_{xx}$$

$$u_x(0, t) = -v_x(0, t)$$

$$u(1, t) = q_1 v(1, t)$$

$$v_t(x, t) = -\alpha\mu(x)v_x + \alpha v + \beta v_{xx}$$

$$v(0, t) = q_2 u(0, t)$$

$$v_x(1, t) = -u_x(1, t)$$

Measurements?

- $u(0, t), v(1, t)$
- $u_x(1, t), v_x(0, t)$

PDE State Estimator

Estimator: (\hat{u}, \hat{v})

$$\hat{u}_t(x, t) = \alpha\lambda(x)\hat{u}_x + \alpha\hat{u} + \beta\hat{u}_{xx} + p_1(x) [u(0, t) - \hat{u}(0, t)]$$

$$\hat{u}_x(0, t) = -v_x(0, t) + p_{10} [u(0, t) - \hat{u}(0, t)]$$

$$\hat{u}(1, t) = q_1 v(1, t)$$

$$\hat{v}_t(x, t) = -\alpha\mu(x)\hat{v}_x + \alpha\hat{v} + \beta\hat{v}_{xx} + p_2(x) [v(1, t) - \hat{v}(1, t)]$$

$$\hat{v}(0, t) = q_2 u(0, t)$$

$$\hat{v}_x(1, t) = -u_x(1, t) + p_{20} [v(1, t) - \hat{v}(1, t)]$$

PDE State Estimator

Estimation Error Dynamics: $(\tilde{u}, \tilde{v}) = (u - \hat{u}, v - \hat{v})$

$$\tilde{u}_t(x, t) = \alpha\lambda(x)\tilde{u}_x + \alpha\tilde{u} + \beta\tilde{u}_{xx} - \textcolor{magenta}{p_1}(x)\tilde{u}(0, t)$$

$$\tilde{u}_x(0, t) = -\textcolor{magenta}{p_{10}}\tilde{u}(0, t)$$

$$\tilde{u}(1, t) = 0$$

$$\tilde{v}_t(x, t) = -\alpha\mu(x)\tilde{v}_x + \alpha\tilde{v} + \beta\tilde{v}_{xx} - \textcolor{magenta}{p_2}(x)\tilde{v}(1, t)$$

$$\tilde{v}(0, t) = 0$$

$$\tilde{v}_x(1, t) = -\textcolor{magenta}{p_{20}}\tilde{v}(1, t)$$

PDE State Estimator

Estimation Error Dynamics: $(\tilde{u}, \tilde{v}) = (u - \hat{u}, v - \hat{v})$

$$\tilde{u}_t(x, t) = \alpha\lambda(x)\tilde{u}_x + \alpha\tilde{u} + \beta\tilde{u}_{xx} - p_1(x)\tilde{u}(0, t)$$

$$\tilde{u}_x(0, t) = -p_{10}\tilde{u}(0, t)$$

$$\tilde{u}(1, t) = 0$$

$$\tilde{v}_t(x, t) = -\alpha\mu(x)\tilde{v}_x + \alpha\tilde{v} + \beta\tilde{v}_{xx} - p_2(x)\tilde{v}(1, t)$$

$$\tilde{v}(0, t) = 0$$

$$\tilde{v}_x(1, t) = -p_{20}\tilde{v}(1, t)$$

Goal: Design estimation gains:

- $p_1(x), p_2(x) : (0, 1) \rightarrow \mathbb{R}$
- $p_{10}, p_{20} \in \mathbb{R}$

such that $(\tilde{u}, \tilde{v}) = (0, 0)$ is exponentially stable

Backstepping Observer Design

Error Dynamics: \tilde{u}

$$\begin{aligned}\tilde{u}_t(x, t) &= \alpha\lambda(x)\tilde{u}_x + \alpha\tilde{u} + \beta\tilde{u}_{xx} - \textcolor{magenta}{p}_1(x)\tilde{u}(0, t) \\ \tilde{u}_x(0, t) &= -\textcolor{magenta}{p}_{10}\tilde{u}(0, t) \\ \tilde{u}(1, t) &= 0\end{aligned}$$

Backstepping Observer Design

Error Dynamics: \tilde{u}

$$\begin{aligned}\tilde{u}_t(x, t) &= \alpha\lambda(x)\tilde{u}_x + \alpha\tilde{u} + \beta\tilde{u}_{xx} - \textcolor{magenta}{p}_1(x)\tilde{u}(0, t) \\ \tilde{u}_x(0, t) &= -\textcolor{magenta}{p}_{10}\tilde{u}(0, t) \\ \tilde{u}(1, t) &= 0\end{aligned}$$

Eliminate advection terms, “Gauge” Transformation

$$\xi(x, t) = \tilde{u}(x, t)e^{\frac{\alpha}{2\beta} \int_0^x \lambda(s)ds}$$

Backstepping Observer Design

Transformed error state: ξ

$$\begin{aligned}\xi_t(x, t) &= \beta \xi_{xx} + g(x)\xi - p_1^\xi(x)\xi(0, t) \\ \xi_x(0, t) &= p_{10}^\xi \xi(0, t) \\ \xi(1, t) &= 0\end{aligned}$$

$$\begin{aligned}g(x) &= \alpha \left[1 - \frac{\lambda'(x)}{2} \right] - \frac{\alpha^2 \lambda^2(x)}{4\beta} \\ p_1^\xi(x) &= p_1(x) e^{\frac{\alpha}{2\beta} \int_0^x \lambda(s) ds} \\ p_{10}^\xi &= \frac{\alpha}{2\beta} \lambda(0) - p_{10}\end{aligned}$$

Backstepping Observer Design

Transformed error state: ξ

$$\begin{aligned}\xi_t(x, t) &= \beta \xi_{xx} + g(x)\xi - p_1^\xi(x)\xi(0, t) \\ \xi_x(0, t) &= p_{10}^\xi \xi(0, t) \\ \xi(1, t) &= 0\end{aligned}$$

Backstepping transformation

$$\xi(x, t) = w_1(x, t) - \int_0^x p(x, y)w_1(y, t)dy$$

Backstepping Observer Design

Transformed error state: ξ

$$\begin{aligned}\xi_t(x, t) &= \beta \xi_{xx} + g(x)\xi - p_1^\xi(x)\xi(0, t) \\ \xi_x(0, t) &= p_{10}^\xi \xi(0, t) \\ \xi(1, t) &= 0\end{aligned}$$

Backstepping transformation

$$\xi(x, t) = w_1(x, t) - \int_0^x p(x, y)w_1(y, t)dy$$

Target system: w_1 , exp. stable in \mathcal{L}^2 -norm

$$\begin{aligned}w_{1t}(x, t) &= \beta w_{1xx}(x, t) - c_1 w_1(x, t), \quad c_1 \geq 0 \\ w_{1x}(0, t) &= w_1(0, t) \\ w_1(1, t) &= 0\end{aligned}$$

Backstepping Observer Design

Kernel PDE: $p(x, y)$

$$\begin{aligned}\beta p_{xx}(x, y) - \beta p_{yy}(x, y) &= -[c_1 + g(x)] p(x, y) \\ p(x, x) &= -\frac{1}{2\beta} \int_x^1 [c_1 + g(s)] ds \\ p(1, y) &= 0\end{aligned}$$

Backstepping Observer Design

Kernel PDE: $p(x, y)$

$$\begin{aligned}\beta p_{xx}(x, y) - \beta p_{yy}(x, y) &= -[c_1 + g(x)] p(x, y) \\ p(x, x) &= -\frac{1}{2\beta} \int_x^1 [c_1 + g(s)] ds \\ p(1, y) &= 0\end{aligned}$$

Estimation gains

$$\begin{aligned}p_1^\xi(x) &= -\beta [p(x, 0) + p_y(x, 0)] \\ p_{10}^\xi &= 1 - p(0, 0) \\ p_1(x) &= p_1^\xi(x) e^{-\frac{\alpha}{2\beta} \int_0^x \lambda(s) ds} \\ p_{10} &= \frac{\alpha}{2\beta} \lambda(0) - p_{10}^\xi\end{aligned}$$

Video Evolution of PDE estimator

Key point: Converges to true distribution, using only HVAC on/off signals.

Parameter Identification

$$u_t(x, t) = \alpha\lambda(x)u_x + \alpha u + \beta u_{xx}$$

$$v_t(x, t) = -\alpha\mu(x)v_x + \alpha v + \beta v_{xx}$$

$$u_x(0, t) = -v_x(0, t)$$

$$v(0, t) = q_2 u(0, t)$$

$$u(1, t) = q_1 v(1, t)$$

$$v_x(1, t) = -u_x(1, t)$$

$$P(t) = \frac{\bar{P}}{\eta} \int_0^1 u(x, t) dx$$

Parameter Identification

$$u_t(x, t) = \alpha\lambda(x)u_x + \alpha u + \beta u_{xx}$$

$$u_x(0, t) = -v_x(0, t)$$

$$u(1, t) = q_1 v(1, t)$$

$$v_t(x, t) = -\alpha\mu(x)v_x + \alpha v + \beta v_{xx}$$

$$v(0, t) = q_2 u(0, t)$$

$$v_x(1, t) = -u_x(1, t)$$

$$P(t) = \frac{\bar{P}}{\eta} \int_0^1 u(x, t) dx$$

Algorithm #1: Power-based Identification [DSCC13]

- Assumes measurements of aggregate power consumption & B.C.'s

Parameter Identification

$$u_t(x, t) = \alpha\lambda(x)u_x + \alpha u + \beta u_{xx}$$

$$u_x(0, t) = -v_x(0, t)$$

$$u(1, t) = q_1 v(1, t)$$

$$v_t(x, t) = -\alpha\mu(x)v_x + \alpha v + \beta v_{xx}$$

$$v(0, t) = q_2 u(0, t)$$

$$v_x(1, t) = -u_x(1, t)$$

$$P(t) = \frac{\bar{P}}{\eta} \int_0^1 u(x, t) dx$$

Algorithm #1: Power-based Identification [DSCC13]

- Assumes measurements of aggregate power consumption & B.C.'s

Algorithm #2: Passive Identifier [IJC]


- Assumes full state measurements

Algorithm #3: Swapping Identifier [IJC]

- Assumes full state measurements

Output Regulation Problem

[Callaway, 2009]



- $P(t) \approx w(t)$
- Tracking error $\approx 1\%$
- Setpoint changes $\approx 0.1^\circ C$

UC San Diego Campus: A Living Laboratory




UC San Diego Campus: A Living Laboratory

Goal: Exploit Flexible Loads in Bldgs

- ① Deploy wireless sensor network
- ② Model/estimator verification
- ③ Control design
- ④ Campus implementation




Libelium Waspmotes and Meshlium Gateway



BUILDING ROBOTICS

Harmonizing energy use and comfort in commercial buildings.



Software platform for collecting building energy data
Prof. David Culler's Group | EECS @ UC Berkeley

Campus Map

Click a highlighted building to view energy usage information.


Zoom In

[Zoom out](#)

Reset


Popup Building List

[Close Building List](#)



Software platform for collecting building energy data
Prof. David Culler's Group | EECS @ UC Berkeley

Hierarchical Control/Monitoring Structure



Outline

1 Modeling and Estimation for DR Loads

- Modeling Aggregations via PDEs
- State Estimation
- Parameter Identification
- UC Campus Implementation

2 PEV-Grid Integration

3 Summary

The PEV-Grid Integration Problem

Obstacle: PEVs impose unprecedented constraints and demands on grid

The PEV-Grid Integration Problem

Obstacle: PEVs impose unprecedented constraints and demands on grid

Opportunities: (1) Mitigate PEV load; (2) Exploit online disturbed energy storage

The PEV-Grid Integration Problem

Obstacle: PEVs impose unprecedented constraints and demands on grid

Opportunities: (1) Mitigate PEV load; (2) Exploit online disturbed energy storage

Some Interesting Facts

Plug-in Electric
Vehicles
(PEVs)

Potentially dispatchable loads
“carbitrage” opportunity
Firm variable renewables

The PEV-Grid Integration Problem

Obstacle: PEVs impose unprecedented constraints and demands on grid

Opportunities: (1) Mitigate PEV load; (2) Exploit online disturbed energy storage

Some Interesting Facts

Plug-in Electric
Vehicles
(PEVs)

Potentially dispatchable loads
“carbitrage” opportunity
Firm variable renewables

The Punchline

Exploit flexibility of PEV charging to enhance efficiency across infrastructures

Modeling Aggregated PEVs


Main Idea: Mathematically model as coupled linear PDEs

$$\begin{array}{l|l} u(T, t) & \# \text{PEVs / SOC, in DISCHARGE state, @ SOC } x, \text{ time } t \\ v(T, t) & \# \text{PEVs / SOC, in CHARGE state, @ SOC } x, \text{ time } t \end{array}$$

Modeling Aggregated PEVs

Main Idea: Mathematically model as coupled linear PDEs


$$\begin{array}{l|l} u(T, t) & \# \text{PEVs / SOC, in DISCHARGE state, @ SOC } x, \text{ time } t \\ v(T, t) & \# \text{PEVs / SOC, in CHARGE state, @ SOC } x, \text{ time } t \end{array}$$



Modeling Aggregated PEVs

Main Idea: Mathematically model as coupled linear PDEs

$$\begin{array}{l|l} u(T, t) & \# \text{PEVs / SOC, in DISCHARGE state, @ SOC } x, \text{ time } t \\ v(T, t) & \# \text{PEVs / SOC, in CHARGE state, @ SOC } x, \text{ time } t \end{array}$$



Open Questions: Modeling, state estimation, control/optimization, implementation

When to charge PEVs?

Research Question:


When to charge PEV's to maximize consumer-side benefits?

Objectives:

Fuel & electricity cost, battery health


Decision variables:

When, how long, at what rate?



Multiobjective Optimization



Energy Cost vs. Battery Health



Infrastructure Req's?

Research Question:
Sensitivity to:
Underlying Data:

Does charging at work lower peak loads?
Fuel/electricity price, battery size, health vs. energy
NHTS Survey, UMTRI driving patterns



Outline

1 Modeling and Estimation for DR Loads

- Modeling Aggregations via PDEs
- State Estimation
- Parameter Identification
- UC Campus Implementation

2 PEV-Grid Integration

3 Summary

Summary of TCL Modeling & Estimation

① Modeling

- Aggregate dynamics via PDEs
- Homogeneous vs. Heterogeneous

② Estimation

- State observer via PDE backstepping
- Parameter identification algorithms

③ UCSD Campus Deployment

④ PEV-Grid Integration

- Extension of aggregation approach

Collaborators



Prof. Jan Bendsten
Dept. of Electronic Systems
Aalborg University, Denmark



Prof. Miroslav Krstic
Mechanical & Aerospace Engineering
Univ. of California, San Diego

Xie Xie!

Visit us at

<http://faculty.ce.berkeley.edu/moura/>

smoura@berkeley.edu