


| | | |
|---|---|---|
|  | Cincinnati Fire Department Fire Training Supplement DRILL BOOK | SECTION #8 Minimum Company Standards |
| Date: May 2018 | TOPIC TITLE: | Total # of Pages: 1 |
| Section #: 8 | Quick Water – Major Fire / Exposure Control | Topic #: 22 |

Title: Quick Water – Major Fire / Exposure Control

Task Level: Company (4 personnel)

Equipment Needed: Engine Company, 5” supply, 2-1/2” Fire Line with 1-1/8” tip, deck mounted master stream with 1-1/2” tip, hydrant, Safe Location without traffic safety hazards.

Recommended Time: 3 minutes

Instruction:

- Stage Engine and assigned personnel away from fire hydrant. When personnel are ready, give signal and proceed to the hydrant.
- TIME STARTS WHEN ENGINE STOPS AT HYDRANT
- Forward lay 5” supply line a distance of 200’
- Immediately start deck gun on pre-determined target
- Hook up 5” and transfer from tank to hydrant water supply
- No water loss for more than 15 seconds
- Deploy 2-1/2” fire line and position for exposure control
- FAO Starts water in 2-1/2” – flow minimum of 300 gpm on simulated exposure
- Time stops when supply line, deck gun and 2-1/2” fire line are all flowing water.

Evaluation: Pass or Fail

Re-Testing: If a company fails to meet time restraints or are stopped due to unsafe acts, they will be given an additional opportunity to pass the evolution in one month.

Critical Criteria:

- Failure to meet time limit
- Failure to wear full PPE
- Failure to advance proper hose lengths or flow proper GPM
- Failure to transfer from tank water to hydrant water.
- Up to 15 second water interruption is acceptable, more than 15 seconds is unacceptable
- Unsafe acts as interpreted by the evaluator