

	Cincinnati Fire Department Fire Training Supplement DRILL BOOK	SECTION #8 Minimum Company Standards
Date: May 2018	TOPIC TITLE:	Total # of Pages: 1
Section #: 8	Quick Water – 1-3/4” Fire Line	Topic #: 27

Title: Quick Water – 1-3/4” Fire Line to Front Door

Task Level: Company (4 personnel)

Equipment Needed: Engine Company, 5” supply, 1-3/4” Fire Line 250 feet,
Safe Location without traffic safety hazards.

Recommended Time: 1 minute (from air brake after laying off)

Instruction:

- Stage Engine and assigned personnel away from fire hydrant. When personnel are ready, give signal and proceed to the hydrant.
- Forward lay 5” supply line a distance of 100 to 200’ – leaving a FF at the hydrant
- ***TIME STARTS WHEN ENGINE STOPS AT SCENE***
- FF & Officer deploy fire line w/o kinks to front door, don PPE & call for water
- Start flowing water into front door – ***TIME STOPS WHEN WATER IS FLOWING CONTINUOUSLY***
- Hydrant water is called for, start water in hydrant, transfer from tank water to hydrant water and re-fill apparatus tank.

Evaluation: Pass or Fail

Re-Testing: If a company fails to meet time restraints or are stopped due to unsafe acts, they will be given an additional opportunity to pass the evolution in one month.

Critical Criteria:

- Failure to meet time limit of 1-3/4” Stretch & PPE Donning w/ Water on the Fire
- Failure to wear full PPE
- Starting the hydrant before being asked or charging 5” bed
- Unsafe acts as interpreted by the evaluator