
	Cincinnati Fire Department Fire Training Supplement DRILL BOOK	SECTION #8 Minimum Company Standards
Date: January 2006	TOPIC TITLE:	Total # of Pages: 2
Section #: 8	Forward Lead with 2-1/2" / Gated Wye and Attack Line Deployment	Topic #: 3

<u>Title:</u>	Forward Lead with 2-1/2" hose with Gated Wye and Attack Line Deployment
<u>Task Level:</u>	1 Company (4 personnel)
<u>Equipment Needed:</u>	1 Engine Company, 5" Supply Line, 2-1/2" Hose, Gated Wye, 1-3/4" Attack Lines with Nozzle, Hydrant, Safe location without traffic safety hazards
<u>Recommended Time:</u>	4 minutes
<u>Reference:</u>	NFPA 1410, 2000 Edition, Training for Initial Scene Operations
<u>Instruction:</u>	<ul style="list-style-type: none"> • Stage 1st Engine Company and assigned personnel away from the hydrant. When personnel are ready, give signal and proceed to the hydrant. • TIME STARTS WHEN 1st ENGINE STOPS AT HYDRANT. • Forward Lay 100' 5" supply from hydrant to simulated fire area • Advance 300' of 2-1/2" hose and Gated Wye • Advance hose pack attack line 150' from gated wye • Officer calls for water when the line is advanced • Flow 150 GPM from the initial hose line • FAO transfers from the tank to the hydrant • Stop the time when all lines are supplied and flowing properly
<u>Evaluation:</u>	Pass or Fail
<u>Re-Testing:</u>	If companies fail to meet the required time limit or are stopped due to unsafe acts they will be given an additional opportunity to pass the evolution in one month.
<u>Critical Criteria:</u>	Failure to meet time limit Failure to wear full PPE Failure to advance proper length of hose Failure to supply proper GPM Failure to transfer from tank to hydrant supply properly. Up to 10 second interruption in water supply deliver is acceptable, more than 10 seconds is unacceptable Unsafe acts as interpreted by the evaluator

	Cincinnati Fire Department Fire Training Supplement DRILL BOOK	SECTION #8 Minimum Company Standards
Date: January 2006	TOPIC TITLE:	Total # of Pages: 2
Section #: 8	Forward Lead with 2-1/2" / Gated Wye and Attack Line Deployment	Topic #: 3

Topic Number 3 Description

