	<b>Cincinnati Fire Department Fire Training Supplement DRILL BOOK</b>	<b>SECTION #8 Minimum Company Standards</b>
Date: January 2006	<b>TOPIC TITLE:</b> Front Suction – Portable Master Stream Deployment	Total # of Pages: 2
Section #: 8		Topic #: 6

**Title:** Master Stream Deployment – Portable Mounted

**Task Level:** Company (4 personnel)

**Equipment Needed:** Engine Company, Portable Master Stream Mount, 5” Supply Line, Hydrant  
Safe location without traffic safety hazards

**Recommended Time:** 3 minutes

**Reference:** NFPA 1410, 2000 Edition, Training for Initial Scene Operations

**Instruction:**


- Stage Engine Company and assigned personnel away from fire area. When personnel are ready, give signal and proceed to the fire area.
- TIME STARTS WHEN ENGINE STOPS AT FIRE AREA.
- Remove Master Stream, Portable Mount and 5” Supply Line
- Reverse Lay 5” supply line a distance of 300 feet.
- FAO hooks into hydrant upon arrival
- Remaining personnel assist in hooking up master stream device to supply line
- Officer orders water started when it is hooked up
- Officer request 1000 GPM to be supplied to device
- FAO transfers from the tank to the hydrant
- Stop the time when all lines are supplied and flowing properly

**Evaluation:** Pass or Fail

**Re-Testing:** If companies fail to meet the required time limit or are stopped due to unsafe acts they will be given an additional opportunity to pass the evolution in one month.

**Critical Criteria:**

Failure to meet time limit  
Failure to wear full PPE  
Failure to supply proper GPM  
Failure to transfer from tank to hydrant supply properly. Up to 10 second interruption in water supply deliver is acceptable, more than 10 seconds is unacceptable  
Failure to properly secure master stream device  
Failure to know rotation and elevation limits of the portable device  
Unsafe acts as interpreted by the evaluator

	<b>Cincinnati Fire Department Fire Training Supplement DRILL BOOK</b>	<b>SECTION #8</b> Minimum Company Standards
Date: January 2006	<b>TOPIC TITLE:</b>	Total # of Pages: 2
Section #: 8	Front Suction – Portable Master Stream Deployment	Topic #: 6

**Topic 6 Description:**

