




1		2		3		4		5		6		7		8			
<div>CERTIFICATION OF THE QUALITY SYSTEM OF THE COMPANIES</div> <div></div> <div>UNI EN 29001 ISO 9001</div> <div>Member of</div> <div></div>	CODIGO	DESCRIPCION APARATO				CANT.	CONSTRUCTOR	TIPO	DATOS TECNICOS		CEDA NUMERO		HOJA Y COLUM.				
	–A0–S1	CONMUTADOR VOLTIMETRICO				1	BLUM	V3/16E/FS/X70S–A1086	/		/		/100.4				
	–A0–S21	TERMOSTATO				1	FANTI COSMI	C10A	0–60C		3289000002		/104.2				
	–A0–T1	TRANSFORMADOR MONOFASICO				1	GIPE	2.5KVA	380Vñ5%/220V 50/60Hz		3293000238		/102.4				
	–A0–T2	TRANSFORMADOR MONOFASICO				1	GIPE	2.5KVA	380Vñ5%/110V 50/60Hz		3293000237		/102.2				
	–A0–T3	TRANSFORMADOR TRIFASICO				1	GIPE	3KVA	380Vñ5%/220V 50/60Hz		3291000250		/100.7				
	–A0–T4	TRANSFORMADOR AMPERIMETRICO				1	FRER	/	800/5A		/		/100.4				
	–A0–T5	TRANSFORMADOR TRIFASICO				1	GIPE	1KVA	380Vñ5%/18Vñ10% 50/60Hz		3293000239		/100.7				
	–A0–V1	PUENTE DE DIODOS SEMICONDUCTORES				1	SEMIKRON	SKD 30/08	/		/		/102.6				
	–A0–V1	DISIPADOR PARA PUENTE DE DIODOS SEMICONDUCTORES				1	SEMIKRON	P5/100	/		/		/102.6				
According to law CENTRO AUTOMATION SpA considers this document to be a company secret and therefore prohibits any person to reproduce or disclose it in whole or part to third parties, without specific written authorization of CENTRO AUTOMATION SpA Management	–A0–Z0	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/108.3				
	–A0–Z1	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/108.4				
	–A0–Z2	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/108.5				
	–A0–Z3	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/108.6				
	–A0–Z4	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/108.4				
	–A0–Z10	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/110.3				
	–A0–Z11	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/110.4				
	–A0–Z12	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/110.5				
	–A0–Z13	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/110.6				
	–A0–Z14	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/110.4				
–A0–Z20	FILTRO RC				1	LUTZE	LRC–S6–0321	110/230Vac 50/60Hz		3361000035		/112.3					
AutoCAD–COMPUTER AIDED DESIGN 3302-802																	
○																	
3				Fecha	27/01/1997		SIPAR				LINEA ENTRANTE		Servicios auxiliares acabadora		= 30BB.F02		
2			Encarg.	VENDRAME		+											
1	EMISION PARA CONE 97	GLEREAN	Contr.	VENDRAME													
	Modificacion	Fecha	Nombr	Norma	IEC	Obtenido de:		Reemplazo para:		Reemplaz. por:		Descript.		30620	Nº: 3062–D30–E3302	Hoja 802 804 Sigue	
ft. DIN6771/Teil 5		1		2		3		4		5		6		7		8	

626.16E–008–802–3