



	1	2	3	4	5	6	7	8	
A	○	CODIGO	DESCRIPCION APARATO	CANT.	CONSTRUCTOR	TIPO	DATOS TECNICOS	CEDA NUMERO	HOJA Y COLUM.
		-A12-F1	BASE TRIPOLAR	1	SIEMENS	3NH4030	160A 660V NH00	3162000064	/340.2
		-A12-F1	FUSIBLE	3	SIEMENS	3NA3814	NH00 gG 35A 500V 120kA	3162000022	/340.2
		-A12-F2	BASE TRIPOLAR	1	SIEMENS	3NH4030	160A 660V NH00	3162000064	/340.3
		-A12-F2	FUSIBLE	3	SIEMENS	3NA3820	NH00 gG 50A 500V 120kA	3162000024	/340.3
	CERTIFICATION OF THE QUALITY SYSTEM OF THE COMPANIES  <small>UNI EN 29001 ISO 9001</small> Member of 	-A12-H1	LUZ ROJA PILOTO	1	SIEMENS	3SB1001-6BC06	í22	3181000001	/348.3
		-A12-H1	SOPORTE PARA 3 BLOQUES DE CONTACTOS	1	SIEMENS	3SB1902-1AC	/	3282000023	/348.3
		-A12-H1	BLOQUE PORTALAMPARA	1	SIEMENS	3SB1400-2A	BA9S	3181000011	/348.3
		-A12-H1	LAMPARA	1	VIMEX	BA9S	130Vac 2W 10x28	/	/348.3
		-A12-H10	PANEL ALARMAS	1	C.Z.	CZ011	12 alarm 24Vdc	/	/354.4
B	○	-A12-K1	CONTACTOR TRIPOLAR	1	SIEMENS	3TF4722-0AF0	110Vac 50Hz	3211000022	/344.3
		-A12-K21	RELAIS	1	WEIDMULLER	RS30 cod. 110022	24Vdc W2	/	/348.3
		-A12-K22	RELAIS	1	WEIDMULLER	RS30 cod. 110022	24Vdc W2	/	/348.3
		-A12-K23	RELAIS	1	WEIDMULLER	RS30 cod. 110022	24Vdc W2	/	/348.3
		-A12-K24	RELAIS	1	WEIDMULLER	RS30 cod. 110022	24Vdc W2	/	/348.3
	According to law CENTRO AUTOMATION SpA considers this document to be a company secret and therefore prohibits any person to reproduce or disclose it in whole or part to third parties, without specific written authorization of CENTRO AUTOMATION SpA Management ○	-A12-K29	RELE SOBRE ZOCALO UNDECAL	1	SCHRACK	MT301,024	24Vdc W3	/	/350.6
		-A12-K29	ZOCALO UNDECAL PARA RELE CON DIODO	1	SCHRACK	MR78,110	/	/	/350.6
		-A12-K30	RELE SOBRE ZOCALO UNDECAL	1	SCHRACK	MT301,024	24Vdc W3	/	/350.6
		-A12-K30	ZOCALO UNDECAL PARA RELE CON DIODO	1	SCHRACK	MR78,110	/	/	/350.6
		-A12-K31	RELAIS	1	WEIDMULLER	RS30 cod. 110022	24Vdc W2	/	/348.3
C	○	-A12-L1	BOBINA TRIPOLAR para INVERTER AC/DC	1	GIPE	0.251mH	78/117A 50Hz	3225000323	/340.3
		-A12-L2	BOBINA TRIPOLAR para INVERTER AC/DC	1	GIPE	0.251mH	78/117A	3225000324	/340.3
		-A12-P1	AMPERIMETRO	1	FRER	F96M	0-100A senales 0-1mA	/	/340.5
		-A12-Q1	AISLADOR TRIPOLAR AC/DC	1	SIEMENS	3NP5060-0CA10	250A 660V	/	/340.2
		-A12-Q1	FUSIBLE	3	SIEMENS	3NE1820-0	80A/690V GR.00 EXTRAR.	/	/340.2
	○	-A12-Q2	INTERRUPTOR AUT. BIPOLAR AC/DC	1	SIEMENS	5SX2 202-7	2A	3265000020	/340.4
		-A12-Q3	INTERRUPTOR AUT. UNIPOLAR AC/DC	1	SIEMENS	5SX2 103-7	3A	3265000005	/344.3
		-A12-Q10	INTERRUPTOR AUT. UNIPOLAR AC/DC	1	SIEMENS	5SX2 102-7	2A	3265000004	/342.2
		-A12-R1	RESISTENCIA	1	SIR	RDP 4000	20hm 4kW	/	/340.2
		-A12-R2	RESISTENCIA	1	SIR	RDP 4000	20hm 4kW	/	/340.2
D	○	-A12-S2	BOTON NEGRO	1	SIEMENS	3SB1000-0AB20	í22	3282000001	/348.6
		-A12-S2	SOPORTE PARA 3 BLOQUES DE CONTACTOS	1	SIEMENS	3SB1902-1AC	/	3282000023	/348.6
		-A12-S2	CONTACTOS AUXILIAR	1	SIEMENS	3SB1400-0A	1NO+1NC	3282000024	/348.6
		-A12-S3	SELECTOR 3 POS. CON RETORNO A 0	1	SIEMENS	3SB1000-2EB20	í22	3282000017	/348.6
		-A12-S3	SOPORTE PARA 3 BLOQUES DE CONTACTOS	1	SIEMENS	3SB1902-1AC	/	3282000023	/348.6
	AutoCAD-COMPUTER AIDED DESIGN 3302-826	-A12-S3	CONTACTOS AUXILIAR	1	SIEMENS	3SB1400-0A	1NO+1NC	3282000024	/348.6
		-A12-U1	INVERTER	1	SIEMENS	6SE7027-2ED10	65.5A/98.3A	/	/340.2
		-A12-U2	GRUPO DE FRENADO	1	SIEMENS	6SE7031-6EB87-2DA0	/	/	/340.1
		-A12-Z1	FILTRO RC	1	LUTZE	LRC-V2-0.68	110/230Vac 50/60Hz	3361000036	/344.3
E	○								
F	○								
	3			Fecha	27/01/1997	SIPAR		= 30BB.F02	
	2	DESP. PRUEBAS	ABR 97	GLEREAN	Encarg				
	1	EMISION PARA CON	ENE 97	GLEREAN	Contr.				
		Modificacion	Fecha	Nombre	Norma	IEC	Obtenido de:	Reemplazo para:	Reemplaz. por:
ft. DIN6771/Teil 5		1	2	3	4	5	6	7	8

626.16E-008-826-3

CON ROLOS LOCOS VERT. SECT. 2

30620

N°3062-D30-E3302

Hoja 826
828 Sigue