




<div>CERTIFICATION OF THE QUALITY SYSTEM OF THE COMPANIES</div> <div></div> <div>UNI EN 29001 ISO 9001</div> <div>Member of</div> <div></div>	1	2	3	4	5	6	7	8			
	CODIGO	DESCRIPCION APARATO			CANT.	CONSTRUCTOR	TIPO	DATOS TECNICOS	CEDA NUMERO	HOJA Y COLUM.	
	-A13-H1	LUZ ROJA PILOTO			1	SIEMENS	3SB1001-6BC06	122	3181000001	/360.5	
	-A13-H1	SOPORTE PARA 3 BLOQUES DE CONTACTOS			1	SIEMENS	3SB1902-1AC	/	3282000023	/360.5	
	-A13-H1	BLOQUE PORTALAMPARA			1	SIEMENS	3SB1400-2A	BA9S	3181000011	/360.5	
	-A13-H1	LAMPARA			1	VIMEX	BA9S	130Vac 2W 10x28	/	/360.5	
	-A13-F1	RELE TERMICO			1	SIEMENS	3UC6200-3A	100-160A	/	/360.2	
	-A13-K1	CONTACTOR TRIPOLAR			1	SIEMENS	3TF5422-0AF0	110Vac 50Hz	3211000026	/360.5	
	-A13-K2	CONTACTOR TRIPOLAR			1	SIEMENS	3TK5222-0AF0	110Vac 50Hz	/	/360.5	
	-A13-K3	CONTACTOR TRIPOLAR			1	SIEMENS	3TF5122-0AF0	110Vac 50Hz	3211000112	/360.5	
<div>According to law CENTRO AUTOMATION SpA considers this document to be a company secret and therefore prohibits any person to reproduce or disclose it in whole or part to third parties, without specific written authorization of CENTRO AUTOMATION SpA Management</div> <div></div>	-A13-K4	RELE SOBRE ZOCALO UNDECAL			1	SCHRAK	MT306,115	115Vac 50Hz W3	/	/360.6	
	-A13-K4	ZOCALO UNDECAL PARA RELE			1	SCHRAK	MR78,700	/	3213000061	/360.6	
	-A13-K5	CONTADOR RETRASO RELE			1	SIEMENS	7PU4620-2AJ20	110Vac	/	/360.4	
	-A13-K6	RELE SOBRE ZOCALO UNDECAL			1	SCHRAK	MT301,024	24Vdc W3	/	/360.6	
	-A13-K6	ZOCALO UNDECAL PARA RELE CON DIODO			1	SCHRAK	MR78,110	/	/	/360.6	
	-A13-Q1	AISLADOR TRIPOLAR AC/DC			1	SIEMENS	3NP5460-0CA10	630A 660V	/	/360.2	
	-A13-Q1	FUSIBLE			3	SIEMENS	3NE3334-0B	500A/1000V GR.2 EXTRAR.	/	/360.2	
	-A13-Q2	INTERRUPTOR AUT. UNIPOLAR AC/DC			1	SIEMENS	5SX2 101-7	1A	3265000002	/360.3	
	-A13-Q3	INTERRUPTOR AUT. UNIPOLAR AC/DC			1	SIEMENS	5SX2 105-7	0.5A	3265000001	/360.2	
	-A13-Q11	INTERRUPTOR AUT. UNIPOLAR AC/DC			1	SIEMENS	5SX2 103-7	3A	3265000005	/360.6	
	-A13-S2	BOTON NEGRO			1	SIEMENS	3SB1000-0AB20	122	3282000001	/360.4	
	-A13-S2	SOPORTE PARA 3 BLOQUES DE CONTACTOS			1	SIEMENS	3SB1902-1AC	/	3282000023	/360.4	
	-A13-S2	CONTACTOS AUXILIAR			1	SIEMENS	3SB1400-0A	1NO+1NC	3282000024	/360.4	
	-A13-U1	SOFT STARTER			1	SIEMENS	3RW2238-0AB15	235A	/	/3602	
	-A13-Z1	FILTRO RC			1	LUTZE	LRC-VM1-1	110/230Vac 50/60Hz	3361000037	/360.5	
	-A13-Z3	FILTRO RC			1	LUTZE	LRC-V2-0.68	110/230Vac 50/60Hz	3361000036	/360.5	
	-A13-Z4	FILTRO RC			1	SCHRAK	MRM-UO 524	24/115Vac	/	/360.6	
	-A13-Z5	FILTRO RC			1	LUTZE	LRC-S6-0321	110/230Vac 50/60Hz	3361000035	/360.4	
	<div>AutoCAD-COMPUTER AIDED DESIGN 3302-828</div>										
<div></div>											
3				Fecha	27/01/1997		= 30BB.F02				
2	DESP. PRUEBAS	ABR 97	GLEREAN	Encarg	VENDRAME		Servicios auxiliares acabadora			+	
1	EMISION PARA CON	ENE 97	GLEREAN	Contr.	VENDRAME		30620			N°3062-D30-E3302	
	Modificacion	Fecha	Nombr	Norma	IEC	Obtenido de:	Reemplazo para:	Reemplaz. por:	Descript.	Hoja 828	
ft. DIN6771/Teil 5 1 2 3 4 5 6 7 8											

626.16E-008-828-3