

	1	2	3	4	5	6	7	8				
A	○	CODIGO	DESCRIPCION APARATO	CANT.	CONSTRUCTOR	TIPO	DATOS TECNICOS	CEDA NUMERO	HOJA Y COLUM.			
		-A17-K1	CONTACTOR TRIPOLAR	1	SIEMENS	3TF4022-0AF0	110Vac 50Hz	/	/386.5			
		-A17-K2	RELE SOBRE ZOCALO UNDECAL	1	SCHRAK	MT301,024	24Vdc W3	/	/386.6			
		-A17-K2	ZOCALO UNDECAL PARA RELE CON DIODO	1	SCHRAK	MR78,110	/	/	/386.6			
	-A17-Q1	AISLADOR TRIPOLAR AC/DC	1	SIEMENS	3NP5060-0CA10	160A 660V	/	/386.2				
	-A17-Q1	FUSIBLE	3	SIEMENS	3NA3803	NH00 gG 10A 500V 120kA	3162000017	/386.2				
	-A17-Q11	INTERRUPTOR AUT. UNIPOLAR AC/DC	1	SIEMENS	5SX2 103-7	3A	3265000005	/386.6				
	-A17-Z1	FILTRO RC	1	LUTZE	LRC-S6-0321	110/230Vac 50/60Hz	3361000035	/386.5				
B	<div>CERTIFICATION OF THE QUALITY SYSTEM OF THE COMPANIES</div> <div> UNI EN 29001 ISO 9001</div> <div>Member of</div> <div></div>											
C	According to law CENTRO AUTOMATION SpA considers this document to be ○ a company secret and therefore prohibits any person to ○ reproduce or disclose it in whole or part to third parties, without specific written authorization of CENTRO AUTOMATION SpA Management											
D	According to law CENTRO AUTOMATION SpA considers this document to be ○ a company secret and therefore prohibits any person to ○ reproduce or disclose it in whole or part to third parties, without specific written authorization of CENTRO AUTOMATION SpA Management											
E	AutoCAD-COMPUTER AIDED DESIGN 3302-836											
F	○											
3				Fecha	27/01/1997	SIPAR			CALENTADOR ACEITE CMA	Servicios auxiliares acabadora	= 30BB.F02	
2				Encarg.	VENDRAME						+	
1	EMISION PARA CONE 97	GLEREAN	Contr.	VENDRAME								
	Modificacion	Fecha	Nombre	Norma	IEC	Obtenido de:	Reemplazo para:	Reemplaz. por:	Descript.	30620	N°3062-D30-E3302	Hoja 836 838 Sigue
ft. DIN6771/Teil 5		1	2		3	4		5	6	7		8

626.16E-008-836-3