Items for BHT-003GCLW

1. **Device Features:**
    a. Temperature
    b. Device On
    c. Device Off
    d. Manual Mode
    e. Programmable Mode
    f. Child Lock Enable
    g. Child Lock Disable
    h. Energy Saving Mode Enable
    i. Energy Saving Mode Disable
    j. Time Scheduling
    k. Current Temperature of Internal Sensor
    l. Current Temperature of External Sensor

2. DAIS

Device:


```
{
 "_id": "100035e0",
 "deviceTypeId": "ezlopi",
 "parentDeviceId": "100035f0",
 "category": "hvac",
 "subcategory": "heater",
 "gatewayId": "457a5069",
 "batteryPowered": false,
 "name": "Thermostat",
 "serviceNotification":false,
 "type": "sensor",
 "reachable": true,
 "roomId": "",
 "security": "no",
 "ready": true,
 "status": "idle"
}
```

Items:

1. **Power**


```
{
"_id": "200035f6",
"deviceId": "100035f0",
"hasGetter": true,
"hasSetter": true,
"enum": [
"off",
"heat",
"cool",
"auto",
"aux_mode",
"resume",
"fan_only",
"furnace",
"dry_air",
"moist_air",
"auto_change_over",
"saving_heat",
"saving_cool",
"away_heat",
"away_cool",
"full_power",
"special",
"eco",
"emergency_heating",
"precooling",
"sleep",
"manufacturer_specific"
],
"name": "thermostat_mode",
"valueType": "token",
"value": " off ",
"valueFormatted": " off "
}
```


2. **Child Lock (Not found In the API doc)**


```
{
"_id": "200035f6",
"deviceId": "100035f0",
```

"hasGetter": true,
"hasSetter": true,
"name": "Child_Lock",
"valueType": "bool",
"value": "true",
"valueFormatted": "true"
}

3. **Programmable (Not found In the API doc)**

{
"_id": "200035f6",
"deviceId": "100035f0",
"hasGetter": true,
"hasSetter": true,
"name": "Program_Mode_Selection",
"valueType": "bool",
"value": "true",
"valueFormatted": "true"
}

4. **Energy Saving**

{
"_id": "200035f6",
"deviceId": "100035f0",
"hasGetter": true,
"hasSetter": true,
"enum": [
"off",
"low",
"moderate",
"aggressive",
"low_postponed",
"moderate_postponed ",
"aggressive_postponed "
],
"name": " thermostat_energy_saving_mode ",
"valueType": "token",
"value": "off",
"valueFormatted": "off"
}

5. **Temperature Set point**

{
"_id": "200035f6",

"deviceId": "100035f0",
"hasGetter": true,
"hasSetter": true,
"name": "thermostat_setpoint",
"valueType": "temperature",
"value": 25,
"valueFormatted": "25"
}

6. **Current Target:**

{
"_id": "200035f6",
"deviceId": "100035f0",
"hasGetter": true,
"hasSetter": false,
"name": "boiler_water_temperature",
"valueType": "temperature",
"value": 27.5,
"valueFormatted": "27.5"
}

7. **Time Scheduling**

TBD