

7. Capacity Tables

FTXM09WVJU9 + RXM09WVJU9

Cooling (60 Hz, 208 V)

AFR	14.6
BF	0.16

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.09	3.25	0.53	3.75	3.09	0.66	3.41	2.93	0.79	3.24	2.85	0.85	3.07	2.77	0.91	2.87	2.68	0.99
16.0	22.0	4.26	3.19	0.54	3.92	3.04	0.66	3.58	2.89	0.79	3.41	2.82	0.85	3.24	2.74	0.92	3.03	2.66	0.99
18.0	25.0	4.43	3.37	0.54	4.09	3.23	0.67	3.75	3.09	0.79	3.58	3.02	0.86	3.41	2.95	0.92	3.20	2.87	1.00
19.4	26.7	4.52	3.58	0.54	4.17	3.44	0.67	3.83	3.31	0.80	3.66	3.24	0.86	3.49	3.18	0.92	3.29	3.10	1.00
22.0	30.0	4.77	3.46	0.55	4.43	3.34	0.67	4.09	3.22	0.80	3.92	3.16	0.87	3.75	3.10	0.93	3.54	3.04	1.01
24.0	32.0	4.94	3.37	0.68	4.60	3.26	0.68	4.26	3.16	0.81	4.09	3.10	0.87	3.91	3.05	0.93	3.71	2.99	1.01

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	13.97	11.10	0.53	12.81	10.54	0.66	11.64	10.00	0.79	11.06	9.73	0.85	10.48	9.47	0.91	9.78	9.15	0.99
60.8	71.6	14.54	10.89	0.54	13.38	10.37	0.66	12.22	9.86	0.79	11.64	9.61	0.85	11.05	9.36	0.92	10.35	9.07	0.99
64.4	77.0	15.12	11.49	0.54	13.96	11.01	0.67	12.79	10.54	0.79	12.21	10.31	0.86	11.63	10.08	0.92	10.93	9.80	1.00
67.0	80.0	15.41	12.21	0.54	14.24	11.75	0.67	13.08	11.30	0.80	12.50	11.07	0.86	11.92	10.85	0.92	11.22	10.59	1.00
71.6	86.0	16.27	11.79	0.55	15.11	11.38	0.67	13.94	10.98	0.80	13.36	10.79	0.87	12.78	10.59	0.93	12.08	10.36	1.01
75.2	89.6	16.85	11.50	0.68	15.68	11.13	0.68	14.52	10.77	0.81	13.94	10.59	0.87	13.36	10.41	0.93	12.66	10.20	1.01

Heating (60 Hz, 208 V)

AFR	14.6
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)															
EDB		-25 / (-25)		-20 / (-20)		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		15.5 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		3.27	1.55	3.33	1.56	3.44	1.57	4.02	1.61	4.61	1.65	5.20	1.69	5.91	1.74	7.14	1.88
21.1		2.93	1.60	3.08	1.61	3.22	1.61	3.82	1.65	4.41	1.69	5.00	1.73	5.72	1.78	6.94	1.92
22.0		2.80	1.62	2.97	1.62	3.14	1.63	3.73	1.67	4.33	1.71	4.92	1.75	5.64	1.80	6.86	1.94
24.0		2.66	1.64	2.87	1.64	3.05	1.65	3.65	1.69	4.25	1.73	4.84	1.76	5.56	1.81	6.78	1.95
25.0		2.59	1.65	2.82	1.65	3.01	1.66	3.61	1.69	4.21	1.73	4.80	1.77	5.52	1.82	6.74	1.96
27.0		2.46	1.67	2.72	1.67	2.93	1.67	3.53	1.71	4.13	1.75	4.72	1.79	5.44	1.84	6.67	1.98

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)															
EDB		-13 / (-13)		-4 / (-4)		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		60 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		11.15	1.55	11.38	1.56	11.72	1.57	13.73	1.61	15.74	1.65	17.75	1.69	20.17	1.74	24.36	1.88
70.0		10.00	1.60	10.50	1.61	11.00	1.61	13.02	1.65	15.05	1.69	17.07	1.73	19.50	1.78	23.68	1.92
71.6		9.54	1.62	10.15	1.62	10.71	1.63	12.74	1.67	14.77	1.71	16.80	1.75	19.23	1.80	23.41	1.94
75.2		9.08	1.64	9.80	1.64	10.42	1.65	12.46	1.69	14.49	1.73	16.53	1.76	18.96	1.81	23.15	1.95
77.0		8.85	1.65	9.62	1.65	10.28	1.66	12.32	1.69	14.36	1.73	16.39	1.77	18.83	1.82	23.01	1.96
80.6		8.39	1.67	9.27	1.67	9.99	1.67	12.04	1.71	14.08	1.75	16.12	1.79	18.56	1.84	22.74	1.98

FTXM12WVJU9 + RXM12WVJU9

Cooling (60 Hz, 208 V)

AFR	15.8
BF	0.16

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	5.23	3.91	0.87	4.79	3.70	1.07	4.36	3.49	1.28	4.14	3.38	1.38	3.92	3.28	1.49	3.66	3.16	1.61
16.0	22.0	5.45	3.84	0.87	5.01	3.63	1.08	4.57	3.44	1.29	4.36	3.34	1.39	4.14	3.24	1.49	3.88	3.13	1.62
18.0	25.0	5.66	4.02	0.88	5.23	3.83	1.09	4.79	3.64	1.29	4.57	3.55	1.40	4.35	3.46	1.50	4.09	3.36	1.62
19.4	26.7	5.77	4.24	0.88	5.33	4.05	1.09	4.90	3.88	1.30	4.68	3.79	1.40	4.46	3.70	1.50	4.20	3.60	1.63
22.0	30.0	6.09	4.08	0.89	5.66	3.92	1.10	5.22	3.76	1.31	5.00	3.68	1.41	4.79	3.61	1.51	4.52	3.52	1.64
24.0	32.0	6.31	3.97	1.10	5.87	3.82	1.10	5.44	3.68	1.31	5.22	3.61	1.42	5.00	3.54	1.52	4.74	3.46	1.64

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	17.85	13.35	0.87	16.36	12.61	1.07	14.87	11.89	1.28	14.13	11.54	1.38	13.39	11.19	1.49	12.49	10.77	1.61
60.8	71.6	18.58	13.09	0.87	17.10	12.40	1.08	15.61	11.72	1.29	14.86	11.39	1.39	14.12	11.06	1.49	13.23	10.67	1.62
64.4	77.0	19.32	13.70	0.88	17.83	13.06	1.09	16.34	12.43	1.29	15.60	12.12	1.40	14.86	11.82	1.50	13.96	11.45	1.62
67.0	80.0	19.69	14.45	0.88	18.20	13.84	1.09	16.71	13.23	1.30	16.00	12.93	1.40	15.22	12.64	1.50	14.33	12.29	1.63
71.6	86.0	20.79	13.91	0.89	19.30	13.37	1.10	17.82	12.83	1.31	17.07	12.57	1.41	16.33	12.31	1.51	15.44	12.00	1.64
75.2	89.6	21.52	13.53	1.10	20.04	13.04	1.10	18.55	12.55	1.31	17.81	12.31	1.42	17.06	12.08	1.52	16.17	11.79	1.64

Heating (60 Hz, 208 V)

AFR	15.8
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)															
EDB	-25 / (-25)		-20 / (-20)		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		15.5 / (24)		
°C	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	
15.0	3.50	1.75	3.86	1.84	4.25	1.94	4.86	2.01	5.48	2.09	6.10	2.16	6.85	2.25	8.27	2.42	
21.1	3.14	1.80	3.56	1.90	3.99	1.99	4.61	2.07	5.24	2.14	5.87	2.21	6.62	2.30	8.01	2.42	
22.0	2.99	1.82	3.44	1.92	3.88	2.01	4.51	2.09	5.15	2.16	5.78	2.23	6.53	2.32	7.92	2.42	
24.0	2.85	1.84	3.32	1.94	3.78	2.04	4.41	2.11	5.05	2.18	5.68	2.25	6.44	2.34	7.82	2.42	
25.0	2.78	1.85	3.26	1.95	3.72	2.05	4.36	2.12	5.00	2.19	5.64	2.26	6.40	2.35	7.78	2.42	
27.0	2.63	1.88	3.14	1.97	3.62	2.07	4.26	2.14	4.90	2.21	5.54	2.29	6.30	2.37	7.69	2.42	

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)															
EDB		-13 / (-13)		-4 / (-4)		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		60 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		11.93	1.75	13.17	1.84	14.49	1.94	16.59	2.01	18.71	2.09	20.83	2.16	23.38	2.25	28.20	2.42
70.0		10.70	1.80	12.15	1.90	13.60	1.99	15.74	2.07	17.89	2.14	20.03	2.21	22.60	2.30	27.34	2.42
71.6		10.21	1.82	11.74	1.92	13.24	2.01	15.40	2.09	17.56	2.16	19.71	2.23	22.29	2.32	27.01	2.42
75.2		9.71	1.84	11.34	1.94	12.89	2.04	15.06	2.11	17.23	2.18	19.39	2.25	21.98	2.34	26.69	2.42
77.0		9.47	1.85	11.13	1.95	12.71	2.05	14.89	2.12	17.06	2.19	19.23	2.26	21.82	2.35	26.54	2.42
80.6		8.98	1.88	10.73	1.97	12.35	2.07	14.55	2.14	16.74	2.21	18.91	2.29	21.51	2.37	26.23	2.42

FTXM18WVJU9 + RXM18WVJU9

Cooling (60 Hz, 208 V)

AFR	22.0
BF	0.27

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	7.20	5.18	1.25	6.60	4.87	1.55	6.00	4.57	1.85	5.70	4.42	2.00	5.40	4.28	2.15	5.04	4.11	2.33
16.0	22.0	7.49	5.07	1.26	6.89	4.78	1.56	6.29	4.50	1.86	5.99	4.37	2.01	5.70	4.23	2.16	5.34	4.07	2.34
18.0	25.0	7.79	5.28	1.27	7.19	5.01	1.57	6.59	4.75	1.87	6.29	4.62	2.02	5.99	4.49	2.17	5.63	4.34	2.35
19.4	26.7	7.94	5.54	1.27	7.34	5.28	1.57	6.74	5.02	1.87	6.44	4.90	2.02	6.14	4.78	2.17	5.78	4.63	2.35
22.0	30.0	8.38	5.32	1.29	7.78	5.09	1.59	7.18	4.86	1.89	6.89	4.75	2.03	6.59	4.65	2.18	6.23	4.52	2.36
24.0	32.0	8.68	5.16	1.30	8.08	4.95	1.60	7.48	4.75	1.89	7.18	4.65	2.04	6.88	4.55	2.19	6.52	4.43	2.37

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	24.56	17.67	1.25	22.51	16.62	1.55	20.47	15.59	1.85	19.44	15.09	2.00	18.42	14.59	2.15	17.19	14.01	2.33
60.8	71.6	25.57	17.31	1.26	23.52	16.33	1.56	21.48	15.36	1.86	20.45	14.89	2.01	19.43	14.43	2.16	18.20	13.88	2.34
64.4	77.0	26.58	18.01	1.27	24.54	17.09	1.57	22.49	16.19	1.87	21.47	15.75	2.02	20.44	15.32	2.17	19.22	14.81	2.35
67.0	80.0	27.09	18.89	1.27	25.04	18.01	1.57	23.00	17.14	1.87	22.00	16.72	2.02	20.95	16.30	2.17	19.72	15.81	2.35
71.6	86.0	28.61	18.14	1.29	26.56	17.36	1.59	24.51	16.60	1.89	23.49	16.22	2.03	22.47	15.85	2.18	21.24	15.42	2.36
75.2	89.6	29.62	17.61	1.30	27.57	16.90	1.60	25.53	16.20	1.89	24.50	15.86	2.04	23.48	15.52	2.19	22.25	15.13	2.37

Heating (60 Hz, 208 V)

AFR	22.0
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)															
EDB	-25 / (-25)		-20 / (-20)		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		15.5 / (24)		
°C	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	
15.0	5.29	3.01	6.00	3.21	6.75	3.42	7.31	3.38	7.88	3.33	8.46	3.28	9.16	3.23	11.06	3.48	
21.1	4.75	3.10	5.54	3.31	6.33	3.52	6.93	3.47	7.53	3.41	8.13	3.36	8.85	3.30	10.75	3.56	
22.0	4.52	3.12	5.35	3.35	6.16	3.56	6.78	3.50	7.39	3.45	8.00	3.39	8.73	3.33	10.63	3.59	
24.0	3.75	2.44	5.17	3.38	6.00	3.59	6.63	3.54	7.25	3.48	7.87	3.43	8.61	3.36	10.51	3.62	
25.0	3.37	2.12	5.08	3.40	5.91	3.61	6.56	3.56	7.18	3.50	7.81	3.44	8.55	3.37	10.44	3.63	
27.0	2.60	1.55	4.36	2.74	5.75	3.65	6.41	3.59	7.05	3.53	7.68	3.47	8.42	3.40	10.32	3.66	

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)														
EDB	-13 / (-13)		-4 / (-4)		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		60 / (75.2)	
°F	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0	18.06	3.01	20.48	3.21	23.02	3.42	24.93	3.38	26.88	3.33	28.85	3.28	31.24	3.23	37.72	3.48
70.0	16.20	3.10	18.90	3.31	21.60	3.52	23.65	3.47	25.70	3.41	27.74	3.36	30.20	3.30	36.68	3.56
71.6	15.42	3.12	18.27	3.35	21.03	3.56	23.14	3.50	25.22	3.45	27.30	3.39	29.78	3.33	36.26	3.59
75.2	12.79	2.44	17.64	3.38	20.47	3.59	22.63	3.54	24.75	3.48	26.86	3.43	29.37	3.36	35.85	3.62
77.0	11.48	2.12	17.32	3.40	20.18	3.61	22.37	3.56	24.52	3.50	26.64	3.44	29.16	3.37	35.64	3.63
80.6	8.86	1.55	14.87	2.74	19.61	3.65	21.86	3.59	24.04	3.53	26.19	3.47	28.74	3.40	35.22	3.66

FTXM24WVJU9 + RXM24WVJU9

Cooling (60 Hz, 208 V)

AFR	23.9
BF	0.36

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	7.45	5.24	1.36	7.45	5.24	1.95	7.09	5.05	2.56	6.73	4.87	2.77	6.38	4.69	2.98	5.57	4.28	2.95
16.0	22.0	8.86	5.70	1.75	8.15	5.34	2.16	7.44	4.98	2.58	7.08	4.81	2.78	6.73	4.64	2.99	5.90	4.25	2.95
18.0	25.0	9.21	5.87	1.76	8.50	5.53	2.17	7.79	5.20	2.59	7.43	5.03	2.79	7.08	4.87	3.00	6.24	4.50	2.95
19.4	26.7	9.38	6.11	1.77	8.67	5.77	2.18	7.96	5.45	2.59	7.61	5.30	2.80	7.26	5.14	3.01	6.41	4.78	2.95
22.0	30.0	9.91	5.84	1.78	9.20	5.55	2.20	8.49	5.26	2.61	8.14	5.12	2.82	7.78	4.99	3.03	6.91	4.66	2.95
24.0	32.0	10.26	5.65	1.80	9.55	5.38	2.21	8.84	5.12	2.62	8.49	4.99	2.83	8.13	4.87	3.04	7.24	4.56	2.95

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	25.41	17.90	1.36	25.41	17.90	1.95	24.18	17.24	2.56	22.97	16.61	2.77	21.77	15.99	2.98	19.01	14.61	2.95
60.8	71.6	30.22	19.47	1.75	27.80	18.21	2.16	25.38	16.99	2.58	24.17	16.40	2.78	22.96	15.81	2.99	20.15	14.49	2.95
64.4	77.0	31.41	20.04	1.76	28.99	18.86	2.17	26.58	17.73	2.59	25.37	17.17	2.79	24.16	16.63	3.00	21.28	15.36	2.95
67.0	80.0	32.01	20.83	1.77	29.59	19.70	2.18	27.17	18.60	2.59	26.00	18.07	2.80	24.76	17.54	3.01	21.85	16.31	2.95
71.6	86.0	33.80	19.93	1.78	31.39	18.93	2.20	28.97	17.95	2.61	27.76	17.48	2.82	26.55	17.01	3.03	23.56	15.89	2.95
75.2	89.6	35.00	19.28	1.80	32.58	18.36	2.21	30.17	17.47	2.62	28.96	17.04	2.83	27.75	16.61	3.04	24.70	15.56	2.95

Heating (60 Hz, 208 V)

AFR	23.9
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)															
EDB	-25 / (-25)		-20 / (-20)		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		15.5 / (24)		
°C	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	
15.0	5.88	3.39	6.67	3.60	7.50	3.80	8.02	3.73	8.55	3.65	9.10	3.57	9.76	3.48	11.79	3.76	
21.1	5.28	3.50	6.15	3.70	7.03	3.91	7.61	3.82	8.18	3.74	8.75	3.66	9.44	3.56	11.46	3.84	
22.0	5.03	3.54	5.95	3.75	6.85	3.95	7.44	3.86	8.03	3.78	8.61	3.69	9.31	3.59	11.33	3.87	
24.0	4.21	2.81	5.74	3.79	6.68	3.96	7.28	3.90	7.88	3.82	8.47	3.73	9.18	3.62	11.20	3.90	
25.0	3.78	2.45	5.64	3.81	6.61	3.96	7.20	3.92	7.80	3.83	8.40	3.75	9.11	3.64	11.14	3.92	
27.0	2.92	1.78	4.90	3.14	6.46	3.96	7.03	3.96	7.65	3.87	8.26	3.78	8.98	3.67	11.01	3.95	

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)															
EDB	-13 / (-13)		-4 / (-4)		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		60 / (75.2)		
°F	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	
59.0	20.07	3.39	22.76	3.60	25.58	3.80	27.36	3.73	29.19	3.65	31.05	3.57	33.31	3.48	40.22	3.76	
70.0	18.00	3.50	21.00	3.70	24.00	3.91	25.95	3.82	27.90	3.74	29.86	3.66	32.20	3.56	39.11	3.84	
71.6	17.17	3.54	20.30	3.75	23.37	3.95	25.39	3.86	27.39	3.78	29.38	3.69	31.76	3.59	38.66	3.87	
75.2	14.38	2.81	19.60	3.79	22.80	3.96	24.83	3.90	26.88	3.82	28.90	3.73	31.31	3.62	38.22	3.90	
77.0	12.90	2.45	19.24	3.81	22.54	3.96	24.55	3.92	26.62	3.83	28.66	3.75	31.09	3.64	38.00	3.92	
80.6	9.95	1.78	16.71	3.14	22.03	3.96	23.99	3.96	26.11	3.87	28.19	3.78	30.64	3.67	37.55	3.95	