

7. Capacity Tables

FTXV09AVJU9 + RXT09AVJU9

Cooling (60 Hz, 208 V)

AFR	10.8
BF	0.20

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	3.64	2.67	0.60	3.33	2.51	0.75	3.03	2.36	0.89	2.87	2.29	0.96	2.72	2.21	1.03	2.54	2.13	1.08
16.0	22.0	3.79	2.61	0.61	3.48	2.47	0.75	3.18	2.33	0.89	3.03	2.26	0.97	2.87	2.19	1.04	2.69	2.11	1.08
18.0	25.0	3.94	2.73	0.61	3.64	2.59	0.75	3.33	2.46	0.90	3.18	2.40	0.97	3.02	2.33	1.04	2.84	2.26	1.08
19.4	26.7	4.05	2.73	0.61	3.74	2.60	0.76	3.44	2.48	0.90	3.28	2.42	0.97	3.13	2.36	1.05	2.95	2.29	1.08
22.0	30.0	4.24	2.76	0.76	3.94	2.64	0.76	3.63	2.53	0.91	3.48	2.48	0.98	3.33	2.42	1.05	3.14	2.36	1.08
24.0	32.0	4.40	2.68	0.77	4.09	2.58	0.77	3.78	2.47	0.91	3.63	2.42	0.98	3.48	2.37	1.06	3.29	2.32	1.08

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	12.42	9.10	0.60	11.37	8.57	0.75	10.33	8.05	0.89	9.81	7.80	0.96	9.29	7.55	1.03	8.66	7.26	1.08
60.8	71.6	12.93	8.91	0.61	11.89	8.42	0.75	10.85	7.94	0.89	10.32	7.70	0.97	9.80	7.47	1.04	9.18	7.19	1.08
64.4	77.0	13.45	9.30	0.61	12.41	8.84	0.75	11.36	8.40	0.90	10.84	8.18	0.97	10.32	7.96	1.04	9.69	7.70	1.08
67.0	80.0	13.81	9.32	0.61	12.77	8.88	0.76	11.72	8.46	0.90	11.20	8.25	0.97	11.20	8.04	1.05	10.05	7.80	1.08
71.6	86.0	14.48	9.41	0.76	13.44	9.02	0.76	12.39	8.64	0.91	11.87	8.45	0.98	11.35	8.27	1.05	10.73	8.05	1.08
75.2	89.6	15.00	9.15	0.77	13.95	8.79	0.77	12.91	8.44	0.91	12.39	8.27	0.98	11.87	8.10	1.06	11.24	7.90	1.08

Heating (60 Hz, 208 V)

AFR	10.9
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25		-20		-15		-10		-5		0		6		15.5	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.22	1.64	2.85	1.68	3.45	1.72	3.79	1.66	4.13	1.59	4.48	1.53	4.90	1.46	5.57	1.58
21.1		1.94	1.70	2.58	1.74	3.19	1.77	3.55	1.71	3.91	1.64	4.27	1.58	4.70	1.50	5.38	1.62
22.0		1.90	1.71	2.54	1.74	3.16	1.78	3.52	1.72	3.88	1.65	4.24	1.59	4.67	1.51	5.35	1.62
24.0		1.81	1.73	2.46	1.76	3.07	1.80	3.44	1.73	3.81	1.67	4.17	1.60	4.61	1.52	5.29	1.64
25.0		1.61	1.45	2.41	1.77	3.03	1.81	3.40	1.74	3.77	1.68	4.41	1.61	4.57	1.53	5.26	1.64
27.0		1.21	0.97	2.22	1.62	2.95	1.83	3.33	1.76	3.70	1.69	4.07	1.62	4.51	1.54	5.20	1.66

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13		-4		5		14		23		32		43		60	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		7.57	1.64	9.71	1.68	11.77	1.72	12.91	1.66	14.08	1.59	15.25	1.53	16.67	1.46	18.94	1.58
70.0		6.63	1.70	8.81	1.74	10.90	1.77	12.11	1.71	13.33	1.64	14.54	1.58	16.00	1.50	18.31	1.62
71.6		6.50	1.71	8.68	1.74	10.77	1.78	12.00	1.72	13.22	1.65	14.44	1.59	15.90	1.51	18.21	1.62
75.2		6.19	1.73	6.38	1.76	10.48	1.80	11.73	1.73	12.97	1.67	14.21	1.60	15.68	1.52	18.01	1.64
77.0		5.50	1.45	8.24	1.77	10.34	1.81	11.60	1.74	12.85	1.68	14.09	1.61	15.57	1.53	17.90	1.64
80.6		4.12	0.97	7.56	1.62	10.06	1.83	11.34	1.76	12.61	1.69	13.86	1.62	15.35	1.54	17.69	1.66

FTXV12AVJU9 + RXT12AVJU9

Cooling (60 Hz, 208 V)

AFR	11.1
BF	0.19

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.38	3.08	0.79	4.34	3.07	1.13	3.95	2.86	1.35	3.75	2.75	1.46	3.55	2.65	1.51	3.31	2.53	1.19
16.0	22.0	4.94	3.21	0.92	4.54	3.01	1.14	4.41	2.81	1.36	3.94	2.72	1.47	3.74	2.62	1.51	3.51	2.51	1.19
18.0	25.0	5.14	3.32	0.93	4.74	3.13	1.15	4.34	2.94	1.37	4.14	2.85	1.48	3.94	2.77	1.51	3.70	2.66	1.19
19.4	26.7	5.28	3.31	0.93	4.88	3.13	1.15	4.48	2.96	1.37	4.28	2.87	1.48	4.08	2.79	1.51	3.84	2.69	1.19
22.0	30.0	5.53	3.31	0.94	5.13	3.15	1.16	4.73	2.99	1.38	4.54	2.92	1.49	4.33	2.84	1.51	4.10	2.75	1.19
24.0	32.0	5.73	3.21	1.17	5.33	3.06	1.17	4.93	2.92	1.39	4.73	2.85	1.50	4.52	2.77	1.51	4.29	2.69	1.19

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	14.94	10.52	0.79	14.82	10.46	1.13	13.46	9.74	1.35	12.78	9.40	1.46	12.10	9.05	1.51	11.29	8.65	1.19
60.8	71.6	16.86	10.97	0.92	15.50	10.28	1.14	14.14	9.60	1.36	13.46	9.28	1.47	12.78	8.95	1.51	11.96	8.57	1.19
64.4	77.0	17.53	11.32	0.93	16.17	10.68	1.15	14.81	10.05	1.37	14.13	9.74	1.48	13.45	9.44	1.51	12.63	9.08	1.19
67.0	80.0	18.00	11.30	0.93	16.64	10.68	1.15	15.28	10.09	1.37	14.60	9.80	1.48	13.92	9.51	1.51	13.10	9.17	1.19
71.6	86.0	18.87	11.30	0.94	17.51	10.75	1.16	16.15	10.21	1.38	15.47	9.95	1.49	14.78	9.69	1.51	13.98	9.39	1.19
75.2	89.6	19.55	10.94	1.17	18.19	10.44	1.17	16.83	9.95	1.39	16.15	9.71	1.50	15.42	9.46	1.51	14.65	9.19	1.19

Heating (60 Hz, 208 V)

AFR	12.4
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25		-20		-15		-10		-5		0		6		15.5	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.75	2.04	3.53	2.08	4.28	2.13	4.61	2.04	4.96	1.95	5.31	1.86	5.73	1.75	6.91	1.89
21.1		2.41	2.11	3.20	2.15	3.96	2.20	4.33	2.10	4.69	2.01	5.06	1.91	5.50	1.80	6.68	1.94
22.0		2.36	2.13	3.15	2.16	3.91	2.21	4.28	2.11	4.65	2.02	5.02	1.92	5.47	1.81	6.65	1.95
24.0		2.25	2.15	3.05	2.19	3.81	2.23	4.19	2.14	4.57	2.04	4.94	1.94	5.39	1.82	6.57	1.96
25.0		2.19	2.16	2.99	2.20	3.76	2.25	4.14	2.15	4.53	2.05	4.90	1.95	5.35	1.83	6.53	1.97
27.0		2.08	2.19	2.89	2.22	3.65	2.27	4.05	2.17	4.44	2.07	4.82	1.97	5.28	1.85	6.19	1.83

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13		-4		5		14		23		32		43		60	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		9.38	2.04	12.04	2.08	14.59	2.13	15.74	2.04	16.93	1.95	18.13	1.86	19.59	1.75	23.63	1.89
70.0		8.22	2.11	10.92	2.15	13.50	2.20	14.77	2.10	16.03	2.01	17.29	1.91	18.80	1.80	22.83	1.94
71.6		8.05	2.13	10.76	2.16	13.35	2.21	14.63	2.11	15.90	2.02	17.16	1.92	18.68	1.81	22.72	1.95
75.2		7.67	2.15	10.39	2.19	13.00	2.23	14.31	2.14	15.60	2.04	16.89	1.94	18.42	1.82	22.46	1.96
77.0		7.49	2.16	10.21	2.20	12.82	2.25	14.15	2.15	15.46	2.05	16.75	1.95	18.29	1.83	22.33	1.97
80.6		7.11	2.19	9.84	2.22	12.46	2.27	13.83	2.17	15.16	2.07	16.47	1.97	18.03	1.85	21.12	1.83

FTXV15AVJU9 + RXT15AVJU9

Cooling (60 Hz, 208 V)

AFR	15.3
BF	0.22

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	5.81	4.09	0.89	5.48	3.92	1.16	4.98	3.66	1.38	4.73	3.53	1.49	4.48	3.41	1.60	4.18	3.26	1.74
16.0	22.0	6.23	4.10	0.94	5.73	3.85	1.16	5.23	3.61	1.39	4.98	3.49	1.50	4.73	3.37	1.61	4.42	3.23	1.74
18.0	25.0	6.48	4.24	0.95	5.98	4.01	1.17	5.48	3.78	1.39	5.23	3.67	1.51	4.97	3.56	1.62	4.67	3.43	1.75
19.4	26.7	6.66	4.24	0.95	6.15	4.02	1.18	5.65	3.80	1.40	5.40	3.69	1.51	5.15	3.59	1.62	4.85	3.47	1.76
22.0	30.0	6.98	4.25	0.96	6.48	4.05	1.18	5.97	3.85	1.41	5.72	3.76	1.52	5.47	3.66	1.63	5.17	3.55	1.76
24.0	32.0	7.23	4.12	0.97	6.73	3.93	1.19	6.22	3.76	1.41	5.97	3.67	1.53	5.72	3.58	1.64	5.42	3.48	1.77

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	19.83	13.96	0.89	18.71	13.37	1.16	16.99	12.48	1.38	16.13	12.05	1.49	15.27	11.62	1.60	14.25	11.11	1.74
60.8	71.6	21.27	13.99	0.94	19.56	13.14	1.16	17.84	12.30	1.39	16.98	11.90	1.50	16.12	11.49	1.61	15.09	11.02	1.74
64.4	77.0	22.12	14.48	0.95	20.40	13.68	1.17	18.69	12.90	1.39	17.83	12.52	1.51	16.97	12.14	1.62	15.94	11.70	1.75
67.0	80.0	22.71	14.46	0.95	21.00	13.70	1.18	19.28	12.96	1.40	18.40	12.60	1.51	17.57	12.24	1.62	16.54	11.82	1.76
71.6	86.0	23.82	14.49	0.96	22.10	13.81	1.18	20.39	13.15	1.41	19.53	12.82	1.52	18.67	12.50	1.63	17.64	12.12	1.76
75.2	89.6	24.67	14.05	0.97	22.95	13.42	1.19	21.24	12.82	1.41	20.38	12.52	1.53	19.52	12.23	1.64	18.49	11.88	1.77

Heating (60 Hz, 208 V)

AFR	18.0
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25		-20		-15		-10		-5		0		6		15.5	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		3.71	2.75	4.77	2.81	5.78	2.87	6.17	2.67	6.58	2.46	7.00	2.25	7.50	1.99	9.05	2.15
21.1		3.26	2.86	4.32	2.91	5.35	2.97	5.79	2.75	6.23	2.53	6.67	2.31	7.20	2.05	8.74	2.21
22.0		3.19	2.87	4.26	2.92	5.29	2.99	5.73	2.77	6.18	2.54	6.62	2.32	7.16	2.06	8.70	2.22
24.0		3.04	2.91	4.12	2.96	5.15	3.02	5.61	2.79	6.06	2.57	6.52	2.35	7.06	2.08	8.60	2.24
25.0		2.96	2.92	4.04	2.97	5.08	3.04	5.55	2.81	6.01	2.58	6.46	2.36	7.01	2.09	8.55	2.25
27.0		2.81	2.96	3.90	3.01	4.94	3.07	5.42	2.84	5.89	2.61	6.36	2.38	6.91	2.10	8.45	2.26

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13		-4		5		14		23		32		43		60	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		12.70	2.75	16.30	2.81	19.77	2.87	21.11	2.67	22.49	2.46	23.91	2.25	25.64	1.99	30.91	2.15
70.0		11.14	2.86	14.79	2.91	18.30	2.97	19.80	2.75	21.30	2.53	22.80	2.31	24.60	2.05	29.88	2.21
71.6		10.91	2.87	14.57	2.92	18.08	2.99	19.61	2.77	21.12	2.54	22.64	2.32	24.45	2.06	29.72	2.22
75.2		10.39	2.91	14.08	2.96	17.60	3.02	19.18	2.79	20.73	2.57	22.27	2.35	24.11	2.08	29.39	2.24
77.0		10.14	2.92	13.83	2.97	17.36	3.04	18.97	2.81	20.54	2.58	22.09	2.36	23.94	2.09	29.22	2.25
80.6		9.63	2.96	13.33	3.01	16.88	3.07	18.54	2.84	20.15	2.61	21.73	2.38	23.60	2.10	28.88	2.26

FTXV18AVJU9 + RXT18AVJU9

Cooling (60 Hz, 208 V)

AFR	16
BF	0.23

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	6.00	4.22	0.87	6.00	4.22	1.23	5.95	4.20	1.73	5.65	4.04	1.87	5.35	3.88	2.01	4.99	3.70	2.17
16.0	22.0	7.37	4.72	1.16	6.84	4.44	1.46	6.24	4.14	1.74	5.94	3.99	1.88	5.64	3.84	2.02	5.28	3.67	2.18
18.0	25.0	7.74	4.89	1.19	7.14	4.60	1.47	6.54	4.31	1.74	6.24	4.17	1.88	5.94	4.03	2.02	5.58	3.87	2.19
19.4	26.7	7.95	4.87	1.19	7.35	4.59	1.47	6.75	4.32	1.75	6.45	4.19	1.89	6.15	4.06	2.03	5.79	3.90	2.20
22.0	30.0	8.34	4.86	1.20	7.73	4.60	1.48	7.13	4.36	1.76	6.83	4.24	1.90	6.53	4.12	2.04	6.17	3.98	2.21
24.0	32.0	8.63	4.70	1.21	8.03	4.46	1.49	7.43	4.24	1.77	7.13	4.13	1.91	6.83	4.02	2.05	6.47	3.89	2.22

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	20.47	14.41	0.87	20.47	14.41	1.23	20.29	14.32	1.73	19.26	13.78	1.87	18.24	13.24	2.01	17.01	12.62	2.17
60.8	71.6	25.14	16.10	1.16	23.35	15.16	1.46	21.30	14.11	1.74	20.28	13.60	1.88	19.25	13.10	2.02	18.02	12.51	2.18
64.4	77.0	26.41	16.69	1.19	24.36	15.68	1.47	22.31	14.70	1.74	21.29	14.23	1.88	20.27	13.76	2.02	19.04	13.20	2.19
67.0	80.0	27.12	16.63	1.19	25.07	15.67	1.47	23.02	14.74	1.75	22.00	14.28	1.89	20.98	13.84	2.03	19.75	13.31	2.20
71.6	86.0	28.44	16.57	1.20	26.39	15.70	1.48	24.34	14.86	1.76	23.32	14.45	1.90	22.29	14.05	2.04	21.06	13.58	2.21
75.2	89.6	29.45	16.02	1.21	27.40	15.23	1.49	25.36	14.46	1.77	24.33	14.09	1.91	23.31	13.72	2.05	22.08	13.28	2.22

Heating (60 Hz, 208 V)

AFR	20.3
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25		-20		-15		-10		-5		0		6		15.5	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.94	2.73	5.83	3.07	6.75	3.42	7.14	3.26	7.56	3.10	7.98	2.93	8.49	2.74	10.25	2.96
21.1		4.43	2.81	5.38	3.17	6.33	3.52	6.78	3.35	7.22	3.18	7.67	3.00	8.21	2.80	9.97	3.02
22.0		4.23	2.85	5.20	3.20	6.16	3.56	6.63	3.38	7.09	3.21	7.55	3.03	8.09	2.83	9.85	3.04
24.0		4.02	2.88	5.02	3.24	6.00	3.59	6.48	3.42	6.96	3.24	7.43	3.06	7.98	2.85	9.74	3.07
25.0		3.92	2.90	4.93	3.26	5.91	3.61	6.41	3.43	6.89	3.25	7.36	3.08	7.92	2.86	9.68	3.08
27.0		3.67	2.86	4.75	3.29	5.75	3.65	6.26	3.47	6.76	3.29	7.24	3.10	7.81	2.89	9.57	3.11

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13		-4		5		14		23		32		43		60	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		16.86	2.73	19.90	3.07	23.02	3.42	24.37	3.26	25.78	3.10	27.22	2.93	28.97	2.74	34.97	2.96
70.0		15.12	2.81	18.36	3.17	21.60	3.52	23.12	3.35	24.65	3.18	26.17	3.00	28.00	2.80	34.01	3.02
71.6		14.42	2.85	17.75	3.20	21.03	3.56	22.62	3.38	24.19	3.21	25.75	3.03	27.61	2.83	33.62	3.04
75.2		13.73	2.88	17.13	3.24	20.47	3.59	22.12	3.42	23.74	3.24	25.34	3.06	27.23	2.85	33.23	3.07
77.0		13.38	2.90	16.82	3.26	20.18	3.61	21.87	3.43	23.52	3.25	25.13	3.08	27.03	2.86	33.04	3.08
80.6		12.53	2.86	16.21	3.29	19.61	3.65	21.37	3.47	23.06	3.29	24.71	3.10	26.65	2.89	32.65	3.11

FTXV24AVJU9 + RXT24AVJU9

Cooling (60 Hz, 208 V)

AFR	17.8
BF	0.25

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	6.50	4.58	0.99	6.50	4.58	1.37	6.50	4.58	1.90	6.50	4.58	2.26	6.41	4.53	2.64	5.98	4.30	2.59
16.0	22.0	7.98	5.11	1.29	7.98	5.11	1.82	7.49	4.85	2.29	7.13	4.67	2.47	6.77	4.49	2.66	6.34	4.27	2.59
18.0	25.0	9.29	5.77	1.56	8.57	5.39	1.93	7.85	5.03	2.30	7.49	4.86	2.48	7.13	4.69	2.67	6.70	4.49	2.59
19.4	26.7	9.54	5.73	1.57	8.82	5.38	1.94	8.10	5.04	2.31	7.74	4.87	2.49	7.38	4.71	2.67	6.94	4.52	2.59
22.0	30.0	10.00	5.69	1.58	9.28	5.37	1.95	8.56	5.06	2.32	8.20	4.91	2.50	7.84	4.76	2.69	7.41	4.59	2.59
24.0	32.0	10.36	5.49	1.59	9.64	5.20	1.96	8.92	4.92	2.33	8.56	4.78	2.52	8.20	4.65	2.70	7.76	4.49	2.59

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	22.18	15.62	0.99	22.18	15.62	1.37	22.18	15.62	1.90	22.18	15.62	2.26	21.89	15.46	2.64	20.41	14.69	2.59
60.8	71.6	27.24	17.45	1.29	27.24	17.45	1.82	25.56	16.56	2.29	24.33	15.93	2.47	23.10	15.31	2.66	21.63	14.57	2.59
64.4	77.0	31.69	19.67	1.56	29.24	18.40	1.93	26.78	17.18	2.30	25.55	16.58	2.48	24.32	16.00	2.67	22.84	15.31	2.59
67.0	80.0	32.55	19.57	1.57	30.09	18.36	1.94	27.63	17.19	2.31	26.40	16.62	2.49	25.17	16.07	2.67	23.70	15.41	2.59
71.6	86.0	34.13	19.42	1.58	31.67	18.33	1.95	29.21	17.27	2.32	27.98	16.76	2.50	26.75	16.26	2.69	25.28	15.67	2.59
75.2	89.6	35.34	18.75	1.59	32.89	17.75	1.96	30.43	16.78	2.33	29.20	16.31	2.52	27.97	15.85	2.70	26.49	15.31	2.59

Heating (60 Hz, 208 V)

AFR	20.3
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25		-20		-15		-10		-5		0		6		15.5	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		5.49	3.03	6.48	3.42	7.50	3.80	8.00	3.74	8.52	3.67	9.06	3.60	9.70	3.52	11.71	3.80
21.1		4.92	3.13	5.98	3.52	7.03	3.91	7.59	3.83	8.15	3.76	8.71	3.69	9.38	3.60	11.39	3.88
22.0		4.70	3.16	5.78	3.56	6.85	3.95	7.43	3.87	8.00	3.80	8.57	3.72	9.25	3.63	11.26	3.91
24.0		4.47	3.20	5.58	3.60	6.67	3.96	7.26	3.91	7.85	3.84	8.43	3.76	9.12	3.66	11.01	3.86
25.0		4.36	3.22	5.48	3.62	6.59	3.96	7.18	3.93	7.78	3.85	8.36	3.78	9.05	3.68	10.65	3.67
27.0		3.67	2.65	4.89	3.17	6.43	3.96	7.02	3.96	7.63	3.89	8.22	3.81	8.93	3.71	9.91	3.30

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13		-4		5		14		23		32		43		60	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		18.73	3.03	22.11	3.42	25.58	3.80	27.30	3.74	29.09	3.67	30.90	3.60	33.10	3.52	39.97	3.80
70.0		16.80	3.13	20.40	3.52	24.00	3.91	25.90	3.83	27.81	3.76	29.71	3.69	32.00	3.60	38.87	3.88
71.6		16.03	3.16	19.72	3.56	23.37	3.95	25.34	3.87	27.30	3.80	29.24	3.72	31.56	3.63	38.42	3.91
75.2		15.25	3.20	19.04	3.60	22.77	3.96	24.78	3.91	26.79	3.84	28.77	3.76	31.12	3.66	37.58	3.86
77.0		14.87	3.22	18.69	3.62	22.48	3.96	24.50	3.93	26.53	3.85	28.53	3.78	30.90	3.68	36.32	3.67
80.6		12.53	2.65	16.70	3.17	21.92	3.96	23.95	3.96	26.02	3.89	28.05	3.81	30.45	3.71	33.82	3.30