

7. Capacity Tables

FDMA09AVJU9 + RXP09AVJU9

Cooling (60 Hz, 208 V)

AFR	8.3
BF	0.13

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	3.05	2.23	0.53	2.80	2.10	0.66	2.54	1.98	0.78	2.41	1.92	0.85	2.28	1.85	0.91	2.13	1.78	0.99
16.0	22.0	3.18	2.19	0.53	2.92	2.07	0.66	2.67	1.95	0.79	2.54	1.89	0.85	2.41	1.83	0.91	2.26	1.77	0.99
18.0	25.0	3.31	2.28	0.54	3.05	2.17	0.66	2.79	2.06	0.79	2.67	2.01	0.85	2.54	1.95	0.92	2.38	1.89	0.99
19.4	26.7	3.40	2.29	0.54	3.14	2.18	0.67	2.88	2.08	0.79	2.75	2.03	0.86	2.63	1.97	0.92	2.47	1.91	1.00
22.0	30.0	3.56	2.31	0.67	3.30	2.21	0.67	3.05	2.12	0.80	2.92	2.07	0.86	2.79	2.03	0.92	2.64	1.98	1.00
24.0	32.0	3.69	2.25	0.67	3.43	2.16	0.67	3.18	2.07	0.80	3.05	2.03	0.86	2.92	1.99	0.93	2.76	1.94	1.00

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	10.42	7.62	0.53	9.54	7.18	0.66	8.67	6.75	0.78	8.23	6.54	0.85	7.79	6.33	0.91	7.27	6.08	0.99
60.8	71.6	10.85	7.47	0.53	9.98	7.06	0.66	9.10	6.65	0.79	8.66	6.45	0.85	8.23	6.26	0.91	7.70	6.03	0.99
64.4	77.0	11.29	7.80	0.54	10.41	7.41	0.66	9.53	7.03	0.79	9.10	6.85	0.85	8.66	6.67	0.92	8.13	6.45	0.99
67.0	80.0	11.59	7.81	0.54	10.71	7.44	0.67	9.84	7.09	0.79	9.40	6.91	0.86	8.96	6.74	0.92	8.44	6.53	1.00
71.6	86.0	12.15	7.88	0.67	11.28	7.56	0.67	10.40	7.24	0.80	9.96	7.08	0.86	9.53	6.92	0.92	9.00	6.74	1.00
75.2	89.6	12.58	7.66	0.67	11.71	7.36	0.67	10.83	7.07	0.80	10.40	6.93	0.86	9.96	6.79	0.93	9.43	6.62	1.00

Heating (60 Hz, 208 V)

AFR	9.1
-----	-----

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.22	1.64	2.85	1.68	3.45	1.72	3.55	1.61	3.65	1.50	3.77	1.39	3.91	1.25	4.14	1.36
21.1		1.62	1.24	2.58	1.74	3.19	1.77	3.33	1.66	3.46	1.54	3.59	1.43	3.75	1.29	4.00	1.39
22.0		1.48	1.10	2.54	1.74	3.16	1.78	3.29	1.67	3.43	1.55	3.57	1.43	3.73	1.30	3.98	1.40
24.0		1.16	0.83	2.46	1.76	3.07	1.80	3.22	1.68	3.37	1.57	3.51	1.45	3.68	1.31	3.94	1.41
25.0		0.99	0.70	2.38	1.73	3.03	1.81	3.19	1.69	3.34	1.57	3.48	1.45	3.65	1.31	3.91	1.41
27.0		0.67	0.45	2.06	1.43	2.95	1.83	3.11	1.71	3.27	1.59	3.42	1.47	3.60	1.32	3.87	1.43

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		7.57	1.64	9.71	1.68	11.77	1.72	12.10	1.61	12.47	1.50	12.85	1.39	13.34	1.25	14.13	1.36
70.0		5.53	1.24	8.81	1.74	10.90	1.77	11.35	1.66	11.80	1.54	12.26	1.43	12.80	1.29	13.66	1.39
71.6		5.04	1.10	8.68	1.74	10.77	1.78	11.24	1.67	11.71	1.55	12.17	1.43	12.72	1.30	13.59	1.40
75.2		3.94	0.83	8.38	1.76	10.48	1.80	11.00	1.68	11.49	1.57	11.97	1.45	12.54	1.31	13.43	1.41
77.0		3.39	0.70	8.14	1.73	10.34	1.81	10.87	1.69	11.38	1.57	11.88	1.45	12.46	1.31	13.36	1.41
80.6		2.30	0.45	7.04	1.43	10.06	1.83	10.63	1.71	11.17	1.59	11.68	1.47	12.28	1.32	13.20	1.43

FDMA12AVJU9 + RXP12AVJU9

Cooling (60 Hz, 208 V)

AFR	9.0
BF	0.15

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.03	2.79	0.77	3.69	2.60	0.96	3.35	2.43	1.14	3.18	2.34	1.24	3.01	2.25	1.33	2.81	2.15	1.20
16.0	22.0	4.20	2.73	0.78	3.86	2.56	0.96	3.52	2.39	1.15	3.35	2.31	1.24	3.18	2.23	1.33	2.98	2.14	1.20
18.0	25.0	4.36	2.82	0.78	4.03	2.66	0.97	3.69	2.50	1.15	3.52	2.43	1.25	3.35	2.35	1.34	3.15	2.26	1.20
19.4	26.7	4.48	2.81	0.79	4.14	2.66	0.97	3.80	2.51	1.16	3.63	2.44	1.25	3.47	2.37	1.34	3.26	2.28	1.20
22.0	30.0	4.70	2.81	0.80	4.36	2.68	0.98	4.02	2.54	1.16	3.85	2.48	1.26	3.68	2.41	1.35	3.48	2.34	1.20
24.0	32.0	4.87	2.73	0.99	4.53	2.60	0.99	4.19	2.48	1.17	4.02	2.42	1.26	3.85	2.36	1.36	3.65	2.29	1.20

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	13.75	9.51	0.77	12.59	8.89	0.96	11.44	8.28	1.14	10.86	7.98	1.24	10.28	7.69	1.33	9.59	7.35	1.20
60.8	71.6	14.32	9.32	0.78	13.16	8.73	0.96	12.01	8.16	1.15	11.43	7.88	1.24	10.85	7.61	1.33	10.16	7.29	1.20
64.4	77.0	14.89	9.62	0.78	13.74	9.07	0.97	12.58	8.54	1.15	12.00	8.28	1.25	11.43	8.02	1.34	10.73	7.72	1.20
67.0	80.0	15.29	9.60	0.79	14.14	9.08	0.97	12.98	8.57	1.16	12.40	8.33	1.25	3.64	8.08	1.34	11.13	7.80	1.20
71.6	86.0	16.03	9.60	0.80	14.88	9.13	0.98	13.72	8.68	1.16	13.15	8.46	1.26	12.57	8.24	1.35	11.87	7.98	1.20
75.2	89.6	16.60	9.30	0.99	15.45	8.87	0.99	14.29	8.46	1.17	13.72	8.25	1.26	13.14	8.05	1.36	12.45	7.81	1.20

Heating (60 Hz, 208 V)

AFR	9.9
-----	-----

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.40	1.78	3.08	1.81	3.74	1.86	4.07	1.81	4.42	1.77	4.77	1.73	5.19	1.67	5.87	1.81
21.1		1.76	1.36	2.80	1.88	3.46	1.92	3.82	1.87	4.18	1.83	4.55	1.78	4.98	1.72	5.67	1.85
22.0		1.61	1.22	2.75	1.89	3.42	1.93	3.78	1.88	4.15	1.83	4.51	1.79	4.95	1.73	5.60	1.84
24.0		1.26	0.92	2.66	1.91	3.33	1.95	3.70	1.90	4.07	1.85	4.44	1.80	4.88	1.74	5.25	1.68
25.0		1.08	0.78	2.59	1.89	3.28	1.96	3.66	1.91	4.03	1.86	4.41	1.81	4.85	1.75	5.08	1.61
27.0		0.73	0.51	2.24	1.58	3.19	1.98	3.58	1.93	3.96	1.88	4.33	1.83	4.73	1.73	4.73	1.46

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		8.19	1.78	10.51	1.81	12.74	1.86	13.90	1.81	15.08	1.77	16.27	1.73	17.72	1.67	20.03	1.81
70.0		6.02	1.36	9.54	1.88	11.80	1.92	13.04	1.87	14.28	1.83	15.52	1.78	17.00	1.72	19.36	1.85
71.6		5.48	1.22	9.40	1.89	11.66	1.93	12.91	1.88	14.16	1.83	15.40	1.79	16.90	1.73	19.11	1.84
75.2		4.29	0.92	9.08	1.91	11.35	1.95	12.63	1.90	13.90	1.85	15.16	1.80	16.66	1.74	17.92	1.68
77.0		3.69	0.78	8.85	1.89	11.20	1.96	12.49	1.91	13.77	1.86	15.03	1.81	16.54	1.75	17.32	1.61
80.6		2.50	0.51	7.66	1.58	10.89	1.98	12.21	1.93	13.50	1.88	14.78	1.83	16.13	1.73	16.13	1.46

FDMA15AVJU9 + RXP15AVJU9

Cooling (60 Hz, 208 V)

AFR	13.2
BF	0.14

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	5.10	3.67	0.83	4.67	3.45	1.03	4.24	3.23	1.23	4.03	3.13	1.33	3.81	3.02	1.43	3.56	2.90	1.55
16.0	22.0	5.31	3.59	0.84	4.88	3.39	1.04	4.46	3.19	1.24	4.24	3.09	1.34	4.03	2.99	1.44	3.77	2.87	1.56
18.0	25.0	5.52	3.74	0.85	5.10	3.55	1.05	4.67	3.36	1.25	4.45	3.27	1.35	4.24	3.18	1.45	3.98	3.07	1.57
19.4	26.7	5.67	3.74	0.85	5.24	3.56	1.05	4.82	3.38	1.25	4.60	3.29	1.35	4.39	3.21	1.45	4.13	3.10	1.57
22.0	30.0	5.95	3.77	0.86	5.52	3.60	1.06	5.09	3.44	1.26	4.88	3.36	1.36	4.66	3.29	1.46	4.41	3.20	1.58
24.0	32.0	6.16	3.66	0.86	5.73	3.51	1.06	5.30	3.36	1.26	5.09	3.29	1.36	4.87	3.22	1.46	4.62	3.14	1.58

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	17.40	12.51	0.83	15.94	11.76	1.03	14.48	11.03	1.23	13.75	10.67	1.33	13.02	10.31	1.43	12.14	9.89	1.55
60.8	71.6	18.13	12.26	0.84	16.66	11.56	1.04	15.20	10.87	1.24	14.47	10.53	1.34	13.74	10.20	1.44	12.86	9.81	1.56
64.4	77.0	18.85	12.75	0.85	17.39	12.10	1.05	15.92	11.46	1.25	15.19	11.14	1.35	14.46	10.83	1.45	13.59	10.47	1.57
67.0	80.0	19.36	12.76	0.85	17.89	12.14	1.05	16.43	11.53	1.25	15.70	11.23	1.35	14.97	10.94	1.45	14.09	10.59	1.57
71.6	86.0	20.30	12.85	0.86	18.83	12.29	1.06	17.37	11.75	1.26	16.64	11.48	1.36	15.91	11.22	1.46	15.03	10.90	1.58
75.2	89.6	21.02	12.48	0.86	19.56	11.97	1.06	18.09	11.47	1.26	17.36	11.23	1.36	16.63	10.98	1.46	15.76	10.70	1.58

Heating (60 Hz, 208 V)

AFR	14.5
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.12	2.27	4.86	2.56	5.62	2.85	5.60	2.60	5.59	2.36	5.59	2.11	5.61	1.81	6.77	1.95
21.1		3.69	2.34	4.48	2.64	5.28	2.93	5.31	2.67	5.35	2.42	5.38	2.16	5.42	1.85	6.59	1.99
22.0		3.52	2.37	4.33	2.67	5.14	2.96	5.20	2.70	5.25	2.44	5.29	2.18	5.35	1.87	6.51	2.01
24.0		3.35	2.40	4.18	2.70	5.00	2.99	5.08	2.73	5.15	2.46	5.21	2.20	5.27	1.88	6.44	2.03
25.0		3.27	2.42	4.11	2.71	4.93	3.01	5.02	2.74	5.10	2.48	5.17	2.21	5.23	1.89	6.40	2.04
27.0		3.10	2.44	3.67	2.42	4.54	2.77	4.91	2.77	5.00	2.50	5.08	2.23	5.16	1.91	6.32	2.05

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		14.05	2.27	16.58	2.56	19.18	2.85	19.10	2.60	19.08	2.36	19.09	2.11	19.14	1.81	23.11	1.95
70.0		12.60	2.34	15.30	2.64	18.00	2.93	18.12	2.67	18.24	2.42	18.36	2.16	18.50	1.85	22.47	1.99
71.6		12.02	2.37	14.79	2.67	17.53	2.96	17.73	2.70	17.90	2.44	18.06	2.18	18.24	1.87	22.21	2.01
75.2		11.44	2.40	14.28	2.70	17.05	2.99	17.34	2.73	17.57	2.46	17.77	2.20	17.99	1.88	21.96	2.03
77.0		11.15	2.42	14.02	2.71	16.82	3.01	17.14	2.74	17.40	2.48	17.62	2.21	17.86	1.89	21.83	2.04
80.6		10.57	2.44	12.54	2.42	15.50	2.77	16.75	2.77	17.07	2.50	17.33	2.23	17.61	1.91	21.58	2.05

FDMA18AVJU9 + RXP18AVJU9

Cooling (60 Hz, 208 V)

AFR	18.5
BF	0.18

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	6.37	4.67	1.04	5.83	4.40	1.29	5.30	4.14	1.54	5.03	4.01	1.66	4.76	3.88	1.78	4.44	3.73	1.93
16.0	22.0	6.63	4.58	1.05	6.10	4.32	1.29	5.56	4.08	1.54	5.29	3.96	1.67	5.03	3.84	1.79	4.71	3.70	1.94
18.0	25.0	6.90	4.78	1.05	6.36	4.54	1.30	5.83	4.31	1.55	5.56	4.20	1.67	5.29	4.09	1.80	4.97	3.96	1.95
19.4	26.7	7.08	4.79	1.06	6.55	4.56	1.31	6.01	4.34	1.56	5.74	4.24	1.68	5.48	4.13	1.80	5.16	4.01	1.95
22.0	30.0	7.43	4.83	1.07	6.89	4.63	1.32	6.36	4.44	1.57	6.09	4.34	1.69	5.82	4.25	1.81	5.50	4.13	1.96
24.0	32.0	7.69	4.70	1.08	7.16	4.52	1.32	6.62	4.34	1.57	6.35	4.25	1.70	6.09	4.16	1.82	5.76	4.06	1.97

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	21.72	15.93	1.04	19.90	15.01	1.29	18.07	14.11	1.54	17.16	13.67	1.66	16.25	13.24	1.78	15.15	12.72	1.93
60.8	71.6	22.63	15.62	1.05	20.80	14.75	1.29	18.98	13.91	1.54	18.06	13.50	1.67	17.15	13.09	1.79	16.06	12.61	1.94
64.4	77.0	23.53	16.30	1.05	21.71	15.49	1.30	19.88	14.71	1.55	18.97	14.33	1.67	18.06	13.95	1.80	16.96	13.50	1.95
67.0	80.0	24.16	16.33	1.06	22.34	15.57	1.31	20.51	14.82	1.56	19.60	14.46	1.68	18.69	14.10	1.80	17.59	13.67	1.95
71.6	86.0	25.34	16.49	1.07	23.51	15.81	1.32	21.69	15.14	1.57	20.77	14.81	1.69	19.86	14.49	1.81	18.77	14.11	1.96
75.2	89.6	26.24	16.03	1.08	24.41	15.41	1.32	22.59	14.80	1.57	21.68	14.50	1.70	20.76	14.20	1.82	19.67	13.85	1.97

Heating (60 Hz, 208 V)

AFR	18.5
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.94	2.73	5.83	3.07	6.75	3.42	6.92	3.20	7.12	2.97	7.32	2.75	7.58	2.47	9.15	2.67
21.1		4.43	2.81	5.38	3.17	6.33	3.52	6.57	3.28	6.81	3.05	7.04	2.81	7.33	2.53	8.90	2.73
22.0		4.23	2.85	5.20	3.20	6.16	3.56	6.43	3.32	6.68	3.08	6.93	2.84	7.23	2.55	8.80	2.75
24.0		4.02	2.88	5.02	3.24	6.00	3.59	6.28	3.35	6.56	3.11	6.82	2.87	7.12	2.58	8.70	2.77
25.0		3.92	2.90	4.93	3.26	5.91	3.61	6.21	3.37	6.49	3.12	6.76	2.88	7.07	2.59	8.65	2.78
27.0		3.72	2.93	4.75	3.29	5.75	3.65	6.07	3.40	6.37	3.15	6.65	2.91	6.97	2.61	8.54	2.81

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		16.86	2.73	19.90	3.07	23.02	3.42	23.62	3.20	24.29	2.97	24.99	2.75	25.86	2.47	31.23	2.67
70.0		15.12	2.81	18.36	3.17	21.60	3.52	22.41	3.28	23.22	3.05	24.03	2.81	25.00	2.53	30.36	2.73
71.6		14.42	2.85	17.75	3.20	21.03	3.56	21.93	3.32	22.79	3.08	23.64	2.84	24.65	2.55	30.02	2.75
75.2		13.73	2.88	17.13	3.24	20.47	3.59	21.44	3.35	22.37	3.11	23.26	2.87	24.31	2.58	29.67	2.77
77.0		13.38	2.90	16.82	3.26	20.18	3.61	21.20	3.37	22.15	3.12	23.07	2.88	24.14	2.59	29.50	2.78
80.6		12.68	2.93	16.21	3.29	19.61	3.65	20.71	3.40	21.73	3.15	22.69	2.91	23.79	2.61	29.16	2.81

FDMA24AVJU9 + RXP24AVJU9

Cooling (60 Hz, 208 V)

AFR	18.9
BF	0.21

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																			
EWB	EDB	10			20			30			35			40			46				
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI		
14.0	20.0	7.47	5.23	1.37	6.84	4.89	1.69	6.22	4.57	2.02	5.90	4.41	2.18	5.59	4.25	2.35	5.21	4.07	2.54		
16.0	22.0	7.78	5.12	1.38	7.15	4.81	1.70	6.53	4.50	2.03	6.21	4.36	2.19	5.90	4.21	2.36	5.52	4.03	2.54		
18.0	25.0	8.09	5.30	1.39	7.47	5.01	1.71	6.84	4.72	2.04	6.52	4.58	2.20	6.21	4.45	2.37	5.83	4.29	2.54		
19.4	26.7	8.31	5.29	1.39	7.68	5.02	1.72	7.05	4.75	2.05	6.74	4.61	2.21	6.43	4.48	2.37	6.05	4.33	2.54		
22.0	30.0	8.71	5.31	1.41	8.09	5.06	1.73	7.46	4.81	2.06	7.14	4.70	2.22	6.83	4.58	2.39	6.45	4.44	2.54		
24.0	32.0	9.02	5.14	1.42	8.40	4.92	1.74	7.77	4.69	2.07	7.46	4.58	2.23	7.14	4.48	2.40	6.76	4.35	2.54		

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																			
EWB	EDB	50			68			86			95			104			115				
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI		
57.2	68.0	25.49	17.84	1.37	23.35	16.70	1.69	21.21	15.59	2.02	20.14	15.05	2.18	19.07	14.52	2.35	17.78	13.89	2.54		
60.8	71.6	26.55	17.48	1.38	24.41	16.41	1.70	22.27	15.37	2.03	21.20	14.86	2.19	20.13	14.36	2.36	18.84	13.77	2.54		
64.4	77.0	27.61	18.09	1.39	25.47	17.09	1.71	23.33	16.12	2.04	22.26	15.64	2.20	21.19	15.17	2.37	19.90	14.62	2.54		
67.0	80.0	28.35	18.06	1.39	26.21	17.11	1.72	24.07	16.19	2.05	23.00	15.74	2.21	21.93	15.30	2.37	20.64	14.77	2.54		
71.6	86.0	29.73	18.11	1.41	27.59	17.25	1.73	25.45	16.43	2.06	24.38	16.02	2.22	23.31	15.62	2.39	22.02	15.15	2.54		
75.2	89.6	30.79	17.55	1.42	28.65	16.77	1.74	26.51	16.01	2.07	25.44	15.64	2.23	24.37	15.28	2.40	23.08	14.85	2.54		

Heating (60 Hz, 208 V)

AFR	20.5
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		5.49	3.03	6.48	3.41	7.50	3.80	7.68	3.54	7.88	3.29	8.10	3.03	8.37	2.73	10.10	2.95
21.1		4.92	3.12	5.98	3.51	7.03	3.90	7.29	3.64	7.54	3.37	7.79	3.11	8.09	2.79	9.82	3.01
22.0		4.70	3.16	5.78	3.55	6.85	3.95	7.13	3.68	7.40	3.41	7.66	3.14	7.98	2.82	9.71	3.03
24.0		4.47	3.20	5.58	3.59	6.66	3.96	6.97	3.71	7.26	3.44	7.54	3.17	7.87	2.84	9.60	3.06
25.0		4.36	3.22	5.48	3.61	6.57	3.96	6.89	3.73	7.19	3.46	7.48	3.18	7.81	2.85	9.55	3.07
27.0		4.13	3.25	4.96	3.29	6.13	3.77	6.73	3.77	7.05	3.49	7.35	3.21	7.70	2.88	9.43	3.10

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		18.73	3.03	22.11	3.41	25.58	3.80	26.20	3.54	26.90	3.29	27.63	3.03	28.55	2.73	34.47	2.95
70.0		16.80	3.12	20.40	3.51	24.00	3.90	24.86	3.64	25.71	3.37	26.57	3.11	27.60	2.79	33.52	3.01
71.6		16.03	3.16	19.72	3.55	23.37	3.95	24.32	3.68	25.24	3.41	26.15	3.14	27.22	2.82	33.14	3.03
75.2		15.25	3.20	19.04	3.59	22.73	3.96	23.78	3.71	24.77	3.44	25.72	3.17	26.84	2.84	32.76	3.06
77.0		14.87	3.22	18.69	3.61	22.42	3.96	23.51	3.73	24.53	3.46	25.51	3.18	26.65	2.85	32.57	3.07
80.6		14.09	3.25	16.92	3.29	20.91	3.77	22.98	3.77	24.06	3.49	25.09	3.21	26.27	2.88	32.19	3.10