

7. Capacity Tables

FTXC09BVJU9 + RXC09BVJU9

Cooling (60 Hz, 208 V)

AFR	11.5
BF	0.10

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	3.41	2.72	0.69	3.12	2.59	0.85	2.84	2.45	1.01	2.69	2.39	1.10	2.55	2.32	1.18	2.20	2.17	1.07
16.0	22.0	3.55	2.67	0.69	3.27	2.55	0.86	2.98	2.42	1.02	2.84	2.36	1.10	2.69	2.30	1.18	2.34	2.15	1.07
18.0	25.0	3.69	2.82	0.70	3.41	2.71	0.86	3.12	2.59	1.02	2.98	2.53	1.11	2.83	2.48	1.19	2.48	2.34	1.07
19.4	26.7	3.79	2.84	0.70	3.51	2.73	0.86	3.22	2.62	1.03	3.08	2.57	1.11	2.93	2.51	1.19	2.58	2.38	1.07
22.0	30.0	3.98	2.90	0.79	3.69	2.80	0.87	3.40	2.70	1.03	3.26	2.65	1.12	3.12	2.61	1.20	2.75	2.49	1.07
24.0	32.0	4.12	2.83	0.79	3.83	2.74	0.88	3.55	2.65	1.04	3.40	2.61	1.12	3.26	2.56	1.20	2.89	2.45	1.07

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	11.64	9.29	0.69	10.66	8.83	0.85	9.68	8.37	1.01	9.19	8.15	1.10	8.70	7.93	1.18	7.52	7.40	1.07
60.8	71.6	12.12	9.12	0.69	11.14	8.68	0.86	10.17	8.26	1.02	9.68	8.05	1.10	9.19	7.84	1.18	7.99	7.34	1.07
64.4	77.0	12.61	9.63	0.70	11.63	9.23	0.86	10.65	8.84	1.02	10.16	8.64	1.11	9.67	8.45	1.19	8.46	7.98	1.07
67.0	80.0	12.94	9.70	0.70	11.97	9.31	0.86	10.99	8.94	1.03	10.50	8.76	1.11	10.01	8.57	1.19	8.79	8.12	1.07
71.6	86.0	13.57	9.90	0.79	12.60	9.55	0.87	11.62	9.22	1.03	11.13	9.05	1.12	10.64	8.89	1.20	9.40	8.48	1.07
75.2	89.6	14.06	9.66	0.79	13.08	9.35	0.88	12.10	9.04	1.04	11.61	8.89	1.12	11.12	8.74	1.20	9.87	8.36	1.07

Heating (60 Hz, 208 V)

AFR	11.0
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		10 / (15)		18 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		1.84	0.76	2.01	0.83	2.34	0.87	2.68	0.91	3.42	1.03	3.72	1.07	4.31	1.14
21.1		1.70	0.79	1.89	0.86	2.22	0.90	2.55	0.94	3.28	1.06	3.58	1.09	4.17	1.16
22.0		1.68	0.79	1.87	0.86	2.20	0.90	2.54	0.94	3.26	1.06	3.56	1.10	4.15	1.17
24.0		1.64	0.80	1.83	0.87	2.16	0.91	2.49	0.95	3.22	1.07	3.51	1.11	4.11	1.18
25.0		1.61	0.81	1.81	0.87	2.14	0.91	2.47	0.95	3.19	1.08	3.49	1.11	4.08	1.18
27.0		1.57	0.81	1.77	0.88	2.10	0.92	2.43	0.96	3.15	1.09	3.45	1.12	4.04	1.19

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		50 / (59)		64 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		6.27	0.76	6.86	0.83	8.00	0.87	9.14	0.91	11.67	1.03	12.68	1.07	14.71	1.14
70.0		5.80	0.79	6.44	0.86	7.58	0.90	8.71	0.94	11.20	1.06	12.21	1.09	14.24	1.16
71.6		5.73	0.79	6.38	0.86	7.51	0.90	8.65	0.94	11.13	1.06	12.14	1.10	14.17	1.17
75.2		5.58	0.80	6.24	0.87	7.37	0.91	8.51	0.95	10.98	1.07	11.99	1.11	14.01	1.18
77.0		5.50	0.81	6.17	0.87	7.30	0.91	8.44	0.95	10.90	1.08	11.91	1.11	13.93	1.18
80.6		5.35	0.81	6.03	0.88	7.17	0.92	8.30	0.96	10.74	1.09	11.76	1.12	13.78	1.19

FTXC12BVJU9 + RXC12BVJU9

Cooling (60 Hz, 208 V)

AFR	12.3
BF	0.12

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	3.87	3.00	0.85	3.54	2.84	1.05	3.22	2.69	1.25	3.05	2.61	1.35	2.73	2.46	1.26	2.27	2.26	1.07
16.0	22.0	4.03	2.94	0.85	3.70	2.79	1.06	3.38	2.65	1.26	3.21	2.58	1.36	2.88	2.44	1.26	2.42	2.24	1.07
18.0	25.0	4.19	3.09	0.86	3.86	2.96	1.06	3.54	2.82	1.26	3.38	2.76	1.37	3.04	2.62	1.26	2.58	2.45	1.07
19.4	26.7	4.30	3.11	0.86	3.97	2.98	1.07	3.65	2.85	1.27	3.49	2.79	1.37	3.15	2.66	1.26	2.69	2.49	1.07
22.0	30.0	4.51	3.16	0.87	4.18	3.05	1.07	3.86	2.93	1.28	3.70	2.88	1.38	3.35	2.76	1.26	2.89	2.61	1.07
24.0	32.0	4.67	3.08	0.98	4.34	2.98	1.08	4.02	2.87	1.28	3.86	2.82	1.38	3.51	2.71	1.26	3.05	2.58	1.07

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	13.19	10.23	0.85	12.08	9.69	1.05	10.97	9.17	1.25	10.42	8.91	1.35	9.31	8.40	1.26	7.74	7.70	1.07
60.8	71.6	13.74	10.03	0.85	12.63	9.53	1.06	11.52	9.04	1.26	10.97	8.80	1.36	9.84	8.31	1.26	8.27	7.66	1.07
64.4	77.0	14.29	10.56	0.86	13.18	10.09	1.06	12.07	9.64	1.26	11.52	9.41	1.37	10.37	8.95	1.26	8.80	8.34	1.07
67.0	80.0	14.67	10.61	0.86	13.56	10.17	1.07	12.45	9.74	1.27	11.90	9.52	1.37	10.74	9.09	1.26	9.17	8.51	1.07
71.6	86.0	15.38	10.79	0.87	14.28	10.40	1.07	13.17	10.01	1.28	12.61	9.82	1.38	11.43	9.42	1.26	9.86	8.90	1.07
75.2	89.6	15.93	10.52	0.98	14.82	10.16	1.08	13.72	9.81	1.28	13.16	9.63	1.38	11.96	9.26	1.26	10.39	8.79	1.07

Heating (60 Hz, 208 V)

AFR	12.4
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		10 / (15)		18 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.15	0.89	2.30	0.91	2.68	0.95	3.06	0.99	3.91	1.08	4.25	1.12	4.93	1.19
21.1		1.99	0.92	2.16	0.93	2.54	0.98	2.92	1.02	3.75	1.11	4.09	1.15	4.77	1.22
22.0		1.97	0.92	2.14	0.94	2.52	0.98	2.90	1.03	3.73	1.11	4.07	1.15	4.74	1.22
24.0		1.92	0.93	2.09	0.95	2.47	0.99	2.85	1.04	3.68	1.12	4.02	1.16	4.69	1.23
25.0		1.89	0.94	2.07	0.95	2.45	1.00	2.83	1.04	3.65	1.13	3.99	1.17	4.67	1.24
27.0		1.84	0.95	2.02	0.96	2.40	1.01	2.78	1.05	3.60	1.14	3.94	1.18	4.62	1.25

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		50 / (59)		64 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		7.35	0.89	7.84	0.91	9.14	0.95	10.44	0.99	13.34	1.08	14.50	1.12	16.81	1.19
70.0		6.80	0.92	7.36	0.93	8.66	0.98	9.96	1.02	12.80	1.11	13.96	1.15	16.27	1.22
71.6		6.72	0.92	7.29	0.94	8.59	0.98	9.89	1.03	12.72	1.11	13.88	1.15	16.19	1.22
75.2		6.54	0.93	7.13	0.95	8.43	0.99	9.73	1.04	12.54	1.12	13.70	1.16	16.01	1.23
77.0		6.45	0.94	7.05	0.95	8.35	1.00	9.65	1.04	12.46	1.13	13.61	1.17	15.92	1.24
80.6		6.27	0.95	6.89	0.96	8.19	1.01	9.49	1.05	12.28	1.14	13.43	1.18	15.75	1.25

FTXC18BVJU9 + RXC18BVJU9

Cooling (60 Hz, 208 V)

AFR	10.7
BF	0.21

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.12	2.90	0.78	4.12	2.90	1.07	4.12	2.90	1.48	4.12	2.90	1.78	4.12	2.90	2.17	3.37	2.51	2.27
16.0	22.0	5.06	3.24	1.04	5.06	3.24	1.47	5.02	3.22	2.11	4.78	3.09	2.28	4.54	2.97	2.45	3.59	2.50	2.27
18.0	25.0	6.07	3.75	1.37	5.75	3.58	1.78	5.26	3.33	2.12	5.02	3.21	2.29	4.78	3.10	2.46	3.81	2.65	2.27
19.4	26.7	6.40	3.81	1.45	5.91	3.57	1.79	5.43	3.33	2.13	5.19	3.22	2.30	4.95	3.11	2.47	3.96	2.68	2.27
22.0	30.0	6.71	3.78	1.46	6.22	3.55	1.80	5.74	3.34	2.14	5.50	3.24	2.31	5.26	3.14	2.48	4.25	2.74	2.27
24.0	32.0	6.95	3.64	1.47	6.46	3.44	1.81	5.98	3.25	2.15	5.74	3.15	2.32	5.50	3.06	2.49	4.47	2.68	2.27

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	14.06	9.90	0.78	14.06	9.90	1.07	14.06	9.90	1.48	14.06	9.90	1.78	14.06	9.90	2.17	11.49	8.57	2.27
60.8	71.6	17.26	11.06	1.04	17.26	11.06	1.47	17.14	10.99	2.11	16.32	10.56	2.28	15.49	10.13	2.45	12.24	8.53	2.27
64.4	77.0	20.71	12.80	1.37	19.60	12.21	1.78	17.95	11.37	2.12	17.13	10.96	2.29	16.31	10.56	2.46	13.00	9.03	2.27
67.0	80.0	21.82	13.01	1.45	20.17	12.18	1.79	18.53	11.37	2.13	17.70	10.98	2.30	16.88	10.60	2.47	13.53	9.13	2.27
71.6	86.0	22.88	12.88	1.46	21.23	12.13	1.80	19.59	11.40	2.14	18.76	11.05	2.31	17.94	10.71	2.48	14.51	9.34	2.27
75.2	89.6	23.70	12.43	1.47	22.05	11.74	1.81	20.40	11.07	2.15	19.58	10.75	2.32	18.75	10.43	2.49	15.26	9.16	2.27

Heating (60 Hz, 208 V)

AFR	12.5
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		10 / (15)		18 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		3.70	1.60	3.90	1.74	4.54	1.82	5.19	1.91	6.41	2.16	6.97	2.23	8.08	2.38
21.1		3.43	1.65	3.66	1.79	4.30	1.88	4.95	1.96	6.16	2.22	6.71	2.29	7.68	2.37
22.0		3.39	1.66	3.62	1.80	4.27	1.89	4.91	1.97	6.12	2.23	6.67	2.30	7.47	2.30
24.0		3.30	1.68	3.54	1.82	4.19	1.90	4.83	1.99	6.03	2.25	6.59	2.32	7.00	2.14
25.0		3.25	1.69	3.50	1.83	4.15	1.91	4.79	2.00	5.99	2.26	6.55	2.33	6.77	2.06
27.0		3.16	1.71	3.42	1.85	4.07	1.93	4.72	2.02	5.90	2.28	6.30	2.27	6.30	1.90

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		50 / (59)		64 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		12.64	1.60	13.30	1.74	15.50	1.82	17.71	1.91	21.89	2.16	23.78	2.23	27.58	2.38
70.0		11.70	1.65	12.47	1.79	14.68	1.88	16.88	1.96	21.00	2.22	22.90	2.29	26.20	2.37
71.6		11.56	1.66	12.35	1.80	14.56	1.89	16.76	1.97	20.87	2.23	22.77	2.30	25.48	2.30
75.2		11.25	1.68	12.08	1.82	14.29	1.90	16.49	1.99	20.58	2.25	22.48	2.32	23.89	2.14
77.0		11.10	1.69	11.95	1.83	14.15	1.91	16.36	2.00	20.44	2.26	22.33	2.33	23.09	2.06
80.6		10.79	1.71	11.68	1.85	13.88	1.93	16.09	2.02	20.15	2.28	21.50	2.27	21.50	1.90

FTXC24BVJU9 + RXC24BVJU9

Cooling (60 Hz, 208 V)

AFR	19.5
BF	0.33

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	6.32	4.45	1.10	6.32	4.45	1.56	6.30	4.44	2.27	5.98	4.27	2.45	5.66	4.10	2.63	4.53	3.54	2.27
16.0	22.0	7.76	4.97	1.50	7.25	4.70	1.91	6.61	4.38	2.28	6.29	4.22	2.46	5.98	4.06	2.64	4.83	3.52	2.27
18.0	25.0	8.20	5.18	1.56	7.56	4.86	1.92	6.93	4.56	2.29	6.61	4.41	2.47	6.29	4.26	2.66	5.13	3.75	2.27
19.4	26.7	8.42	5.16	1.56	7.78	4.86	1.93	7.15	4.57	2.30	6.83	4.43	2.48	6.51	4.29	2.66	5.34	3.80	2.27
22.0	30.0	8.83	5.14	1.58	8.19	4.87	1.94	7.56	4.60	2.31	7.24	4.48	2.49	6.92	4.35	2.68	5.73	3.90	2.27
24.0	32.0	9.14	4.97	1.59	8.51	4.72	1.96	7.87	4.48	2.32	7.55	4.36	2.51	7.23	4.25	2.69	6.03	3.83	2.27

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	21.55	15.18	1.10	21.55	15.18	1.56	21.49	15.14	2.27	20.40	14.57	2.45	19.32	14.00	2.63	15.45	12.07	2.27
60.8	71.6	26.47	16.96	1.50	24.73	16.04	1.91	22.56	14.93	2.28	21.48	14.39	2.46	20.39	13.86	2.64	16.48	12.01	2.27
64.4	77.0	27.97	17.66	1.56	25.80	16.59	1.92	23.63	15.55	2.29	22.55	15.04	2.47	21.46	14.54	2.66	17.50	12.79	2.27
67.0	80.0	28.73	17.59	1.56	26.56	16.57	1.93	24.39	15.58	2.30	23.30	15.10	2.48	22.22	14.63	2.66	18.22	12.95	2.27
71.6	86.0	30.12	17.52	1.58	27.95	16.60	1.94	25.78	15.71	2.31	24.70	15.28	2.49	23.61	14.85	2.68	19.55	13.32	2.27
75.2	89.6	31.19	16.94	1.59	29.02	16.10	1.96	26.85	15.29	2.32	25.77	14.89	2.51	24.68	14.50	2.69	20.58	13.07	2.27

Heating (60 Hz, 208 V)

AFR	21.5
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		10 / (15)		18 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.53	1.96	4.84	2.02	5.65	2.12	6.45	2.22	7.97	2.38	8.66	2.46	10.05	2.62
21.1		4.19	2.03	4.54	2.08	5.35	2.18	6.15	2.28	7.65	2.45	8.34	2.53	9.72	2.69
22.0		4.14	2.04	4.50	2.09	5.30	2.19	6.11	2.29	7.60	2.46	8.29	2.54	9.68	2.70
24.0		4.03	2.06	4.40	2.12	5.20	2.21	6.01	2.31	7.50	2.48	8.19	2.56	9.57	2.72
25.0		3.98	2.07	4.35	2.13	5.16	2.23	5.96	2.32	7.44	2.49	8.14	2.57	9.52	2.74
27.0		3.87	2.09	4.25	2.15	5.06	2.25	5.86	2.35	7.34	2.52	8.03	2.60	9.38	2.74

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		50 / (59)		64 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		15.45	1.96	16.53	2.02	19.27	2.12	22.01	2.22	27.20	2.38	29.56	2.46	34.27	2.62
70.0		14.30	2.03	15.50	2.08	18.24	2.18	20.99	2.28	26.10	2.45	28.46	2.53	33.18	2.69
71.6		14.13	2.04	15.35	2.09	18.09	2.19	20.83	2.29	25.94	2.46	28.30	2.54	33.01	2.70
75.2		13.76	2.06	15.02	2.12	17.76	2.21	20.50	2.31	25.58	2.48	27.94	2.56	32.65	2.72
77.0		13.57	2.07	14.85	2.13	17.59	2.23	20.33	2.32	25.40	2.49	27.76	2.57	32.47	2.74
80.6		13.19	2.09	14.51	2.15	17.26	2.25	20.00	2.35	25.04	2.52	27.40	2.60	32.00	2.74