

FVXV09AVJUW(T)9 + RXP09AVJU9**Cooling (60 Hz, 208 V)**

AFR	8.4
BF	0.17

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	3.54	2.45	0.53	3.24	2.29	0.66	2.95	2.13	0.79	2.80	2.05	0.85	2.65	1.98	0.91	2.47	1.89	0.99
16.0	22.0	3.69	2.40	0.54	3.39	2.25	0.66	3.09	2.10	0.79	2.94	2.03	0.85	2.80	1.96	0.92	2.62	1.87	0.99
18.0	25.0	3.84	2.48	0.54	3.54	2.33	0.67	3.24	2.20	0.79	3.09	2.13	0.86	2.94	2.06	0.92	2.76	1.99	1.00
19.4	26.7	3.94	2.47	0.54	3.64	2.34	0.67	3.34	2.21	0.80	3.19	2.14	0.86	3.05	2.08	0.92	2.87	2.00	1.00
22.0	30.0	4.13	2.47	0.55	3.83	2.35	0.67	3.54	2.23	0.80	3.39	2.18	0.86	3.24	2.12	0.93	3.06	2.05	1.00
24.0	32.0	4.28	2.39	0.68	3.98	2.28	0.68	3.68	2.17	0.80	3.53	2.12	0.87	3.38	2.07	0.93	3.21	2.01	1.01

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	12.08	8.36	0.53	11.07	7.80	0.66	10.05	7.27	0.79	9.55	7.01	0.85	9.04	6.75	0.91	8.43	6.45	0.99
60.8	71.6	12.59	8.19	0.54	11.57	7.67	0.66	10.56	7.17	0.79	10.05	6.92	0.85	9.54	6.68	0.92	8.93	6.40	0.99
64.4	77.0	13.09	8.45	0.54	12.07	7.97	0.67	11.06	7.50	0.79	10.55	7.27	0.86	10.04	7.04	0.92	9.43	6.78	1.00
67.0	80.0	13.44	8.43	0.54	12.42	7.97	0.67	11.41	7.53	0.80	10.90	7.31	0.86	3.20	7.09	0.92	9.78	6.84	1.00
71.6	86.0	14.09	8.43	0.55	13.08	8.02	0.67	12.06	7.62	0.80	11.55	7.42	0.86	11.05	7.23	0.93	10.44	7.00	1.00
75.2	89.6	14.59	8.16	0.68	13.58	7.79	0.68	12.56	7.42	0.80	12.06	7.24	0.87	11.55	7.06	0.93	10.94	6.86	1.01

Heating (60 Hz, 208 V)

AFR	9.1
-----	-----

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.22	1.64	2.85	1.68	3.45	1.72	3.87	1.69	4.29	1.67	4.71	1.65	5.22	1.63	6.04	1.76
21.1		1.77	1.42	2.58	1.74	3.19	1.77	3.63	1.75	4.06	1.73	4.49	1.70	5.01	1.67	5.77	1.76
22.0		1.61	1.25	2.54	1.74	3.16	1.78	3.59	1.76	4.03	1.73	4.46	1.71	4.98	1.68	5.61	1.69
24.0		1.26	0.91	2.46	1.76	3.07	1.80	3.51	1.78	3.95	1.75	4.39	1.72	4.91	1.69	5.26	1.53
25.0		1.08	0.76	2.41	1.77	3.03	1.81	3.47	1.79	3.91	1.76	4.35	1.73	4.88	1.70	5.09	1.46
27.0		0.73	0.48	2.25	1.67	2.95	1.83	3.40	1.80	3.84	1.78	4.28	1.75	4.74	1.66	4.74	1.31

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		7.57	1.64	9.71	1.68	11.77	1.72	13.19	1.69	14.63	1.67	16.08	1.65	17.82	1.63	20.60	1.76
70.0		6.03	1.42	8.81	1.74	10.90	1.77	12.38	1.75	13.85	1.73	15.33	1.70	17.10	1.67	19.69	1.76
71.6		5.50	1.25	8.68	1.74	10.77	1.78	12.26	1.76	13.74	1.73	15.22	1.71	16.99	1.68	19.15	1.69
75.2		4.30	0.91	8.38	1.76	10.48	1.80	11.99	1.78	13.48	1.75	14.97	1.72	16.76	1.69	17.96	1.53
77.0		3.70	0.76	8.24	1.77	10.34	1.81	11.85	1.79	13.36	1.76	14.85	1.73	16.64	1.70	17.36	1.46
80.6		2.50	0.48	7.67	1.67	10.06	1.83	11.59	1.80	13.10	1.78	14.61	1.75	16.16	1.66	16.16	1.31

FVXV12AVJUW(T)9 + RXP12AVJU9**Cooling (60 Hz, 208 V)**

AFR	9.1
BF	0.21

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.08	2.76	0.72	3.75	2.58	0.90	3.41	2.39	1.07	3.23	2.30	1.16	3.06	2.21	1.24	2.86	2.10	1.17
16.0	22.0	4.26	2.72	0.73	3.92	2.53	0.90	3.58	2.35	1.07	3.40	2.27	1.16	3.23	2.18	1.25	3.03	2.08	1.17
18.0	25.0	4.43	2.79	0.73	4.09	2.62	0.91	3.75	2.45	1.08	3.57	2.37	1.17	3.40	2.29	1.25	3.20	2.20	1.17
19.4	26.7	4.55	2.78	0.74	4.21	2.61	0.91	3.86	2.46	1.08	3.69	2.38	1.17	3.52	2.30	1.26	3.31	2.21	1.17
22.0	30.0	4.77	2.76	0.74	4.43	2.62	0.92	4.09	2.47	1.09	3.91	2.40	1.18	3.74	2.34	1.26	3.54	2.26	1.17
24.0	32.0	4.94	2.67	0.75	4.60	2.54	0.92	4.26	2.41	1.09	4.08	2.34	1.18	3.91	2.28	1.27	3.71	2.21	1.17

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	13.92	9.43	0.72	12.79	8.79	0.90	11.62	8.15	1.07	11.03	7.84	1.16	10.45	7.53	1.24	9.74	7.17	1.17
60.8	71.6	14.55	9.27	0.73	13.37	8.64	0.90	12.20	8.04	1.07	11.61	7.74	1.16	11.03	7.45	1.25	10.32	7.11	1.17
64.4	77.0	15.13	9.51	0.73	13.95	8.93	0.91	12.78	8.36	1.08	12.19	8.08	1.17	11.61	7.81	1.25	10.90	7.49	1.17
67.0	80.0	15.53	9.47	0.74	14.36	8.92	0.91	13.19	8.38	1.08	12.60	8.11	1.17	3.69	7.86	1.26	11.31	7.55	1.17
71.6	86.0	16.29	9.43	0.74	15.12	8.93	0.92	13.94	8.44	1.09	13.36	8.20	1.18	12.77	7.97	1.26	12.06	7.70	1.17
75.2	89.6	16.87	9.11	0.75	15.70	8.65	0.92	14.52	8.21	1.09	13.94	7.99	1.18	13.35	7.78	1.27	12.64	7.53	1.17

Heating (60 Hz, 208 V)

AFR	10.5
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.22	1.64	2.85	1.68	3.45	1.72	4.07	1.76	4.70	1.80	5.33	1.84	6.08	1.89	7.27	2.04
21.1		1.94	1.70	2.58	1.74	3.19	1.77	3.82	1.81	4.45	1.86	5.08	1.90	5.83	1.94	6.74	1.93
22.0		1.88	1.68	2.54	1.74	3.16	1.78	3.78	1.82	4.41	1.86	5.04	1.90	5.80	1.95	6.56	1.85
24.0		1.47	1.21	2.46	1.76	3.07	1.80	3.70	1.84	4.33	1.88	4.96	1.92	5.72	1.97	6.15	1.69
25.0		1.27	1.00	2.41	1.77	3.03	1.81	3.66	1.85	4.29	1.89	4.92	1.93	5.67	1.98	5.94	1.61
27.0		0.86	0.63	2.33	1.79	2.95	1.83	3.58	1.87	4.21	1.91	4.84	1.95	5.53	1.95	5.53	1.46

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		7.57	1.64	9.71	1.68	11.77	1.72	13.90	1.76	16.04	1.80	18.17	1.84	20.74	1.89	24.80	2.04
70.0		6.63	1.70	8.81	1.74	10.90	1.77	13.04	1.81	15.19	1.86	17.33	1.90	19.90	1.94	23.00	1.93
71.6		6.42	1.68	8.68	1.74	10.77	1.78	12.92	1.82	15.06	1.86	17.20	1.90	19.78	1.95	22.37	1.85
75.2		5.02	1.21	8.38	1.76	10.48	1.80	12.63	1.84	14.78	1.88	16.93	1.92	19.50	1.97	20.97	1.69
77.0		4.32	1.00	8.24	1.77	10.34	1.81	12.49	1.85	14.64	1.89	16.79	1.93	19.36	1.98	20.28	1.61
80.6		2.92	0.63	7.94	1.79	10.06	1.83	12.21	1.87	14.36	1.91	16.51	1.95	18.88	1.95	18.88	1.46

FVXV15AVJUW(T)9 + RXP15AVJU9**Cooling (60 Hz, 208 V)**

AFR	11.1
BF	0.22

Temp: Celsius / TC, SHC, PI: kW

Temp. Celsius / °C, SHC, PI, kW																				
INDOOR		OUTDOOR TEMPERATURE (°CDB)																		
EWB	EDB	10			20			30			35			40			46			
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	
14.0	20.0	4.93	3.34	0.75	4.93	3.34	1.03	4.93	3.34	1.41	4.90	3.32	1.64	4.64	3.18	1.76	4.33	3.00	1.91	
16.0	22.0	5.85	3.67	0.90	5.85	3.67	1.25	5.42	3.43	1.53	5.16	3.29	1.65	4.90	3.15	1.77	4.59	2.98	1.92	
18.0	25.0	6.72	4.10	1.04	6.20	3.81	1.29	5.68	3.53	1.53	5.42	3.40	1.66	5.16	3.27	1.78	4.84	3.11	1.93	
19.4	26.7	6.90	4.07	1.05	6.38	3.80	1.29	5.86	3.53	1.54	5.60	3.40	1.66	5.34	3.28	1.78	5.02	3.13	1.93	
22.0	30.0	7.24	4.02	1.06	6.72	3.77	1.30	6.19	3.53	1.55	5.93	3.41	1.67	5.67	3.30	1.79	5.36	3.16	1.94	
24.0	32.0	7.49	3.87	1.06	6.97	3.64	1.31	6.45	3.42	1.56	6.19	3.31	1.68	5.93	3.21	1.80	5.62	3.09	1.95	

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	16.82	11.40	0.75	16.82	11.40	1.03	16.82	11.40	1.41	16.72	11.34	1.64	15.84	10.84	1.76	14.77	10.24	1.91
60.8	71.6	19.97	12.54	0.90	19.97	12.54	1.25	18.49	11.70	1.53	17.60	11.21	1.65	16.72	10.73	1.77	15.65	10.17	1.92
64.4	77.0	22.93	14.00	1.04	21.15	13.01	1.29	19.37	12.06	1.53	18.48	11.60	1.66	17.60	11.15	1.78	16.53	10.62	1.93
67.0	80.0	23.55	13.90	1.05	21.77	12.95	1.29	19.99	12.05	1.54	19.10	11.61	1.66	18.21	11.18	1.78	17.14	10.68	1.93
71.6	86.0	24.69	13.72	1.06	22.91	12.86	1.30	21.13	12.04	1.55	20.24	11.64	1.67	19.35	11.25	1.79	18.29	10.80	1.94
75.2	89.6	25.57	13.22	1.06	23.79	12.43	1.31	22.01	11.68	1.56	21.12	11.31	1.68	20.23	10.95	1.80	19.17	10.53	1.95

Heating (60 Hz, 208 V)

AFR	11.8
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.12	2.27	4.86	2.56	5.62	2.85	5.74	2.62	5.87	2.39	6.01	2.16	6.19	1.89	7.47	2.04
21.1		3.69	2.34	4.48	2.64	5.28	2.93	5.44	2.69	5.61	2.45	5.78	2.22	5.98	1.93	7.23	2.06
22.0		3.52	2.37	4.30	2.63	5.04	2.85	5.33	2.72	5.51	2.48	5.69	2.24	5.90	1.95	6.81	1.91
24.0		3.33	2.37	3.89	2.34	4.63	2.56	5.21	2.75	5.40	2.50	5.59	2.26	5.81	1.96	6.40	1.77
25.0		3.12	2.22	3.68	2.20	4.43	2.42	5.15	2.76	5.35	2.51	5.55	2.27	5.77	1.97	6.20	1.70
27.0		2.71	1.92	3.27	1.92	4.01	2.15	5.03	2.79	5.25	2.54	5.46	2.29	5.69	1.99	5.78	1.56

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		14.05	2.27	16.58	2.56	19.18	2.85	19.58	2.62	20.02	2.39	20.50	2.16	21.10	1.89	25.48	2.04
70.0		12.60	2.34	15.30	2.64	18.00	2.93	18.57	2.69	19.14	2.45	19.71	2.22	20.40	1.93	24.66	2.06
71.6		12.02	2.37	14.68	2.63	17.21	2.85	18.17	2.72	18.79	2.48	19.40	2.24	20.12	1.95	23.25	1.91
75.2		11.36	2.37	13.27	2.34	15.80	2.56	17.77	2.75	18.44	2.50	19.08	2.26	19.84	1.96	21.84	1.77
77.0		10.66	2.22	12.57	2.20	15.10	2.42	17.57	2.76	18.26	2.51	18.93	2.27	19.70	1.97	21.14	1.70
80.6		9.25	1.92	11.16	1.92	13.69	2.15	17.17	2.79	17.91	2.54	18.61	2.29	19.41	1.99	19.73	1.56

FVXV18AVJUW(T)9 + RXP18AVJU9**Cooling (60 Hz, 208 V)**

AFR	12.7
BF	0.24

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	5.52	3.74	0.83	5.52	3.74	1.16	5.52	3.74	1.63	5.49	3.72	1.94	5.20	3.56	2.09	4.85	3.36	2.26
16.0	22.0	6.55	4.11	1.03	6.55	4.11	1.47	6.07	3.84	1.81	5.78	3.68	1.95	5.49	3.52	2.10	5.14	3.34	2.27
18.0	25.0	7.53	4.60	1.23	6.95	4.27	1.52	6.36	3.96	1.81	6.07	3.81	1.96	5.78	3.66	2.11	5.43	3.49	2.28
19.4	26.7	7.73	4.56	1.24	7.15	4.25	1.53	6.56	3.95	1.82	6.27	3.81	1.97	5.98	3.67	2.11	5.63	3.50	2.29
22.0	30.0	8.11	4.50	1.25	7.52	4.22	1.54	6.94	3.95	1.83	6.65	3.82	1.98	6.36	3.69	2.12	6.01	3.54	2.30
24.0	32.0	8.40	4.34	1.26	7.81	4.08	1.55	7.23	3.83	1.84	6.94	3.71	1.99	6.64	3.60	2.13	6.29	3.46	2.31

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	18.82	12.75	0.83	18.82	12.75	1.16	18.82	12.75	1.63	18.74	12.70	1.94	17.74	12.14	2.09	16.55	11.47	2.26
60.8	71.6	22.34	14.02	1.03	22.34	14.02	1.47	20.72	13.11	1.81	19.72	12.56	1.95	18.73	12.02	2.10	17.53	11.39	2.27
64.4	77.0	25.69	15.69	1.23	23.70	14.57	1.52	21.71	13.51	1.81	20.71	12.99	1.96	19.71	12.49	2.11	18.52	11.90	2.28
67.0	80.0	26.38	15.57	1.24	24.39	14.51	1.53	22.40	13.49	1.82	21.40	13.00	1.97	20.40	12.52	2.11	19.21	11.96	2.29
71.6	86.0	27.66	15.37	1.25	25.67	14.40	1.54	23.68	13.48	1.83	22.68	13.04	1.98	21.69	12.60	2.12	20.49	12.09	2.30
75.2	89.6	28.65	14.81	1.26	26.66	13.92	1.55	24.66	13.08	1.84	23.67	12.67	1.99	22.67	12.27	2.13	21.48	11.80	2.31

Heating (60 Hz, 208 V)

AFR	12.9
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)															
EDB		-25.5/(-25)		-20/(-20)		-15/(-15)		-10/(-9)		-5/(-4)		0/(1.5)		6/(8.3)		15.5/(24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.12	2.27	4.86	2.56	5.62	2.85	5.84	2.61	6.07	2.37	6.31	2.13	6.61	1.84	7.98	1.99
21.1		3.69	2.34	4.48	2.64	5.28	2.93	5.54	2.68	5.81	2.43	6.07	2.18	6.39	1.89	7.74	2.02
22.0		3.52	2.37	4.33	2.67	5.14	2.96	5.42	2.71	5.70	2.46	5.97	2.20	6.30	1.90	7.30	1.91
24.0		3.35	2.40	4.16	2.68	4.96	2.96	5.30	2.74	5.59	2.48	5.88	2.23	6.21	1.92	6.85	1.79
25.0		3.27	2.42	3.94	2.55	4.74	2.83	5.24	2.75	5.54	2.49	5.83	2.24	6.17	1.93	6.63	1.74
27.0		2.90	2.22	3.50	2.28	4.30	2.56	5.12	2.78	5.43	2.52	5.73	2.26	6.08	1.94	6.19	1.62

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FWB)															
EDB		-13.8/(-13)		-4/(-4)		5/(5)		14/(15.8)		23/(24.8)		32/(34.7)		43/(47)		60/(75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		14.05	2.27	16.58	2.56	19.18	2.85	19.93	2.61	20.72	2.37	21.54	2.13	22.55	1.84	27.23	1.99
70.0		12.60	2.34	15.30	2.64	18.00	2.93	18.90	2.68	19.81	2.43	20.71	2.18	21.80	1.89	26.40	2.02
71.6		12.02	2.37	14.79	2.67	17.53	2.96	18.50	2.71	19.45	2.46	20.38	2.20	21.50	1.90	24.89	1.91
75.2		11.44	2.40	14.21	2.68	16.92	2.96	18.09	2.74	19.08	2.48	20.05	2.23	21.20	1.92	23.39	1.79
77.0		11.15	2.42	13.45	2.55	16.17	2.83	17.88	2.75	18.90	2.49	19.89	2.24	21.05	1.93	22.63	1.74
80.6		9.90	2.22	11.94	2.28	14.66	2.56	17.47	2.78	18.54	2.52	19.56	2.26	20.75	1.94	21.12	1.62