

7. Capacity Tables

FTKF09BVJU9 + RKF09BVJU9

Cooling (60 Hz, 208 V)

AFR	10.8
BF	0.20

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																				
EWB	EDB	10			20			30			35			40			46			48		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	3.64	2.67	0.60	3.33	2.51	0.75	3.03	2.36	0.89	2.87	2.29	0.96	2.72	2.21	1.03	2.54	2.13	1.08	1.65	1.15	0.64
16.0	22.0	3.79	2.61	0.61	3.48	2.47	0.75	3.18	2.33	0.89	3.03	2.26	0.97	2.87	2.19	1.04	2.69	2.11	1.08	1.72	1.14	0.64
18.0	25.0	3.94	2.73	0.61	3.64	2.59	0.75	3.33	2.46	0.90	3.18	2.40	0.97	3.02	2.33	1.04	2.84	2.26	1.08	1.85	1.25	0.64
19.4	26.7	4.05	2.73	0.61	3.74	2.60	0.76	3.44	2.48	0.90	3.28	2.42	0.97	3.13	2.36	1.05	2.95	2.29	1.08	1.92	1.27	0.64
22.0	30.0	4.24	2.76	0.76	3.94	2.64	0.76	3.63	2.53	0.91	3.48	2.48	0.98	3.33	2.42	1.05	3.14	2.36	1.08	2.05	1.33	0.64
24.0	32.0	4.40	2.68	0.77	4.09	2.58	0.77	3.78	2.47	0.91	3.63	2.42	0.98	3.48	2.37	1.06	3.29	2.32	1.08	2.16	1.31	0.64

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																				
EWB	EDB	50			68			86			95			104			115			118		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	12.42	9.10	0.60	11.37	8.57	0.75	10.33	8.05	0.89	9.81	7.80	0.96	9.29	7.55	1.03	8.66	7.26	1.08	5.63	3.93	0.64
60.8	71.6	12.93	8.91	0.61	11.89	8.42	0.75	10.85	7.94	0.89	10.32	7.70	0.97	9.80	7.47	1.04	9.18	7.19	1.08	5.98	3.90	0.64
64.4	77.0	13.45	9.30	0.61	12.41	8.84	0.75	11.36	8.40	0.90	10.84	8.18	0.97	10.32	7.96	1.04	9.69	7.70	1.08	6.32	4.25	0.64
67.0	80.0	13.81	9.32	0.61	12.77	8.88	0.76	11.72	8.46	0.90	11.20	8.25	0.97	11.20	8.04	1.05	10.05	7.80	1.08	6.56	4.34	0.64
71.6	86.0	14.48	9.41	0.76	13.44	9.02	0.76	12.39	8.64	0.91	11.87	8.45	0.98	11.35	8.27	1.05	10.73	8.05	1.08	7.01	4.54	0.64
75.2	89.6	15.00	9.15	0.77	13.95	8.79	0.77	12.91	8.44	0.91	12.39	8.27	0.98	11.87	8.10	1.06	11.24	7.90	1.08	7.35	4.48	0.64

Symbols:

AFR	: Airflow rate	(m ³ /min.)
BF	: Bypass factor	
EWB	: Entering wet bulb temp.	(°C) / (°F)
EDB	: Entering dry bulb temp.	(°C) / (°F)
TC	: Total capacity	(kW) / (kBtu/h)
SHC	: Sensible heat capacity	(kW) / (kBtu/h)
PI	: Power input	(kW)

Notes:

1.  shows MAX capacities and power input.
2. TC, PI and SHC must be calculated by interpolation using the figures in the above tables. (Figures out of the tables should not be used for calculation.)
3. Capacities are based on the following conditions.
Corresponding refrigerant piping length : 25 ft (7.5 m)
Level difference : 0 ft (0 m)
4. Airflow rate (AFR) and Bypass factor (BF) are tabulated above table.

C: 3D155209

FTKF12BVJU9 + RKF12BVJU9

Cooling (60 Hz, 208 V)

AFR	11.7
BF	0.21

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																				
EWB	EDB	10			20			30			35			40			46			48		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.48	3.16	0.83	4.34	3.08	1.13	3.95	2.88	1.35	3.75	2.77	1.46	3.55	2.67	1.51	3.31	2.56	1.19	1.81	1.04	0.61
16.0	22.0	4.94	3.23	0.92	4.54	3.03	1.14	4.14	2.83	1.36	3.94	2.74	1.47	3.74	2.64	1.51	3.51	2.53	1.19	1.92	1.03	0.61
18.0	25.0	5.14	3.34	0.93	4.74	3.15	1.15	4.34	2.97	1.37	4.14	2.88	1.48	3.94	2.79	1.51	3.70	2.69	1.19	2.03	1.13	0.61
19.4	26.7	5.28	3.33	0.93	4.88	3.15	1.15	4.48	2.98	1.37	4.28	2.90	1.48	4.08	2.81	1.51	3.84	2.71	1.19	2.11	1.15	0.61
22.0	30.0	5.53	3.34	0.94	5.13	3.18	1.16	4.73	3.02	1.38	4.54	2.94	1.49	4.33	2.87	1.51	4.10	2.78	1.19	2.25	1.20	0.61
24.0	32.0	5.73	3.23	1.17	5.33	3.09	1.17	4.93	2.94	1.39	4.73	2.87	1.50	4.52	2.80	1.51	4.29	2.72	1.19	2.36	1.19	0.61

Temp: Fahrenheit / TC, SHC: kBTu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																				
EWB	EDB	50			68			86			95			104			115			118		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	15.29	10.77	0.83	14.82	10.52	1.13	13.46	9.81	1.35	12.78	9.46	1.46	12.10	9.12	1.51	11.29	8.72	1.19	6.17	3.56	0.61
60.8	71.6	16.86	11.02	0.92	15.50	10.34	1.14	14.14	9.67	1.36	13.46	9.34	1.47	12.78	9.02	1.51	11.96	8.64	1.19	6.55	3.53	0.61
64.4	77.0	17.53	11.39	0.93	16.17	10.75	1.15	14.81	10.13	1.37	14.13	9.82	1.48	13.45	9.52	1.51	12.63	9.17	1.19	6.93	3.85	0.61
67.0	80.0	18.00	11.37	0.93	16.64	10.76	1.15	15.28	10.17	1.37	14.60	9.88	1.48	14.60	9.60	1.51	13.10	9.26	1.19	7.19	3.92	0.61
71.6	86.0	18.87	11.38	0.94	17.51	10.84	1.16	16.15	10.30	1.38	15.47	10.04	1.49	14.78	9.78	1.51	13.98	9.49	1.19	7.68	4.10	0.61
75.2	89.6	19.55	11.03	1.17	18.19	10.53	1.17	16.83	10.04	1.39	16.15	9.80	1.50	15.42	9.55	1.51	14.65	9.29	1.19	8.06	4.05	0.61

Symbols:

AFR	: Airflow rate	(m ³ /min.)
BF	: Bypass factor	
EWB	: Entering wet bulb temp.	(°C) / (°F)
EDB	: Entering dry bulb temp.	(°C) / (°F)
TC	: Total capacity	(kW) / (kBTu/h)
SHC	: Sensible heat capacity	(kW) / (kBTu/h)
PI	: Power input	(kW)

Notes:

1.  shows MAX capacities and power input.
2. TC, PI and SHC must be calculated by interpolation using the figures in the above tables. (Figures out of the tables should not be used for calculation.)
3. Capacities are based on the following conditions.
Corresponding refrigerant piping length : 25 ft (7.5 m)
Level difference : 0 ft (0 m)
4. Airflow rate (AFR) and Bypass factor (BF) are tabulated above table.

C: 3D155211

FTKF18BVJU9 + RKF18BVJU9

Cooling (60 Hz, 208 V)

AFR	16.0
BF	0.18

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																				
EWB	EDB	10			20			30			35			40			46			50		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	6.39	4.50	0.92	6.39	4.50	1.31	5.95	4.27	1.65	5.65	4.11	1.78	5.35	3.96	1.91	4.99	3.78	2.07	2.37	1.28	0.87
16.0	22.0	7.45	4.81	1.12	6.85	4.51	1.39	6.25	4.21	1.65	5.94	4.06	1.79	5.64	3.91	1.92	5.28	3.74	2.08	2.52	1.27	0.87
18.0	25.0	7.74	4.96	1.13	7.14	4.67	1.40	6.54	4.39	1.66	6.24	4.26	1.79	5.94	4.12	1.93	5.58	3.96	2.09	2.67	1.39	0.87
19.4	26.7	7.95	4.95	1.13	7.35	4.67	1.40	6.75	4.41	1.67	6.45	4.28	1.80	6.15	4.15	1.93	5.79	4.00	2.09	2.77	1.42	0.87
22.0	30.0	8.34	4.94	1.15	7.74	4.70	1.41	7.14	4.46	1.68	6.84	4.34	1.81	6.54	4.22	1.94	6.18	4.09	2.10	2.97	1.49	0.87
24.0	32.0	8.64	4.78	1.15	8.03	4.56	1.42	7.43	4.34	1.69	7.13	4.23	1.82	6.83	4.13	1.95	6.47	4.00	2.11	3.12	1.47	0.87

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																				
EWB	EDB	50			68			86			95			104			115			122		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	21.80	15.35	0.92	21.80	15.35	1.31	20.29	14.56	1.65	19.27	14.02	1.78	18.25	13.50	1.91	17.02	12.88	2.07	8.10	4.37	0.87
60.8	71.6	25.41	16.43	1.12	23.36	15.37	1.39	21.31	14.35	1.65	20.28	13.85	1.79	19.26	13.36	1.92	18.03	12.78	2.08	8.60	4.34	0.87
64.4	77.0	26.42	16.93	1.13	24.37	15.94	1.40	22.32	14.99	1.66	21.30	14.52	1.79	20.27	14.06	1.93	19.04	13.52	2.09	9.11	4.75	0.87
67.0	80.0	27.13	16.88	1.13	25.08	15.95	1.40	23.03	15.04	1.67	22.00	14.59	1.80	22.00	14.16	1.93	19.75	13.64	2.09	9.47	4.85	0.87
71.6	86.0	28.45	16.87	1.15	26.40	16.02	1.41	24.35	15.20	1.68	23.33	14.80	1.81	22.30	14.41	1.94	21.07	13.95	2.10	10.13	5.09	0.87
75.2	89.6	29.46	16.32	1.15	27.41	15.55	1.42	25.36	14.80	1.69	24.34	14.44	1.82	23.31	14.08	1.95	22.09	13.65	2.11	10.63	5.03	0.87

Symbols:

AFR	: Airflow rate	(m ³ /min.)
BF	: Bypass factor	
EWB	: Entering wet bulb temp.	(°C) / (°F)
EDB	: Entering dry bulb temp.	(°C) / (°F)
TC	: Total capacity	(kW) / (kBtu/h)
SHC	: Sensible heat capacity	(kW) / (kBtu/h)
PI	: Power input	(kW)

Notes:

1.  shows MAX capacities and power input.
2. TC, PI and SHC must be calculated by interpolation using the figures in the above tables. (Figures out of the tables should not be used for calculation.)
3. Capacities are based on the following conditions.
Corresponding refrigerant piping length : 25 ft (7.5 m)
Level difference : 0 ft (0 m)
4. Airflow rate (AFR) and Bypass factor (BF) are tabulated above table.

C: 3D156383

FTKF24BVJU9 + RKF24BVJU9

Cooling (60 Hz, 208 V)

AFR	17.8
BF	0.25

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																				
EWB	EDB	10			20			30			35			40			46			50		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	6.54	4.60	1.00	6.54	4.60	1.37	6.54	4.60	1.90	6.54	4.60	2.26	6.42	4.54	2.61	5.98	4.31	2.26	2.39	1.10	0.78
16.0	22.0	8.03	5.14	1.29	8.03	5.14	1.82	7.49	4.86	2.26	7.13	4.68	2.44	6.77	4.49	2.62	6.34	4.28	2.26	2.54	1.09	0.78
18.0	25.0	9.29	5.77	1.54	8.57	5.40	1.91	7.85	5.04	2.27	7.49	4.87	2.45	7.13	4.70	2.63	6.70	4.50	2.26	2.69	1.19	0.78
19.4	26.7	9.54	5.74	1.55	8.82	5.39	1.91	8.10	5.05	2.28	7.74	4.88	2.46	7.38	4.72	2.64	6.95	4.53	2.26	2.80	1.22	0.78
22.0	30.0	10.01	5.70	1.56	9.28	5.38	1.93	8.56	5.07	2.29	8.20	4.92	2.47	7.84	4.78	2.66	7.41	4.60	2.26	2.99	1.28	0.78
24.0	32.0	10.36	5.50	1.58	9.64	5.21	1.94	8.92	4.93	2.30	8.56	4.79	2.49	8.20	4.66	2.67	7.77	4.50	2.26	3.14	1.26	0.78

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																				
EWB	EDB	50			68			86			95			104			115			122		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	22.31	15.71	1.00	22.31	15.71	1.37	22.31	15.71	1.90	22.31	15.71	2.26	21.89	15.49	2.61	20.42	14.71	2.26	8.16	3.74	0.78
60.8	71.6	27.40	17.55	1.29	27.40	17.55	1.82	25.57	16.59	2.26	24.34	15.95	2.44	23.11	15.33	2.62	21.64	14.60	2.26	8.67	3.71	0.78
64.4	77.0	31.71	19.70	1.54	29.25	18.43	1.91	26.79	17.20	2.27	25.56	16.61	2.45	24.33	16.03	2.63	22.85	15.34	2.26	9.18	4.06	0.78
67.0	80.0	32.56	19.59	1.55	30.10	18.38	1.91	27.64	17.22	2.28	26.40	16.66	2.46	26.40	16.10	2.64	23.70	15.45	2.26	9.54	4.15	0.78
71.6	86.0	34.14	19.45	1.56	31.68	18.36	1.93	29.22	17.31	2.29	27.99	16.79	2.47	26.76	16.29	2.66	25.29	15.70	2.26	10.21	4.35	0.78
75.2	89.6	35.36	18.78	1.58	32.90	17.78	1.94	30.44	16.82	2.30	29.21	16.35	2.49	27.98	15.89	2.67	26.50	15.35	2.26	10.72	4.30	0.78

Symbols:

AFR	: Airflow rate	(m ³ /min.)
BF	: Bypass factor	
EWB	: Entering wet bulb temp.	(°C) / (°F)
EDB	: Entering dry bulb temp.	(°C) / (°F)
TC	: Total capacity	(kW) / (kBtu/h)
SHC	: Sensible heat capacity	(kW) / (kBtu/h)
PI	: Power input	(kW)

Notes:

1.  shows MAX capacities and power input.
2. TC, PI and SHC must be calculated by interpolation using the figures in the above tables. (Figures out of the tables should not be used for calculation.)
3. Capacities are based on the following conditions.
Corresponding refrigerant piping length : 25 ft (7.5 m)
Level difference : 0 ft (0 m)
4. Airflow rate (AFR) and Bypass factor (BF) are tabulated above table.

C: 3D156384

FTXF09BVJU9 + RXF09BVJU9

Cooling (60 Hz, 208 V)

AFR	10.8
BF	0.20

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																				
EWB	EDB	10			20			30			35			40			46			48		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	3.64	2.67	0.60	3.33	2.51	0.75	3.03	2.36	0.89	2.87	2.29	0.96	2.72	2.21	1.03	2.54	2.13	1.08	1.65	1.15	0.64
16.0	22.0	3.79	2.61	0.61	3.48	2.47	0.75	3.18	2.33	0.89	3.03	2.26	0.97	2.87	2.19	1.04	2.69	2.11	1.08	1.75	1.14	0.64
18.0	25.0	3.94	2.73	0.61	3.64	2.59	0.75	3.33	2.46	0.90	3.18	2.40	0.97	3.02	2.33	1.04	2.84	2.26	1.08	1.85	1.25	0.64
19.4	26.7	4.05	2.73	0.61	3.74	2.60	0.76	3.44	2.48	0.90	3.28	2.42	0.97	3.13	2.36	1.05	2.95	2.29	1.08	1.92	1.27	0.64
22.0	30.0	4.24	2.76	0.76	3.94	2.64	0.76	3.63	2.53	0.91	3.48	2.48	0.98	3.33	2.42	1.05	3.14	2.36	1.08	2.05	1.33	0.64
24.0	32.0	4.40	2.68	0.77	4.09	2.58	0.77	3.78	2.47	0.91	3.63	2.42	0.98	3.48	2.37	1.06	3.29	2.32	1.08	2.16	1.31	0.64

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																				
EWB	EDB	50			68			86			95			104			115			118		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	12.42	9.10	0.60	11.37	8.57	0.75	10.33	8.05	0.89	9.81	7.80	0.96	9.29	7.55	1.03	8.66	7.26	1.08	5.63	3.93	0.64
60.8	71.6	12.93	8.91	0.61	11.89	8.42	0.75	10.85	7.94	0.89	10.32	7.70	0.97	9.80	7.47	1.04	9.18	7.19	1.08	5.98	3.90	0.64
64.4	77.0	13.45	9.30	0.61	12.41	8.84	0.75	11.36	8.40	0.90	10.84	8.18	0.97	10.32	7.96	1.04	9.69	7.70	1.08	6.32	4.25	0.64
67.0	80.0	13.81	9.32	0.61	12.77	8.88	0.76	11.72	8.46	0.90	11.20	8.25	0.97	11.20	8.04	1.05	10.05	7.80	1.08	6.56	4.34	0.64
71.6	86.0	14.48	9.41	0.76	13.44	9.02	0.76	12.39	8.64	0.91	11.87	8.45	0.98	11.35	8.27	1.05	10.73	8.05	1.08	7.01	4.54	0.64
75.2	89.6	15.00	9.15	0.77	13.95	8.79	0.77	12.91	8.44	0.91	12.39	8.27	0.98	11.87	8.10	1.06	11.24	7.90	1.08	7.35	4.48	0.64

Heating (60 Hz, 208 V)

AFR	10.9
-----	------

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)													
EDB		-15		-10		-5		0		6		10		18	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.44	1.10	2.93	1.15	3.41	1.21	3.90	1.27	4.90	1.46	5.32	1.51	6.17	1.61
21.1		2.26	1.13	2.75	1.19	3.23	1.25	3.72	1.30	4.70	1.50	5.12	1.55	5.97	1.65
22.0		2.23	1.14	2.72	1.20	3.20	1.25	3.69	1.31	4.67	1.51	5.10	1.56	5.94	1.65
24.0		2.17	1.15	2.66	1.21	3.14	1.27	3.63	1.32	4.61	1.52	5.03	1.57	5.88	1.67
25.0		2.14	1.16	2.63	1.22	3.12	1.27	3.60	1.33	4.57	1.53	5.00	1.58	5.85	1.67
27.0		2.08	1.17	2.57	1.23	3.06	1.28	3.54	1.34	4.51	1.54	4.93	1.59	5.64	1.61

INDOOR		OUTDOOR TEMPERATURE (°FWB)													
EDB		5		14		23		32		43		50		64	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		8.33	1.10	9.98	1.15	11.64	1.21	13.30	1.27	16.71	1.46	18.16	1.51	21.06	1.61
70.0		7.71	1.13	9.37	1.19	11.02	1.25	12.68	1.30	16.00	1.50	17.49	1.55	20.38	1.65
71.6		7.62	1.14	9.28	1.20	10.93	1.25	12.59	1.31	15.94	1.51	17.39	1.56	20.28	1.65
75.2		7.42	1.15	9.07	1.21	10.73	1.27	12.39	1.32	15.72	1.52	17.16	1.57	20.06	1.67
77.0		7.32	1.16	8.97	1.22	10.63	1.27	12.28	1.33	15.60	1.53	17.05	1.58	19.95	1.67
80.6		7.11	1.17	8.77	1.23	10.43	1.28	12.08	1.34	15.38	1.54	16.83	1.59	19.25	1.61

FTXF12BVJU9 + RXF12BVJU9

Cooling (60 Hz, 208 V)

AFR	11.7
BF	0.21

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																				
EWB	EDB	10			20			30			35			40			46			48		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.48	3.16	0.83	4.34	3.08	1.13	3.95	2.88	1.35	3.75	2.77	1.46	3.55	2.67	1.51	3.31	2.56	1.19	1.81	1.04	0.61
16.0	22.0	4.94	3.23	0.92	4.54	3.03	1.14	4.14	2.83	1.36	3.94	2.74	1.47	3.74	2.64	1.51	3.51	2.53	1.19	1.92	1.03	0.61
18.0	25.0	5.14	3.34	0.93	4.74	3.15	1.15	4.34	2.97	1.37	4.14	2.88	1.48	3.94	2.79	1.51	3.70	2.69	1.19	2.03	1.13	0.61
19.4	26.7	5.28	3.33	0.93	4.88	3.15	1.15	4.48	2.98	1.37	4.28	2.90	1.48	4.08	2.81	1.51	3.84	2.71	1.19	2.11	1.15	0.61
22.0	30.0	5.53	3.34	0.94	5.13	3.18	1.16	4.73	3.02	1.38	4.54	2.94	1.49	4.33	2.87	1.51	4.10	2.78	1.19	2.25	1.20	0.61
24.0	32.0	5.73	3.23	1.17	5.33	3.09	1.17	4.93	2.94	1.39	4.73	2.87	1.50	4.52	2.80	1.51	4.29	2.72	1.19	2.36	1.19	0.61

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																				
EWB	EDB	50			68			86			95			104			115			118		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	15.29	10.77	0.83	14.82	10.52	1.13	13.46	9.81	1.35	12.78	9.46	1.46	12.10	9.12	1.51	11.29	8.72	1.19	6.17	3.56	0.61
60.8	71.6	16.86	11.02	0.92	15.50	10.34	1.14	14.14	9.67	1.36	13.46	9.34	1.47	12.78	9.02	1.51	11.96	8.64	1.19	6.55	3.53	0.61
64.4	77.0	17.53	11.39	0.93	16.17	10.75	1.15	14.81	10.13	1.37	14.13	9.82	1.48	13.45	9.52	1.51	12.63	9.17	1.19	6.93	3.85	0.61
67.0	80.0	18.00	11.37	0.93	16.64	10.76	1.15	15.28	10.17	1.37	14.60	9.88	1.48	14.60	9.60	1.51	13.10	9.26	1.19	7.19	3.92	0.61
71.6	86.0	18.87	11.38	0.94	17.51	10.84	1.16	16.15	10.30	1.38	15.47	10.04	1.49	14.78	9.78	1.51	13.98	9.49	1.19	7.68	4.10	0.61
75.2	89.6	19.55	11.03	1.17	18.19	10.53	1.17	16.83	10.04	1.39	16.15	9.80	1.50	15.42	9.55	1.51	14.65	9.29	1.19	8.06	4.05	0.61

Heating (60 Hz, 208 V)

AFR	12.3
-----	------

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)													
EDB		-15		-10		-5		0		6		10		18	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		3.01	1.28	3.60	1.46	4.20	1.53	4.80	1.60	5.50	1.68	5.98	1.74	6.93	1.85
21.1		2.78	1.32	3.38	1.50	3.98	1.58	4.58	1.65	5.28	1.73	5.76	1.78	6.71	1.90
22.0		2.75	1.33	3.35	1.51	3.95	1.58	4.54	1.65	5.25	1.74	5.72	1.79	6.68	1.91
24.0		2.68	1.35	3.28	1.53	3.87	1.60	4.47	1.67	5.17	1.75	5.65	1.81	6.61	1.92
25.0		2.64	1.35	3.24	1.54	3.84	1.61	4.44	1.68	5.14	1.76	5.61	1.82	6.57	1.93
27.0		2.57	1.37	3.17	1.55	3.76	1.62	4.36	1.69	5.06	1.77	5.54	1.83	6.19	1.77

INDOOR		OUTDOOR TEMPERATURE (°FWB)													
EDB		5		14		23		32		43		50		64	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		10.26	1.28	12.30	1.46	14.34	1.53	16.38	1.60	18.77	1.68	20.40	1.74	23.66	1.85
70.0		9.50	1.32	11.54	1.50	13.58	1.58	15.62	1.65	18.00	1.73	19.64	1.78	22.90	1.90
71.6		9.39	1.33	11.43	1.51	13.47	1.58	15.51	1.65	17.90	1.74	19.53	1.79	22.79	1.91
75.2		9.14	1.35	11.18	1.53	13.22	1.60	15.26	1.67	17.65	1.75	19.28	1.81	22.54	1.92
77.0		9.01	1.35	11.05	1.54	13.09	1.61	15.13	1.68	17.53	1.76	19.16	1.82	22.41	1.93
80.6		8.76	1.37	10.80	1.55	12.84	1.62	14.88	1.69	17.28	1.77	18.91	1.83	21.11	1.77

FTXF18BVJU9 + RXF18BVJU9

Cooling (60 Hz, 208 V)

AFR	16.0
BF	0.18

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																				
EWB	EDB	10			20			30			35			40			46			50		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	6.39	4.50	0.92	6.39	4.50	1.31	5.95	4.27	1.65	5.65	4.11	1.78	5.35	3.96	1.91	4.99	3.78	2.07	2.37	1.28	0.87
16.0	22.0	7.45	4.81	1.12	6.85	4.51	1.39	6.25	4.21	1.65	5.94	4.06	1.79	5.64	3.91	1.92	5.28	3.74	2.08	2.52	1.27	0.87
18.0	25.0	7.74	4.96	1.13	7.14	4.67	1.40	6.54	4.39	1.66	6.24	4.26	1.79	5.94	4.12	1.93	5.58	3.96	2.09	2.67	1.39	0.87
19.4	26.7	7.95	4.95	1.13	7.35	4.67	1.40	6.75	4.41	1.67	6.45	4.28	1.80	6.15	4.15	1.93	5.79	4.00	2.09	2.77	1.42	0.87
22.0	30.0	8.34	4.94	1.15	7.74	4.70	1.41	7.14	4.46	1.68	6.84	4.34	1.81	6.54	4.22	1.94	6.18	4.09	2.10	2.97	1.49	0.87
24.0	32.0	8.64	4.78	1.15	8.03	4.56	1.42	7.43	4.34	1.69	7.13	4.23	1.82	6.83	4.13	1.95	6.47	4.00	2.11	3.12	1.47	0.87

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																				
EWB	EDB	50			68			86			95			104			115			122		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	21.80	15.35	0.92	21.80	15.35	1.31	20.29	14.56	1.65	19.27	14.02	1.78	18.25	13.50	1.91	17.02	12.88	2.07	8.10	4.37	0.87
60.8	71.6	25.41	16.43	1.12	23.36	15.37	1.39	21.31	14.35	1.65	20.28	13.85	1.79	19.26	13.36	1.92	18.03	12.78	2.08	8.60	4.34	0.87
64.4	77.0	26.42	16.93	1.13	24.37	15.94	1.40	22.32	14.99	1.66	21.30	14.52	1.79	20.27	14.06	1.93	19.04	13.52	2.09	9.11	4.75	0.87
67.0	80.0	27.13	16.88	1.13	25.08	15.95	1.40	23.03	15.04	1.67	22.00	14.59	1.80	22.00	14.16	1.93	19.75	13.64	2.09	9.47	4.85	0.87
71.6	86.0	28.45	16.87	1.15	26.40	16.02	1.41	24.35	15.20	1.68	23.33	14.80	1.81	22.30	14.41	1.94	21.07	13.95	2.10	10.13	5.09	0.87
75.2	89.6	29.46	16.32	1.15	27.41	15.55	1.42	25.36	14.80	1.69	24.34	14.44	1.82	23.31	14.08	1.95	22.09	13.65	2.11	10.63	5.03	0.87

Heating (60 Hz, 208 V)

AFR	20.3
-----	------

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)													
EDB		-15		-10		-5		0		6		10		18	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.81	2.16	5.76	2.10	6.72	2.20	7.67	2.30	8.56	2.35	9.30	2.43	10.78	2.59
21.1		4.45	2.23	5.41	2.17	6.36	2.27	7.32	2.37	8.21	2.42	8.95	2.50	10.43	2.66
22.0		4.40	2.24	5.35	2.18	6.31	2.28	7.26	2.38	8.16	2.43	8.90	2.51	10.38	2.67
24.0		4.28	2.26	5.24	2.20	6.19	2.30	7.15	2.40	8.05	2.45	8.79	2.53	10.27	2.69
25.0		4.22	2.27	5.18	2.21	6.13	2.31	7.09	2.42	7.99	2.46	8.73	2.54	10.21	2.70
27.0		4.11	2.29	5.06	2.23	6.02	2.34	6.97	2.44	7.88	2.48	8.62	2.56	10.10	2.72

INDOOR		OUTDOOR TEMPERATURE (°FWB)													
EDB		5		14		23		32		43		50		64	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		16.40	2.16	19.66	2.10	22.92	2.20	26.18	2.30	29.19	2.35	31.72	2.43	36.78	2.59
70.0		15.20	2.23	18.44	2.17	21.71	2.27	24.97	2.37	28.00	2.42	30.54	2.50	35.60	2.66
71.6		15.00	2.24	18.27	2.18	21.53	2.28	24.79	2.38	27.84	2.43	30.37	2.51	35.43	2.67
75.2		14.61	2.26	17.87	2.20	21.13	2.30	24.39	2.40	27.45	2.45	29.98	2.53	35.04	2.69
77.0		14.41	2.27	17.67	2.21	20.93	2.31	24.19	2.42	27.26	2.46	29.79	2.54	34.85	2.70
80.6		14.01	2.29	17.27	2.23	20.53	2.34	23.79	2.44	26.87	2.48	29.40	2.56	34.46	2.72

FTXF24BVJU9 + RXF24BVJU9

Cooling (60 Hz, 208 V)

AFR	17.8
BF	0.25

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CDB)																				
EWB	EDB	10			20			30			35			40			46			50		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	6.54	4.60	1.00	6.54	4.60	1.37	6.54	4.60	1.90	6.54	4.60	2.26	6.42	4.54	2.61	5.98	4.31	2.26	2.39	1.10	0.78
16.0	22.0	8.03	5.14	1.29	8.03	5.14	1.82	7.49	4.86	2.26	7.13	4.68	2.44	6.77	4.49	2.62	6.34	4.28	2.26	2.54	1.09	0.78
18.0	25.0	9.29	5.77	1.54	8.57	5.40	1.91	7.85	5.04	2.27	7.49	4.87	2.45	7.13	4.70	2.63	6.70	4.50	2.26	2.69	1.19	0.78
19.4	26.7	9.54	5.74	1.55	8.82	5.39	1.91	8.10	5.05	2.28	7.74	4.88	2.46	7.38	4.72	2.64	6.95	4.53	2.26	2.80	1.22	0.78
22.0	30.0	10.01	5.70	1.56	9.28	5.38	1.93	8.56	5.07	2.29	8.20	4.92	2.47	7.84	4.78	2.66	7.41	4.60	2.26	2.99	1.28	0.78
24.0	32.0	10.36	5.50	1.58	9.64	5.21	1.94	8.92	4.93	2.30	8.56	4.79	2.49	8.20	4.66	2.67	7.77	4.50	2.26	3.14	1.26	0.78

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE (°FDB)																				
EWB	EDB	50			68			86			95			104			115			122		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	22.31	15.71	1.00	22.31	15.71	1.37	22.31	15.71	1.90	22.31	15.71	2.26	21.89	15.49	2.61	20.42	14.71	2.26	8.16	3.74	0.78
60.8	71.6	27.40	17.55	1.29	27.40	17.55	1.82	25.57	16.59	2.26	24.34	15.95	2.44	23.11	15.33	2.62	21.64	14.60	2.26	8.67	3.71	0.78
64.4	77.0	31.71	19.70	1.54	29.25	18.43	1.91	26.79	17.20	2.27	25.56	16.61	2.45	24.33	16.03	2.63	22.85	15.34	2.26	9.18	4.06	0.78
67.0	80.0	32.56	19.59	1.55	30.10	18.38	1.91	27.64	17.22	2.28	26.40	16.66	2.46	26.40	16.10	2.64	23.70	15.45	2.26	9.54	4.15	0.78
71.6	86.0	34.14	19.45	1.56	31.68	18.36	1.93	29.22	17.31	2.29	27.99	16.79	2.47	26.76	16.29	2.66	25.29	15.70	2.26	10.21	4.35	0.78
75.2	89.6	35.36	18.78	1.58	32.90	17.78	1.94	30.44	16.82	2.30	29.21	16.35	2.49	27.98	15.89	2.67	26.50	15.35	2.26	10.72	4.30	0.78

Heating (60 Hz, 208 V)

AFR	20.3
-----	------

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE (°CWB)													
EDB		-15		-10		-5		0		6		10		18	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		5.31	2.50	6.37	2.60	7.43	2.72	8.48	2.85	9.78	3.01	10.62	3.11	11.18	2.78
21.1		4.92	2.59	5.98	2.68	7.03	2.81	8.09	2.94	9.38	3.10	10.23	3.20	10.73	2.78
22.0		4.86	2.60	5.92	2.69	6.98	2.82	8.03	2.95	9.32	3.11	10.17	3.21	10.67	2.78
24.0		4.73	2.63	5.79	2.72	6.85	2.85	7.90	2.98	9.19	3.14	10.04	3.24	10.53	2.78
25.0		4.67	2.64	5.72	2.74	6.78	2.86	7.84	2.99	9.13	3.15	9.97	3.25	10.46	2.78
27.0		4.54	2.67	5.60	2.76	6.65	2.89	7.71	3.02	9.00	3.18	9.85	3.28	10.02	2.72

INDOOR		OUTDOOR TEMPERATURE (°FWB)													
EDB		5		14		23		32		43		50		64	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		18.13	2.50	21.74	2.60	25.34	2.72	28.95	2.85	33.35	3.01	36.24	3.11	38.14	2.78
70.0		16.80	2.59	20.39	2.68	24.00	2.81	27.60	2.94	32.00	3.10	34.90	3.20	36.61	2.78
71.6		16.59	2.60	20.19	2.69	23.80	2.82	27.41	2.95	31.81	3.11	34.70	3.21	36.40	2.78
75.2		16.15	2.63	19.75	2.72	23.36	2.85	26.96	2.98	31.36	3.14	34.25	3.24	35.92	2.78
77.0		15.93	2.64	19.53	2.74	23.14	2.86	26.74	2.99	31.14	3.15	34.03	3.25	35.69	2.78
80.6		15.49	2.67	19.09	2.76	22.70	2.89	26.30	3.02	30.70	3.18	33.59	3.28	34.20	2.72