

1. Capacity Tables (Reference Data)

1.1 Heat Pump (Fahrenheit)

1.1.1 FCA

FCA18AAVJU + RZA18AAVJU

Cooling Capacity for Standard Condition (Te: 43°F)

Outdoor air temp.	Indoor air temp. °FWB																				
	57			61			64			67			70			72			75		
	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
°FDB	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
23	11.7	11.7	0.38	14.2	13.9	0.46	16.1	15.5	0.53	18.0	16.1	0.60	19.9	17.4	0.68	21.2	17.5	0.73	23.1	18.4	0.80
30	11.7	11.7	0.39	14.2	13.9	0.48	16.1	15.5	0.55	18.0	16.1	0.62	19.9	17.4	0.70	21.2	17.5	0.75	23.1	18.4	0.83
40	11.7	11.7	0.41	14.2	13.9	0.50	16.1	15.5	0.58	18.0	16.1	0.65	19.9	17.4	0.73	21.2	17.5	0.79	23.1	18.4	0.87
50	11.7	11.7	0.42	14.2	13.9	0.53	16.1	15.5	0.61	18.0	16.1	0.69	19.9	17.4	0.77	21.2	17.5	0.83	23.1	18.4	0.92
54	11.7	11.7	0.43	14.2	13.9	0.54	16.1	15.5	0.62	18.0	16.1	0.70	19.9	17.4	0.79	21.2	17.5	0.85	23.1	18.4	0.93
58	11.7	11.7	0.44	14.2	13.9	0.55	16.1	15.5	0.63	18.0	16.1	0.72	19.9	17.4	0.81	21.2	17.5	0.86	22.8	18.2	0.94
62	11.7	11.7	0.45	14.2	13.9	0.56	16.1	15.5	0.64	18.0	16.1	0.73	19.9	17.4	0.82	21.2	17.5	0.88	22.5	18.0	0.96
66	11.7	11.7	0.46	14.2	13.9	0.57	16.1	15.5	0.66	18.0	16.1	0.75	19.9	17.4	0.87	21.2	17.5	0.95	22.2	17.7	1.01
70	11.7	11.7	0.47	14.2	13.9	0.58	16.1	15.5	0.69	18.0	16.1	0.81	19.9	17.4	0.94	21.2	17.5	1.03	21.8	17.4	1.07
72	11.7	11.7	0.47	14.2	13.9	0.60	16.1	15.5	0.72	18.0	16.1	0.84	19.9	17.4	0.98	21.2	17.5	1.07	21.7	17.3	1.09
75	11.7	11.7	0.49	14.2	13.9	0.64	16.1	15.5	0.76	18.0	16.1	0.89	19.9	17.4	1.04	21.0	17.4	1.13	21.4	17.1	1.13
79	11.7	11.7	0.53	14.2	13.9	0.69	16.1	15.5	0.82	18.0	16.1	0.96	19.9	17.4	1.12	20.7	17.1	1.18	21.1	16.8	1.19
83	11.7	11.7	0.57	14.2	13.9	0.74	16.1	15.5	0.88	18.0	16.1	1.04	19.9	17.4	1.20	20.4	16.9	1.23	20.7	16.6	1.24
87	11.7	11.7	0.61	14.2	13.9	0.79	16.1	15.5	0.95	18.0	16.1	1.11	19.8	17.3	1.28	20.0	16.6	1.29	20.4	16.3	1.30
91	11.7	11.7	0.65	14.2	13.9	0.85	16.1	15.5	1.01	18.0	16.1	1.20	19.4	17.0	1.34	19.7	16.3	1.34	20.1	16.0	1.35
93	11.7	11.7	0.67	14.2	13.9	0.88	16.1	15.5	1.05	18.0	16.1	1.24	19.3	16.9	1.36	19.5	16.2	1.37	19.9	15.9	1.38
95	11.7	11.7	0.69	14.2	13.9	0.91	16.1	15.5	1.09	18.0	16.1	1.29	19.1	16.7	1.39	19.3	16.0	1.40	19.7	15.8	1.41
99	11.7	11.7	0.74	14.2	13.9	0.97	16.1	15.5	1.17	18.0	16.1	1.38	18.8	16.4	1.44	19.0	15.7	1.45	19.4	15.5	1.46
103	11.7	11.7	0.79	14.2	13.9	1.04	16.1	15.5	1.25	18.0	16.1	1.48	18.4	16.1	1.50	18.7	15.5	1.51	19.0	15.2	1.52
106	11.7	11.7	0.87	14.2	13.9	1.15	16.1	15.5	1.38	17.8	15.9	1.60	18.2	15.9	1.61	18.4	15.2	1.62	18.8	15.0	1.63
110	11.7	11.7	1.00	14.2	13.9	1.32	16.1	15.5	1.59	17.5	15.6	1.78	17.8	15.6	1.79	18.1	15.0	1.80	18.1	14.5	1.80
115	11.7	11.7	1.17	14.2	13.9	1.55	16.1	15.5	1.86	16.8	15.1	1.99	16.8	14.7	1.99	16.8	13.9	1.99	16.8	13.5	1.99
118	11.7	11.7	1.28	14.2	13.9	1.69	14.3	13.8	1.71	14.3	12.8	1.71	14.3	12.5	1.71	14.3	11.9	1.71	14.3	11.5	1.71
122	10.7	10.8	1.28	10.7	10.5	1.28	10.7	10.3	1.28	10.7	9.61	1.28	10.7	9.40	1.28	10.7	8.90	1.28	10.7	8.59	1.28

TC: Total capacity: MBH

SHC: Sensible heat capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.

2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.

3. shows rated condition.

Heating Capacity for Standard Condition (Tc: 115°F)

Outdoor air temp.	Indoor air temp. °FDB											
	61		65		68		70		72		75	
	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
°FDB °FWB	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-3.64 -4.0	19.3	2.84	19.3	2.84	19.3	2.84	19.3	2.84	19.1	2.84	17.8	2.84
-1.84 -2.2	20.1	2.88	20.1	2.88	20.1	2.88	20.0	2.88	19.1	2.88	17.8	2.73
5.5 5.0	23.4	3.06	22.2	2.99	20.9	2.92	20.0	2.75	19.1	2.53	17.8	2.23
9.5 8.5	24.0	3.02	22.2	2.93	20.9	2.71	20.0	2.51	19.1	2.31	17.8	2.04
13.0 12.0	24.0	2.97	22.2	2.78	20.9	2.48	20.0	2.30	19.1	2.13	17.8	1.89
15.0 14.0	24.0	2.94	22.2	2.65	20.9	2.37	20.0	2.20	19.1	2.03	17.8	1.81
17.0 15.5	24.0	2.92	22.2	2.55	20.9	2.29	20.0	2.12	19.1	1.97	17.8	1.76
19.0 18.0	24.0	2.77	22.2	2.41	20.9	2.17	20.0	2.01	19.1	1.87	17.8	1.67
22.0 20.0	24.0	2.65	22.2	2.31	20.9	2.08	20.0	1.94	19.1	1.80	17.8	1.61
26.0 24.0	24.0	2.43	22.2	2.13	20.9	1.92	20.0	1.79	19.1	1.67	17.8	1.51
30.0 28.0	24.0	2.25	22.2	1.97	20.9	1.79	20.0	1.67	19.1	1.57	17.8	1.42
35.0 32.0	24.0	2.09	22.2	1.84	20.9	1.67	20.0	1.57	19.1	1.48	17.8	1.34
39.0 36.0	24.0	1.95	22.2	1.73	20.9	1.58	20.0	1.48	19.1	1.40	17.8	1.28
44.0 40.0	24.0	1.83	22.2	1.63	20.9	1.49	20.0	1.41	19.1	1.33	17.8	1.22
47.0 43.0	24.0	1.75	22.2	1.56	20.9	1.43	20.0	1.36	19.1	1.28	17.8	1.18
51.0 47.0	24.0	1.65	22.2	1.48	20.9	1.37	20.0	1.30	19.1	1.23	17.8	1.14
54.0 50.0	24.0	1.59	22.2	1.43	20.9	1.32	20.0	1.26	19.1	1.20	17.8	1.11
57.0 53.0	24.0	1.53	22.2	1.38	20.9	1.28	20.0	1.22	19.1	1.16	17.8	1.09
60.0 56.0	24.0	1.48	22.2	1.34	20.9	1.25	20.0	1.19	19.1	1.13	17.8	1.06
64.0 60.0	24.0	1.42	22.2	1.29	20.9	1.20	20.0	1.15	19.1	1.10	17.8	1.03

TC: Total capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.

2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.

3. shows rated condition.

FCA24AAVJU + RZA24AAVJU**Cooling Capacity for Standard Condition (Te: 43°F)**

Outdoor air temp.	Indoor air temp. °FWB																				
	57			61			64			67			70			72			75		
	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
°FDB	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
23	15.6	14.8	0.53	18.9	17.2	0.65	21.5	18.9	0.74	24.0	19.9	0.84	26.5	21.3	0.94	28.2	21.4	1.01	30.7	22.5	1.12
30	15.6	14.8	0.54	18.9	17.2	0.67	21.5	18.9	0.77	24.0	19.9	0.87	26.5	21.3	0.97	28.2	21.4	1.05	30.7	22.5	1.16
40	15.6	14.8	0.57	18.9	17.2	0.70	21.5	18.9	0.80	24.0	19.9	0.91	26.5	21.3	1.02	28.2	21.4	1.10	30.7	22.5	1.21
50	15.6	14.8	0.59	18.9	17.2	0.73	21.5	18.9	0.84	24.0	19.9	0.96	26.5	21.3	1.08	28.2	21.4	1.16	30.7	22.5	1.28
54	15.6	14.8	0.60	18.9	17.2	0.75	21.5	18.9	0.86	24.0	19.9	0.98	26.5	21.3	1.10	28.2	21.4	1.18	30.7	22.5	1.30
58	15.6	14.8	0.62	18.9	17.2	0.76	21.5	18.9	0.88	24.0	19.9	1.00	26.5	21.3	1.12	28.2	21.4	1.20	30.5	22.3	1.31
62	15.6	14.8	0.63	18.9	17.2	0.78	21.5	18.9	0.90	24.0	19.9	1.02	26.5	21.3	1.15	28.2	21.4	1.23	30.0	21.9	1.30
66	15.6	14.8	0.64	18.9	17.2	0.80	21.5	18.9	0.92	24.0	19.9	1.04	26.5	21.3	1.17	28.2	21.4	1.26	29.6	21.6	1.29
70	15.6	14.8	0.65	18.9	17.2	0.81	21.5	18.9	0.94	24.0	19.9	1.07	26.5	21.3	1.20	28.2	21.4	1.29	29.1	21.3	1.28
72	15.6	14.8	0.66	18.9	17.2	0.82	21.5	18.9	0.95	24.0	19.9	1.08	26.5	21.3	1.21	28.2	21.4	1.30	28.9	21.1	1.28
75	15.6	14.8	0.67	18.9	17.2	0.84	21.5	18.9	0.97	24.0	19.9	1.10	26.5	21.3	1.23	28.0	21.3	1.31	28.5	20.9	1.31
79	15.6	14.8	0.69	18.9	17.2	0.86	21.5	18.9	1.00	24.0	19.9	1.18	26.5	21.3	1.37	27.6	20.9	1.44	28.1	20.5	1.45
83	15.6	14.8	0.73	18.9	17.2	0.95	21.5	18.9	1.13	24.0	19.9	1.33	26.5	21.3	1.55	27.1	20.6	1.59	27.6	20.2	1.60
87	15.6	14.8	0.81	18.9	17.2	1.06	21.5	18.9	1.27	24.0	19.9	1.49	26.4	21.2	1.72	26.7	20.2	1.73	27.2	19.9	1.74
91	15.6	14.8	0.90	18.9	17.2	1.18	21.5	18.9	1.41	24.0	19.9	1.67	25.9	20.8	1.86	26.2	19.9	1.87	26.7	19.6	1.88
93	15.6	14.8	0.95	18.9	17.2	1.24	21.5	18.9	1.49	24.0	19.9	1.76	25.7	20.7	1.93	26.0	19.7	1.94	26.5	19.4	1.95
95	15.6	14.8	1.00	18.9	17.2	1.31	21.5	18.9	1.57	24.0	19.9	1.85	25.5	20.5	2.00	25.8	19.6	2.01	26.3	19.2	2.03
99	15.6	14.8	1.10	18.9	17.2	1.45	21.5	18.9	1.74	24.0	19.9	2.05	25.0	20.1	2.15	25.3	19.2	2.16	25.8	18.9	2.17
103	15.6	14.8	1.21	18.9	17.2	1.59	21.5	18.9	1.91	24.0	19.9	2.26	24.6	19.7	2.29	24.9	18.9	2.30	25.4	18.6	2.32
106	15.6	14.8	1.30	18.9	17.2	1.71	21.5	18.9	2.05	23.7	19.7	2.38	24.2	19.5	2.40	24.6	18.6	2.41	25.1	18.3	2.43
110	15.6	14.8	1.42	18.9	17.2	1.87	21.5	18.9	2.25	23.3	19.3	2.52	23.8	19.1	2.54	24.1	18.3	2.56	24.1	17.7	2.56
115	15.6	14.8	1.58	18.9	17.2	2.09	21.5	18.9	2.52	22.5	18.6	2.69	22.5	18.1	2.69	22.5	17.0	2.69	22.5	16.4	2.69
118	15.6	14.8	1.69	18.9	17.2	2.23	19.3	16.9	2.29	19.3	16.0	2.29	19.3	15.5	2.29	19.3	14.6	2.29	19.3	14.1	2.29
122	14.7	14.0	1.69	14.7	13.4	1.69	14.7	12.9	1.69	14.7	12.2	1.69	14.7	11.8	1.69	14.7	11.1	1.69	14.7	10.7	1.69

TC: Total capacity: MBH

SHC: Sensible heat capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

Heating Capacity for Standard Condition (Tc: 115°F)

Outdoor air temp.	Indoor air temp. °FDB											
	61		65		68		70		72		75	
	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
°FDB °FWB	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-3.64 -4.0	20.8	3.00	20.8	2.95	20.8	2.91	20.8	2.88	20.8	2.85	20.8	2.81
-1.84 -2.2	21.4	2.98	21.4	2.93	21.4	2.89	21.4	2.86	21.4	2.83	21.4	2.79
5.5 5.0	23.8	2.91	23.8	2.86	23.8	2.82	23.8	2.80	23.8	2.77	23.8	2.74
9.5 8.5	25.1	2.88	25.1	2.83	25.1	2.80	25.1	2.77	25.1	2.75	24.0	2.72
13.0 12.0	26.3	2.85	26.3	2.81	26.3	2.77	26.3	2.75	25.8	2.73	24.0	2.57
15.0 14.0	26.9	2.83	26.9	2.79	26.9	2.76	26.9	2.74	25.8	2.72	24.0	2.47
17.0 15.5	27.5	2.82	27.5	2.78	27.5	2.75	27.0	2.73	25.8	2.68	24.0	2.39
19.0 18.0	28.3	2.81	28.3	2.77	28.2	2.74	27.0	2.72	25.8	2.55	24.0	2.28
22.0 20.0	29.0	2.80	29.0	2.76	28.2	2.73	27.0	2.64	25.8	2.46	24.0	2.20
26.0 24.0	30.4	2.77	30.0	2.74	28.2	2.62	27.0	2.45	25.8	2.28	24.0	2.06
30.0 28.0	31.8	2.75	30.0	2.69	28.2	2.44	27.0	2.28	25.8	2.14	24.0	1.94
35.0 32.0	32.4	2.74	30.0	2.51	28.2	2.29	27.0	2.15	25.8	2.01	24.0	1.83
39.0 36.0	32.4	2.66	30.0	2.36	28.2	2.15	27.0	2.02	25.8	1.91	24.0	1.74
44.0 40.0	32.4	2.50	30.0	2.22	28.2	2.04	27.0	1.92	25.8	1.81	24.0	1.66
47.0 43.0	32.4	2.39	30.0	2.13	28.2	1.96	27.0	1.85	25.8	1.75	24.0	1.61
51.0 47.0	32.4	2.26	30.0	2.03	28.2	1.87	27.0	1.77	25.8	1.68	24.0	1.55
54.0 50.0	32.4	2.17	30.0	1.95	28.2	1.80	27.0	1.71	25.8	1.63	24.0	1.51
57.0 53.0	32.4	2.09	30.0	1.89	28.2	1.75	27.0	1.66	25.8	1.58	24.0	1.47
60.0 56.0	32.4	2.02	30.0	1.83	28.2	1.70	27.0	1.62	25.8	1.54	24.0	1.44
64.0 60.0	32.4	1.93	30.0	1.76	28.2	1.64	27.0	1.56	25.8	1.49	24.0	1.40

TC: Total capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

FCA30AAVJU + RZA30AAVJU

Cooling Capacity for Standard Condition (Te: 43°F)

Outdoor air temp.	Indoor air temp. °FWB																				
	57			61			64			67			70			72			75		
	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
°FDB	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
23	19.5	16.7	0.67	23.7	19.4	0.82	26.8	21.1	0.94	30.0	22.3	1.07	33.2	24.1	1.20	35.3	24.2	1.29	38.4	25.0	1.42
30	19.5	16.7	0.69	23.7	19.4	0.85	26.8	21.1	0.97	30.0	22.3	1.10	33.2	24.1	1.24	35.3	24.2	1.33	38.4	25.0	1.47
40	19.5	16.7	0.72	23.7	19.4	0.89	26.8	21.1	1.02	30.0	22.3	1.16	33.2	24.1	1.30	35.3	24.2	1.39	38.4	25.0	1.54
50	19.5	16.7	0.75	23.7	19.4	0.93	26.8	21.1	1.07	30.0	22.3	1.22	33.2	24.1	1.36	35.3	24.2	1.47	38.4	25.0	1.62
54	19.5	16.7	0.77	23.7	19.4	0.95	26.8	21.1	1.09	30.0	22.3	1.24	33.2	24.1	1.39	35.3	24.2	1.50	38.4	25.0	1.65
58	19.5	16.7	0.78	23.7	19.4	0.97	26.8	21.1	1.12	30.0	22.3	1.27	33.2	24.1	1.42	35.3	24.2	1.53	38.1	24.8	1.66
62	19.5	16.7	0.80	23.7	19.4	0.99	26.8	21.1	1.14	30.0	22.3	1.30	33.2	24.1	1.45	35.3	24.2	1.56	37.5	24.4	1.65
66	19.5	16.7	0.81	23.7	19.4	1.01	26.8	21.1	1.16	30.0	22.3	1.32	33.2	24.1	1.49	35.3	24.2	1.60	36.9	24.1	1.64
70	19.5	16.7	0.83	23.7	19.4	1.03	26.8	21.1	1.19	30.0	22.3	1.35	33.2	24.1	1.52	35.3	24.2	1.63	36.4	23.7	1.63
72	19.5	16.7	0.84	23.7	19.4	1.04	26.8	21.1	1.20	30.0	22.3	1.37	33.2	24.1	1.54	35.3	24.2	1.65	36.1	23.5	1.62
75	19.5	16.7	0.85	23.7	19.4	1.06	26.8	21.1	1.22	30.0	22.3	1.39	33.2	24.1	1.57	35.1	24.1	1.70	35.7	23.3	1.71
79	19.5	16.7	0.87	23.7	19.4	1.09	26.8	21.1	1.28	30.0	22.3	1.51	33.2	24.1	1.75	34.5	23.7	1.85	35.1	22.9	1.86
83	19.5	16.7	0.92	23.7	19.4	1.19	26.8	21.1	1.43	30.0	22.3	1.68	33.2	24.1	1.95	33.9	23.3	2.00	34.5	22.5	2.01
87	19.5	16.7	1.01	23.7	19.4	1.32	26.8	21.1	1.58	30.0	22.3	1.86	33.0	23.9	2.14	33.4	22.9	2.15	34.0	22.2	2.17
91	19.5	16.7	1.11	23.7	19.4	1.45	26.8	21.1	1.74	30.0	22.3	2.05	32.4	23.5	2.29	32.8	22.5	2.30	33.4	21.8	2.32
93	19.5	16.7	1.17	23.7	19.4	1.52	26.8	21.1	1.83	30.0	22.3	2.15	32.1	23.3	2.37	32.5	22.3	2.38	33.1	21.6	2.39
95	19.5	16.7	1.23	23.7	19.4	1.61	26.8	21.1	1.93	30.0	22.3	2.28	31.8	23.1	2.47	32.2	22.2	2.48	32.9	21.4	2.50
99	19.5	16.7	1.38	23.7	19.4	1.81	26.8	21.1	2.17	30.0	22.3	2.56	31.3	22.7	2.68	31.7	21.8	2.70	32.3	21.1	2.72
103	19.5	16.7	1.53	23.7	19.4	2.02	26.8	21.1	2.42	30.0	22.3	2.87	30.7	22.3	2.90	31.1	21.4	2.91	31.7	20.7	2.94
106	19.5	16.7	1.66	23.7	19.4	2.18	26.8	21.1	2.62	29.7	22.0	3.04	30.3	22.0	3.06	30.7	21.1	3.08	31.3	20.4	3.10
110	19.5	16.7	1.83	23.7	19.4	2.41	26.8	21.1	2.91	29.1	21.6	3.26	29.7	21.6	3.28	30.1	20.7	3.30	30.1	19.6	3.30
115	19.5	16.7	2.07	23.7	19.4	2.73	26.8	21.1	3.29	28.1	20.9	3.52	28.1	20.4	3.52	28.1	19.3	3.52	28.1	18.3	3.52
118	19.5	16.7	2.22	23.7	19.4	2.93	24.7	19.5	3.13	24.7	18.4	3.13	24.7	17.9	3.13	24.7	17.0	3.13	24.7	16.1	3.13
122	19.5	16.7	2.43	19.6	16.1	2.46	19.6	15.5	2.46	19.6	14.6	2.46	19.6	14.2	2.46	19.6	13.5	2.46	19.6	12.8	2.46

TC: Total capacity: MBH

SHC: Sensible heat capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

Heating Capacity for Standard Condition (Tc: 115°F)

Outdoor air temp.	Indoor air temp. °FDB											
	61		65		68		70		72		75	
	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
°FDB °FWB	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-3.64 -4.0	28.7	4.27	28.7	4.25	28.7	4.24	28.7	4.23	28.7	4.23	28.7	4.21
-1.84 -2.2	30.1	4.27	30.1	4.25	30.1	4.24	30.1	4.23	30.1	4.22	30.1	4.21
5.5 5.0	35.5	4.25	35.5	4.23	35.5	4.22	34.0	4.22	32.5	4.06	30.2	3.61
9.5 8.5	38.1	4.24	37.8	4.23	35.5	4.22	34.0	4.02	32.5	3.73	30.2	3.33
13.0 12.0	40.0	4.24	37.8	4.22	35.5	3.99	34.0	3.71	32.5	3.45	30.2	3.09
15.0 14.0	40.8	4.23	37.8	4.22	35.5	3.82	34.0	3.56	32.5	3.31	30.2	2.96
17.0 15.5	40.8	4.23	37.8	4.09	35.5	3.70	34.0	3.45	32.5	3.21	30.2	2.88
19.0 18.0	40.8	4.23	37.8	3.88	35.5	3.51	34.0	3.28	32.5	3.06	30.2	2.75
22.0 20.0	40.8	4.23	37.8	3.73	35.5	3.38	34.0	3.16	32.5	2.95	30.2	2.65
26.0 24.0	40.8	3.91	37.8	3.46	35.5	3.14	34.0	2.94	32.5	2.75	30.2	2.48
30.0 28.0	40.8	3.64	37.8	3.22	35.5	2.93	34.0	2.75	32.5	2.58	30.2	2.33
35.0 32.0	40.8	3.39	37.8	3.01	35.5	2.75	34.0	2.58	32.5	2.42	30.2	2.20
39.0 36.0	40.8	3.18	37.8	2.83	35.5	2.59	34.0	2.44	32.5	2.29	30.2	2.09
44.0 40.0	40.8	2.99	37.8	2.67	35.5	2.45	34.0	2.31	32.5	2.18	30.2	1.99
47.0 43.0	40.8	2.87	37.8	2.57	35.5	2.36	34.0	2.23	32.5	2.10	30.2	1.92
51.0 47.0	40.8	2.72	37.8	2.44	35.5	2.24	34.0	2.12	32.5	2.01	30.2	1.84
54.0 50.0	40.8	2.62	37.8	2.35	35.5	2.17	34.0	2.05	32.5	1.94	30.2	1.79
57.0 53.0	40.8	2.52	37.8	2.27	35.5	2.10	34.0	1.99	32.5	1.88	30.2	1.74
60.0 56.0	40.8	2.43	37.8	2.20	35.5	2.03	34.0	1.93	32.5	1.83	30.2	1.69
64.0 60.0	40.8	2.33	37.8	2.11	35.5	1.95	34.0	1.86	32.5	1.76	30.2	1.63

TC: Total capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

FCA36AAVJU + RZA36AAVJU

Cooling Capacity for Standard Condition (Te: 43°F)

Outdoor air temp.	Indoor air temp. °FWB																				
	57			61			64			67			70			72			75		
	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
°FDB	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
23	23.4	20.8	0.87	28.4	24.3	1.07	32.2	26.7	1.22	36.0	28.3	1.39	39.8	30.3	1.55	42.3	30.6	1.67	46.1	31.8	1.84
30	23.4	20.8	0.89	28.4	24.3	1.10	32.2	26.7	1.26	36.0	28.3	1.43	39.8	30.3	1.61	42.3	30.6	1.72	46.1	31.8	1.90
40	23.4	20.8	0.93	28.4	24.3	1.15	32.2	26.7	1.32	36.0	28.3	1.50	39.8	30.3	1.69	42.3	30.6	1.81	46.1	31.8	2.00
50	23.4	20.8	0.98	28.4	24.3	1.21	32.2	26.7	1.39	36.0	28.3	1.58	39.8	30.3	1.77	42.3	30.6	1.90	46.1	31.8	2.10
54	23.4	20.8	0.99	28.4	24.3	1.23	32.2	26.7	1.42	36.0	28.3	1.61	39.8	30.3	1.81	42.3	30.6	1.94	46.1	31.8	2.15
58	23.4	20.8	1.01	28.4	24.3	1.26	32.2	26.7	1.45	36.0	28.3	1.65	39.8	30.3	1.85	42.3	30.6	1.98	45.7	31.5	2.15
62	23.4	20.8	1.03	28.4	24.3	1.28	32.2	26.7	1.48	36.0	28.3	1.68	39.8	30.3	1.89	42.3	30.6	2.03	45.0	31.0	2.14
66	23.4	20.8	1.06	28.4	24.3	1.31	32.2	26.7	1.51	36.0	28.3	1.72	39.8	30.3	1.93	42.3	30.6	2.07	44.3	30.5	2.13
70	23.4	20.8	1.08	28.4	24.3	1.34	32.2	26.7	1.55	36.0	28.3	1.76	39.8	30.3	1.97	42.3	30.6	2.12	43.7	30.1	2.11
72	23.4	20.8	1.09	28.4	24.3	1.35	32.2	26.7	1.56	36.0	28.3	1.78	39.8	30.3	2.00	42.3	30.6	2.14	43.3	29.8	2.11
75	23.4	20.8	1.11	28.4	24.3	1.38	32.2	26.7	1.59	36.0	28.3	1.81	39.8	30.3	2.03	42.1	30.4	2.18	42.8	29.5	2.19
79	23.4	20.8	1.13	28.4	24.3	1.41	32.2	26.7	1.65	36.0	28.3	1.95	39.8	30.3	2.26	41.4	29.9	2.39	42.1	29.0	2.40
83	23.4	20.8	1.19	28.4	24.3	1.55	32.2	26.7	1.85	36.0	28.3	2.18	39.8	30.3	2.53	40.7	29.4	2.59	41.5	28.6	2.61
87	23.4	20.8	1.32	28.4	24.3	1.72	32.2	26.7	2.06	36.0	28.3	2.42	39.5	30.1	2.79	40.0	29.0	2.80	40.8	28.1	2.82
91	23.4	20.8	1.46	28.4	24.3	1.90	32.2	26.7	2.28	36.0	28.3	2.69	38.9	29.5	3.00	39.4	28.5	3.01	40.1	27.6	3.03
93	23.4	20.8	1.53	28.4	24.3	2.00	32.2	26.7	2.39	36.0	28.3	2.82	38.5	29.3	3.10	39.0	28.2	3.12	39.8	27.4	3.14
95	23.4	20.8	1.60	28.4	24.3	2.10	32.2	26.7	2.51	36.0	28.3	2.97	38.2	29.0	3.21	38.7	28.0	3.22	39.4	27.2	3.24
99	23.4	20.8	1.76	28.4	24.3	2.30	32.2	26.7	2.76	36.0	28.3	3.26	37.5	28.5	3.42	38.0	27.5	3.43	38.8	26.7	3.46
103	23.4	20.8	1.92	28.4	24.3	2.52	32.2	26.7	3.03	36.0	28.3	3.58	36.8	28.0	3.63	37.3	27.0	3.64	38.1	26.2	3.67
106	23.4	20.8	2.05	28.4	24.3	2.69	32.2	26.7	3.24	35.6	28.0	3.76	36.3	27.6	3.78	36.8	26.6	3.80	37.4	25.8	3.82
110	23.4	20.8	2.23	28.4	24.3	2.94	32.2	26.7	3.54	34.9	27.4	3.97	35.6	27.0	3.99	35.6	25.7	3.99	35.6	24.5	3.99
115	23.4	20.8	2.48	28.4	24.3	3.27	32.1	26.6	3.92	32.1	25.2	3.92	32.1	24.4	3.92	32.1	23.2	3.92	32.1	22.1	3.92
118	23.4	20.8	2.67	27.7	23.7	3.40	27.7	23.0	3.40	27.7	21.8	3.40	27.7	21.0	3.40	27.7	20.0	3.40	27.7	19.1	3.40
122	21.8	19.5	2.78	21.8	18.7	2.78	21.8	18.1	2.78	21.8	17.2	2.78	21.8	16.6	2.78	21.8	15.8	2.78	21.8	15.0	2.78

TC: Total capacity: MBH

SHC: Sensible heat capacity: MBH

PI: Power input: kW

- Note:** 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

Heating Capacity for Standard Condition (Tc: 115°F)

Outdoor air temp.		Indoor air temp. °FDB											
		61		65		68		70		72		75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
°FDB	°FWB	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-3.64	-4.0	30.1	4.86	30.1	5.04	30.1	5.17	30.1	5.26	30.1	5.34	30.1	5.47
-1.84	-2.2	31.6	4.94	31.6	5.11	31.6	5.23	31.6	5.32	31.6	5.40	31.6	5.53
5.5	5.0	37.6	5.19	37.6	5.35	37.6	5.46	37.6	5.53	37.6	5.64	35.5	4.75
9.5	8.5	40.5	5.30	40.5	5.44	40.5	5.55	40.0	5.38	38.2	4.94	35.5	4.32
13.0	12.0	43.4	5.40	43.4	5.54	41.8	5.33	40.0	4.91	38.2	4.51	35.5	3.97
15.0	14.0	44.8	5.45	44.5	5.58	41.8	5.07	40.0	4.67	38.2	4.30	35.5	3.80
17.0	15.5	45.7	5.49	44.5	5.49	41.8	4.88	40.0	4.51	38.2	4.15	35.5	3.67
19.0	18.0	47.1	5.55	44.5	5.17	41.8	4.60	40.0	4.26	38.2	3.93	35.5	3.49
22.0	20.0	48.0	5.59	44.5	4.93	41.8	4.40	40.0	4.08	38.2	3.77	35.5	3.36
26.0	24.0	48.0	5.21	44.5	4.52	41.8	4.05	40.0	3.76	38.2	3.49	35.5	3.13
30.0	28.0	48.0	4.79	44.5	4.17	41.8	3.75	40.0	3.49	38.2	3.25	35.5	2.93
35.0	32.0	48.0	4.42	44.5	3.87	41.8	3.49	40.0	3.27	38.2	3.05	35.5	2.77
39.0	36.0	48.0	4.11	44.5	3.61	41.8	3.28	40.0	3.07	38.2	2.89	35.5	2.63
44.0	40.0	48.0	3.84	44.5	3.39	41.8	3.09	40.0	2.91	38.2	2.74	35.5	2.52
47.0	43.0	48.0	3.66	44.5	3.24	41.8	2.97	40.0	2.80	38.2	2.65	35.5	2.44
51.0	47.0	48.0	3.45	44.5	3.07	41.8	2.82	40.0	2.67	38.2	2.53	35.5	2.35
54.0	50.0	48.0	3.31	44.5	2.96	41.8	2.73	40.0	2.59	38.2	2.46	35.5	2.29
57.0	53.0	48.0	3.18	44.5	2.86	41.8	2.64	40.0	2.51	38.2	2.40	35.5	2.24
60.0	56.0	48.0	3.07	44.5	2.76	41.8	2.57	40.0	2.45	38.2	2.34	35.5	2.20
64.0	60.0	48.0	2.93	44.5	2.65	41.8	2.48	40.0	2.37	38.2	2.27	35.5	2.14

TC: Total capacity: MBH

PI: Power input: kW

- Note:** 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

FCA42AAVJU + RZA42AAVJU

Cooling Capacity for Standard Condition (Te: 43°F)

Outdoor air temp.	Indoor air temp. °FWB																							
	57			61			64			67			70			72			75					
	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI			
°FDB	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW			
23	27.3	22.7	1.18	33.2	26.4	1.44	37.6	28.9	1.66	42.0	30.6	1.88	46.4	33.0	2.11	49.4	33.0	2.26	53.8	34.0	2.50			
30	27.3	22.7	1.21	33.2	26.4	1.49	37.6	28.9	1.71	42.0	30.6	1.94	46.4	33.0	2.18	49.4	33.0	2.34	53.8	34.0	2.58			
40	27.3	22.7	1.26	33.2	26.4	1.56	37.6	28.9	1.79	42.0	30.6	2.03	46.4	33.0	2.28	49.4	33.0	2.45	53.8	34.0	2.71			
50	27.3	22.7	1.32	33.2	26.4	1.64	37.6	28.9	1.88	42.0	30.6	2.14	46.4	33.0	2.40	49.4	33.0	2.58	53.8	34.0	2.85			
54	27.3	22.7	1.35	33.2	26.4	1.67	37.6	28.9	1.92	42.0	30.6	2.18	46.4	33.0	2.45	49.4	33.0	2.63	53.8	34.0	2.91			
58	27.3	22.7	1.37	33.2	26.4	1.70	37.6	28.9	1.96	42.0	30.6	2.23	46.4	33.0	2.51	49.4	33.0	2.69	53.3	33.7	2.92			
62	27.3	22.7	1.40	33.2	26.4	1.74	37.6	28.9	2.00	42.0	30.6	2.28	46.4	33.0	2.56	49.4	33.0	2.75	52.5	33.2	2.98			
66	27.3	22.7	1.43	33.2	26.4	1.78	37.6	28.9	2.05	42.0	30.6	2.33	46.4	33.0	2.70	49.4	33.0	2.97	51.7	32.7	3.15			
70	27.3	22.7	1.46	33.2	26.4	1.82	37.6	28.9	2.15	42.0	30.6	2.52	46.4	33.0	2.93	49.4	33.0	3.21	50.9	32.2	3.31			
72	27.3	22.7	1.48	33.2	26.4	1.88	37.6	28.9	2.23	42.0	30.6	2.62	46.4	33.0	3.04	49.4	33.0	3.34	50.5	31.9	3.40			
75	27.3	22.7	1.53	33.2	26.4	1.98	37.6	28.9	2.36	42.0	30.6	2.78	46.4	33.0	3.22	49.1	32.8	3.50	49.9	31.5	3.52			
79	27.3	22.7	1.64	33.2	26.4	2.13	37.6	28.9	2.54	42.0	30.6	2.99	46.4	33.0	3.48	48.3	32.3	3.67	49.2	31.1	3.69			
83	27.3	22.7	1.76	33.2	26.4	2.29	37.6	28.9	2.74	42.0	30.6	3.22	46.4	33.0	3.75	47.5	31.8	3.84	48.4	30.6	3.86			
87	27.3	22.7	1.89	33.2	26.4	2.46	37.6	28.9	2.94	42.0	30.6	3.46	46.1	32.8	3.99	46.7	31.3	4.01	47.6	30.1	4.03			
91	27.3	22.7	2.02	33.2	26.4	2.64	37.6	28.9	3.16	42.0	30.6	3.72	45.3	32.2	4.16	45.9	30.7	4.17	46.8	29.6	4.20			
93	27.3	22.7	2.09	33.2	26.4	2.73	37.6	28.9	3.27	42.0	30.6	3.86	45.0	31.9	4.24	45.5	30.5	4.26	46.4	29.3	4.29			
95	27.3	22.7	2.16	33.2	26.4	2.83	37.6	28.9	3.39	42.0	30.6	4.00	44.6	31.6	4.32	45.1	30.2	4.34	46.0	29.1	4.37			
99	27.3	22.7	2.31	33.2	26.4	3.03	37.6	28.9	3.63	42.0	30.6	4.29	43.8	31.1	4.49	44.3	29.7	4.52	45.2	28.6	4.55			
103	27.3	22.7	2.47	33.2	26.4	3.24	37.6	28.9	3.90	42.0	30.6	4.61	43.0	30.5	4.67	43.6	29.2	4.69	43.6	27.5	4.69			
106	27.3	22.7	2.59	33.2	26.4	3.41	37.6	28.9	4.10	41.5	30.3	4.76	42.2	29.9	4.78	42.2	28.2	4.78	42.2	26.6	4.78			
110	27.3	22.7	2.77	33.2	26.4	3.65	37.6	28.9	4.40	39.4	28.8	4.73	39.4	28.0	4.73	39.4	26.4	4.73	39.4	24.9	4.73			
115	27.3	22.7	3.07	32.2	25.6	3.88	32.2	24.8	3.88	32.2	23.5	3.88	32.2	22.8	3.88	32.2	21.5	3.88	32.2	20.3	3.88			
118	27.3	22.7	3.30	27.8	22.2	3.40	27.8	21.4	3.40	27.8	20.3	3.40	27.8	19.8	3.40	27.8	18.6	3.40	27.8	17.6	3.40			
122	22.0	18.3	2.72	22.0	17.5	2.72	22.0	16.9	2.72	22.0	16.0	2.72	22.0	15.6	2.72	22.0	14.7	2.72	22.0	13.9	2.72			

TC: Total capacity: MBH

SHC: Sensible heat capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

Heating Capacity for Standard Condition (Tc: 115°F)

Outdoor air temp.		Indoor air temp. °FDB											
		61		65		68		70		72		75	
		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
°FDB	°FWB	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-3.64	-4.0	30.1	5.32	30.1	5.37	30.1	5.41	30.1	5.43	30.1	5.46	30.1	5.49
-1.84	-2.2	31.6	5.35	31.6	5.39	31.6	5.43	31.6	5.45	31.6	5.48	31.6	5.51
5.5	5.0	37.8	5.42	37.8	5.47	37.8	5.50	37.8	5.52	37.8	5.54	37.8	5.57
9.5	8.5	40.8	5.46	40.8	5.50	40.8	5.53	40.8	5.55	40.8	5.57	40.8	5.60
13.0	12.0	43.8	5.49	43.8	5.53	43.8	5.55	43.8	5.57	43.8	5.59	41.8	5.52
15.0	14.0	45.4	5.50	45.4	5.54	45.4	5.57	45.4	5.59	44.9	5.61	41.8	5.26
17.0	15.5	46.3	5.52	46.3	5.55	46.3	5.58	46.3	5.60	44.9	5.62	41.8	5.07
19.0	18.0	47.8	5.53	47.8	5.57	47.8	5.60	47.0	5.61	44.9	5.47	41.8	4.78
22.0	20.0	49.0	5.55	49.0	5.58	49.0	5.61	47.0	5.63	44.9	5.23	41.8	4.56
26.0	24.0	51.3	5.57	51.3	5.61	49.1	5.63	47.0	5.20	44.9	4.78	41.8	4.16
30.0	28.0	53.6	5.60	52.2	5.63	49.1	5.19	47.0	4.78	44.9	4.38	41.8	3.80
35.0	32.0	56.0	5.62	52.2	5.37	49.1	4.78	47.0	4.40	44.9	4.02	41.8	3.47
39.0	36.0	56.4	5.64	52.2	4.97	49.1	4.42	47.0	4.06	44.9	3.70	41.8	3.17
44.0	40.0	56.4	5.32	52.2	4.61	49.1	4.08	47.0	3.74	44.9	3.40	41.8	2.91
47.0	43.0	56.4	5.05	52.2	4.36	49.1	3.85	47.0	3.52	44.9	3.20	41.8	2.72
51.0	47.0	56.4	4.70	52.2	4.05	49.1	3.57	47.0	3.26	44.9	2.95	41.8	2.49
54.0	50.0	56.4	4.47	52.2	3.84	49.1	3.37	47.0	3.07	44.9	2.77	41.8	2.33
57.0	53.0	56.4	4.24	52.2	3.64	49.1	3.19	47.0	2.89	44.9	2.61	41.8	2.18
60.0	56.0	56.4	4.04	52.2	3.45	49.1	3.01	47.0	2.73	44.9	2.45	41.8	2.04
64.0	60.0	56.4	3.77	52.2	3.21	49.1	2.80	47.0	2.52	44.9	2.25	41.8	1.86

TC: Total capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

FCA48AAVJU + RZA48AAVJU

Cooling Capacity for Standard Condition (Te: 43°F)

Outdoor air temp.	Indoor air temp. °FWB																				
	57			61			64			67			70			72			75		
	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
°FDB	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
23	31.1	25.9	1.60	37.9	30.2	1.97	42.9	33.1	2.26	48.0	35.0	2.56	53.1	37.7	2.87	56.4	37.8	3.09	61.5	38.8	3.41
30	31.1	25.9	1.65	37.9	30.2	2.03	42.9	33.1	2.33	48.0	35.0	2.65	53.1	37.7	2.97	56.4	37.8	3.19	61.5	38.8	3.52
40	31.1	25.9	1.72	37.9	30.2	2.13	42.9	33.1	2.44	48.0	35.0	2.77	53.1	37.7	3.11	56.4	37.8	3.35	61.5	38.8	3.69
50	31.1	25.9	1.80	37.9	30.2	2.23	42.9	33.1	2.57	48.0	35.0	2.92	53.1	37.7	3.28	56.4	37.8	3.52	61.5	38.8	3.88
54	31.1	25.9	1.84	37.9	30.2	2.28	42.9	33.1	2.62	48.0	35.0	2.98	53.1	37.7	3.34	56.4	37.8	3.59	61.5	38.8	3.97
58	31.1	25.9	1.87	37.9	30.2	2.32	42.9	33.1	2.68	48.0	35.0	3.04	53.1	37.7	3.42	56.4	37.8	3.67	60.9	38.5	3.98
62	31.1	25.9	1.91	37.9	30.2	2.37	42.9	33.1	2.73	48.0	35.0	3.11	53.1	37.7	3.49	56.4	37.8	3.75	60.0	37.9	4.06
66	31.1	25.9	1.95	37.9	30.2	2.42	42.9	33.1	2.79	48.0	35.0	3.18	53.1	37.7	3.69	56.4	37.8	4.04	59.1	37.3	4.29
70	31.1	25.9	1.99	37.9	30.2	2.48	42.9	33.1	2.93	48.0	35.0	3.44	53.1	37.7	3.99	56.4	37.8	4.38	58.2	36.8	4.52
72	31.1	25.9	2.01	37.9	30.2	2.56	42.9	33.1	3.04	48.0	35.0	3.57	53.1	37.7	4.15	56.4	37.8	4.56	57.8	36.5	4.63
75	31.1	25.9	2.09	37.9	30.2	2.70	42.9	33.1	3.22	48.0	35.0	3.79	53.1	37.7	4.40	56.1	37.5	4.78	57.1	36.1	4.81
79	31.1	25.9	2.24	37.9	30.2	2.91	42.9	33.1	3.47	48.0	35.0	4.08	53.1	37.7	4.74	55.2	36.9	5.00	56.2	35.5	5.04
83	31.1	25.9	2.40	37.9	30.2	3.12	42.9	33.1	3.73	48.0	35.0	4.39	53.1	37.7	5.11	54.3	36.3	5.23	55.3	34.9	5.27
87	31.1	25.9	2.57	37.9	30.2	3.35	42.9	33.1	4.01	48.0	35.0	4.72	52.7	37.4	5.44	53.4	35.7	5.46	54.4	34.3	5.50
91	31.1	25.9	2.75	37.9	30.2	3.60	42.9	33.1	4.30	48.0	35.0	5.08	51.8	36.8	5.67	52.5	35.1	5.69	53.5	33.8	5.73
93	31.1	25.9	2.85	37.9	30.2	3.72	42.9	33.1	4.46	48.0	35.0	5.26	51.4	36.5	5.78	52.0	34.8	5.81	53.0	33.5	5.85
95	31.1	25.9	2.95	37.9	30.2	3.86	42.9	33.1	4.62	48.0	35.0	5.45	50.9	36.2	5.90	51.6	34.5	5.92	52.6	33.2	5.97
99	31.1	25.9	3.15	37.9	30.2	4.13	42.9	33.1	4.95	48.0	35.0	5.86	50.0	35.5	6.13	50.7	33.9	6.16	51.1	32.2	6.17
103	31.1	25.9	3.37	37.9	30.2	4.42	42.9	33.1	5.31	48.0	35.0	6.29	48.9	34.7	6.35	48.9	32.7	6.35	48.9	30.9	6.35
106	31.1	25.9	3.54	37.9	30.2	4.65	42.9	33.1	5.60	47.3	34.5	6.47	47.3	33.6	6.47	47.3	31.6	6.47	47.3	29.8	6.47
110	31.1	25.9	3.78	37.9	30.2	4.98	40.9	31.5	5.58	40.9	29.9	5.58	40.9	29.1	5.58	40.9	27.4	5.58	40.9	25.9	5.58
115	31.1	25.9	4.10	33.1	26.3	4.46	33.1	25.4	4.46	33.1	24.1	4.46	33.1	23.5	4.46	33.1	22.1	4.46	33.1	20.9	4.46
118	28.3	23.6	3.79	28.3	22.6	3.79	28.3	21.8	3.79	28.3	20.6	3.79	28.3	20.1	3.79	28.3	19.0	3.79	28.3	17.9	3.79
122	22.0	18.3	2.91	22.0	17.5	2.91	22.0	16.9	2.91	22.0	16.0	2.91	22.0	15.6	2.91	22.0	14.7	2.91	22.0	13.9	2.91

TC: Total capacity: MBH

SHC: Sensible heat capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

Heating Capacity for Standard Condition (Tc: 115°F)

Outdoor air temp.	Indoor air temp. °FDB											
	61		65		68		70		72		75	
	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
°FDB °FWB	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-3.64 -4.0	30.1	5.27	30.1	5.34	30.1	5.39	30.1	5.42	30.1	5.46	30.1	5.51
-1.84 -2.2	31.6	5.30	31.6	5.37	31.6	5.42	31.6	5.45	31.6	5.48	31.6	5.53
5.5 5.0	37.8	5.41	37.8	5.47	37.8	5.51	37.8	5.54	37.8	5.57	37.8	5.61
9.5 8.5	40.8	5.45	40.8	5.51	40.8	5.55	40.8	5.58	40.8	5.61	40.8	5.65
13.0 12.0	43.8	5.49	43.8	5.55	43.8	5.59	43.8	5.61	43.8	5.64	43.8	5.68
15.0 14.0	45.5	5.51	45.5	5.57	45.5	5.61	45.5	5.63	45.5	5.66	45.5	5.70
17.0 15.5	46.8	5.53	46.8	5.58	46.8	5.62	46.8	5.65	46.8	5.67	46.8	5.71
19.0 18.0	48.9	5.55	48.9	5.60	48.9	5.64	48.9	5.67	48.9	5.69	48.0	5.73
22.0 20.0	50.6	5.57	50.6	5.62	50.6	5.66	50.6	5.68	50.6	5.71	48.0	5.74
26.0 24.0	54.1	5.61	54.1	5.66	54.1	5.69	54.0	5.71	51.6	5.74	48.0	5.18
30.0 28.0	57.5	5.64	57.5	5.69	56.4	5.72	54.0	5.74	51.6	5.57	48.0	4.60
35.0 32.0	60.9	5.67	60.0	5.72	56.4	5.75	54.0	5.60	51.6	4.95	48.0	4.13
39.0 36.0	64.3	5.70	60.0	5.74	56.4	5.62	54.0	5.00	51.6	4.45	48.0	3.75
44.0 40.0	64.8	5.73	60.0	5.77	56.4	5.05	54.0	4.51	51.6	4.04	48.0	3.45
47.0 43.0	64.8	5.75	60.0	5.52	56.4	4.68	54.0	4.20	51.6	3.78	48.0	3.26
51.0 47.0	64.8	5.77	60.0	4.99	56.4	4.27	54.0	3.85	51.6	3.49	48.0	3.05
54.0 50.0	64.8	5.71	60.0	4.65	56.4	4.00	54.0	3.63	51.6	3.31	48.0	2.93
57.0 53.0	64.8	5.31	60.0	4.36	56.4	3.77	54.0	3.44	51.6	3.15	48.0	2.82
60.0 56.0	64.8	4.96	60.0	4.09	56.4	3.56	54.0	3.27	51.6	3.02	48.0	2.74
64.0 60.0	64.8	4.56	60.0	3.79	56.4	3.33	54.0	3.08	51.6	2.88	48.0	2.65

TC: Total capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.