

1.1.2 FAA

FAA18AAVJU + RZA18AAVJU

Cooling Capacity for Standard Condition (Te: 43°F)

Outdoor air temp.	Indoor air temp. °FWB																				
	57			61			64			67			70			72			75		
	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
°FDB	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
23	11.7	10.2	0.41	14.2	11.7	0.51	16.1	12.7	0.58	18.0	13.7	0.66	19.9	14.3	0.74	21.2	14.9	0.80	23.1	14.5	0.88
30	11.7	10.2	0.43	14.2	11.7	0.52	16.1	12.7	0.60	18.0	13.7	0.68	19.9	14.3	0.77	21.2	14.9	0.82	23.1	14.5	0.91
40	11.7	10.2	0.44	14.2	11.7	0.55	16.1	12.7	0.63	18.0	13.7	0.72	19.9	14.3	0.80	21.2	14.9	0.86	23.1	14.5	0.95
50	11.7	10.2	0.46	14.2	11.7	0.57	16.1	12.7	0.66	18.0	13.7	0.75	19.9	14.3	0.84	21.2	14.9	0.91	23.1	14.5	1.00
54	11.7	10.2	0.47	14.2	11.7	0.59	16.1	12.7	0.68	18.0	13.7	0.77	19.9	14.3	0.86	21.2	14.9	0.93	23.1	14.5	1.02
58	11.7	10.2	0.48	14.2	11.7	0.60	16.1	12.7	0.69	18.0	13.7	0.78	19.9	14.3	0.88	21.2	14.9	0.95	22.8	14.4	1.03
62	11.7	10.2	0.49	14.2	11.7	0.61	16.1	12.7	0.70	18.0	13.7	0.80	19.9	14.3	0.90	21.2	14.9	0.97	22.5	14.2	1.02
66	11.7	10.2	0.50	14.2	11.7	0.62	16.1	12.7	0.72	18.0	13.7	0.82	19.9	14.3	0.92	21.2	14.9	0.99	22.2	14.0	1.01
70	11.7	10.2	0.51	14.2	11.7	0.64	16.1	12.7	0.74	18.0	13.7	0.84	19.9	14.3	0.94	21.2	14.9	1.01	21.8	13.7	1.01
72	11.7	10.2	0.52	14.2	11.7	0.65	16.1	12.7	0.74	18.0	13.7	0.85	19.9	14.3	0.95	21.2	14.9	1.03	21.7	13.6	1.04
75	11.7	10.2	0.53	14.2	11.7	0.66	16.1	12.7	0.76	18.0	13.7	0.87	19.9	14.3	1.01	21.0	14.8	1.10	21.4	13.5	1.11
79	11.7	10.2	0.54	14.2	11.7	0.69	16.1	12.7	0.82	18.0	13.7	0.97	19.9	14.3	1.13	20.7	14.6	1.19	21.1	13.3	1.20
83	11.7	10.2	0.59	14.2	11.7	0.76	16.1	12.7	0.91	18.0	13.7	1.07	19.9	14.3	1.24	20.4	14.3	1.27	20.7	13.0	1.28
87	11.7	10.2	0.64	14.2	11.7	0.84	16.1	12.7	1.00	18.0	13.7	1.18	19.8	14.2	1.36	20.0	14.1	1.36	20.4	12.8	1.37
91	11.7	10.2	0.70	14.2	11.7	0.92	16.1	12.7	1.10	18.0	13.7	1.29	19.4	13.9	1.44	19.7	13.9	1.45	20.1	12.6	1.46
93	11.7	10.2	0.73	14.2	11.7	0.96	16.1	12.7	1.15	18.0	13.7	1.35	19.3	13.8	1.49	19.5	13.7	1.49	19.9	12.5	1.50
95	11.7	10.2	0.76	14.2	11.7	1.00	16.1	12.7	1.20	18.0	13.7	1.41	19.1	13.7	1.53	19.3	13.6	1.54	19.7	12.4	1.55
99	11.7	10.2	0.83	14.2	11.7	1.09	16.1	12.7	1.31	18.0	13.7	1.55	18.8	13.5	1.62	19.0	13.4	1.62	19.4	12.2	1.64
103	11.7	10.2	0.90	14.2	11.7	1.19	16.1	12.7	1.42	18.0	13.7	1.68	18.4	13.2	1.71	18.7	13.2	1.71	19.0	12.0	1.73
106	11.7	10.2	0.96	14.2	11.7	1.26	16.1	12.7	1.52	17.8	13.5	1.76	18.2	13.0	1.77	18.4	13.0	1.78	18.8	11.8	1.79
110	11.7	10.2	1.09	14.2	11.7	1.44	16.1	12.7	1.74	17.5	13.3	1.94	17.8	12.8	1.96	18.1	12.7	1.97	18.1	11.4	1.97
115	11.7	10.2	1.28	14.2	11.7	1.69	16.1	12.7	2.04	16.8	12.8	2.18	16.8	12.1	2.18	16.8	11.9	2.18	16.8	10.6	2.18
118	11.7	10.2	1.40	14.2	11.7	1.85	14.3	11.3	1.88	14.3	10.9	1.88	14.3	10.3	1.88	14.3	10.1	1.88	14.3	9.03	1.88
122	10.7	9.36	1.40	10.7	8.86	1.40	10.7	8.48	1.40	10.7	8.18	1.40	10.7	7.71	1.40	10.7	7.57	1.40	10.7	6.77	1.40

TC: Total capacity: MBH

SHC: Sensible heat capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

Heating Capacity for Standard Condition (Tc: 115°F)

Outdoor air temp.	Indoor air temp. °FDB											
	61		65		68		70		72		75	
	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
°FDB °FWB	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-3.64 -4.0	17.3	3.09	17.3	3.16	17.3	3.22	17.3	3.25	17.3	3.29	17.3	3.34
-1.84 -2.2	18.1	3.12	18.1	3.19	18.1	3.24	18.1	3.28	18.1	3.31	17.8	3.36
5.5 5.0	21.1	3.23	21.1	3.29	20.9	3.34	20.0	3.37	19.1	3.28	17.8	2.99
9.5 8.5	22.5	3.27	22.2	3.33	20.9	3.37	20.0	3.26	19.1	3.07	17.8	2.80
13.0 12.0	24.0	3.31	22.2	3.37	20.9	3.24	20.0	3.06	19.1	2.88	17.8	2.63
15.0 14.0	24.0	3.33	22.2	3.39	20.9	3.13	20.0	2.96	19.1	2.79	17.8	2.54
17.0 15.5	24.0	3.35	22.2	3.31	20.9	3.05	20.0	2.88	19.1	2.72	17.8	2.48
19.0 18.0	24.0	3.37	22.2	3.17	20.9	2.93	20.0	2.77	19.1	2.61	17.8	2.38
22.0 20.0	24.0	3.39	22.2	3.07	20.9	2.83	20.0	2.68	19.1	2.53	17.8	2.31
26.0 24.0	24.0	3.19	22.2	2.89	20.9	2.67	20.0	2.52	19.1	2.39	17.8	2.18
30.0 28.0	24.0	3.01	22.2	2.73	20.9	2.52	20.0	2.39	19.1	2.26	17.8	2.06
35.0 32.0	24.0	2.85	22.2	2.58	20.9	2.39	20.0	2.26	19.1	2.14	17.8	1.96
39.0 36.0	24.0	2.70	22.2	2.45	20.9	2.27	20.0	2.15	19.1	2.03	17.8	1.87
44.0 40.0	24.0	2.57	22.2	2.33	20.9	2.16	20.0	2.05	19.1	1.94	17.8	1.78
47.0 43.0	24.0	2.48	22.2	2.25	20.9	2.09	20.0	1.98	19.1	1.87	17.8	1.72
51.0 47.0	24.0	2.36	22.2	2.15	20.9	2.00	20.0	1.89	19.1	1.80	17.8	1.65
54.0 50.0	24.0	2.29	22.2	2.08	20.9	1.93	20.0	1.84	19.1	1.74	17.8	1.60
57.0 53.0	24.0	2.21	22.2	2.02	20.9	1.87	20.0	1.78	19.1	1.69	17.8	1.55
60.0 56.0	24.0	2.15	22.2	1.96	20.9	1.82	20.0	1.73	19.1	1.64	17.8	1.51
64.0 60.0	24.0	2.06	22.2	1.88	20.9	1.75	20.0	1.66	19.1	1.58	17.8	1.45

TC: Total capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

FAA24AAVJU + RZA24AAVJU

Cooling Capacity for Standard Condition (Te: 43°F)

Outdoor air temp.	Indoor air temp. °FWB																				
	57			61			64			67			70			72			75		
	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
°FDB	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW	MBH	MBH	kW
23	15.6	13.5	0.60	18.9	15.3	0.73	21.5	16.5	0.84	24.0	18.0	0.96	26.5	18.5	1.07	28.2	19.0	1.15	30.7	18.8	1.27
30	15.6	13.5	0.62	18.9	15.3	0.76	21.5	16.5	0.87	24.0	18.0	0.99	26.5	18.5	1.11	28.2	19.0	1.19	30.7	18.8	1.31
40	15.6	13.5	0.64	18.9	15.3	0.79	21.5	16.5	0.91	24.0	18.0	1.03	26.5	18.5	1.16	28.2	19.0	1.25	30.7	18.8	1.38
50	15.6	13.5	0.67	18.9	15.3	0.83	21.5	16.5	0.96	24.0	18.0	1.09	26.5	18.5	1.22	28.2	19.0	1.31	30.7	18.8	1.45
54	15.6	13.5	0.69	18.9	15.3	0.85	21.5	16.5	0.98	24.0	18.0	1.11	26.5	18.5	1.25	28.2	19.0	1.34	30.7	18.8	1.48
58	15.6	13.5	0.70	18.9	15.3	0.87	21.5	16.5	1.00	24.0	18.0	1.13	26.5	18.5	1.27	28.2	19.0	1.37	30.5	18.6	1.48
62	15.6	13.5	0.71	18.9	15.3	0.88	21.5	16.5	1.02	24.0	18.0	1.16	26.5	18.5	1.30	28.2	19.0	1.40	30.0	18.4	1.48
66	15.6	13.5	0.73	18.9	15.3	0.90	21.5	16.5	1.04	24.0	18.0	1.18	26.5	18.5	1.33	28.2	19.0	1.43	29.6	18.1	1.47
70	15.6	13.5	0.74	18.9	15.3	0.92	21.5	16.5	1.07	24.0	18.0	1.21	26.5	18.5	1.36	28.2	19.0	1.46	29.1	17.8	1.46
72	15.6	13.5	0.75	18.9	15.3	0.93	21.5	16.5	1.08	24.0	18.0	1.23	26.5	18.5	1.38	28.2	19.0	1.48	28.9	17.7	1.45
75	15.6	13.5	0.76	18.9	15.3	0.95	21.5	16.5	1.10	24.0	18.0	1.25	26.5	18.5	1.40	28.0	18.9	1.49	28.5	17.5	1.49
79	15.6	13.5	0.78	18.9	15.3	0.97	21.5	16.5	1.14	24.0	18.0	1.34	26.5	18.5	1.55	27.6	18.6	1.64	28.1	17.2	1.65
83	15.6	13.5	0.83	18.9	15.3	1.08	21.5	16.5	1.28	24.0	18.0	1.51	26.5	18.5	1.76	27.1	18.3	1.80	27.6	16.9	1.81
87	15.6	13.5	0.92	18.9	15.3	1.20	21.5	16.5	1.44	24.0	18.0	1.70	26.4	18.4	1.95	26.7	18.0	1.96	27.2	16.6	1.97
91	15.6	13.5	1.03	18.9	15.3	1.34	21.5	16.5	1.61	24.0	18.0	1.89	25.9	18.1	2.11	26.2	17.7	2.12	26.7	16.4	2.14
93	15.6	13.5	1.08	18.9	15.3	1.41	21.5	16.5	1.69	24.0	18.0	2.00	25.7	17.9	2.19	26.0	17.5	2.20	26.5	16.2	2.22
95	15.6	13.5	1.14	18.9	15.3	1.49	21.5	16.5	1.78	24.0	18.0	2.10	25.5	17.8	2.28	25.8	17.4	2.29	26.3	16.1	2.30
99	15.6	13.5	1.25	18.9	15.3	1.64	21.5	16.5	1.97	24.0	18.0	2.33	25.0	17.5	2.44	25.3	17.1	2.45	25.8	15.8	2.47
103	15.6	13.5	1.38	18.9	15.3	1.81	21.5	16.5	2.17	24.0	18.0	2.57	24.6	17.1	2.60	24.9	16.8	2.61	25.4	15.5	2.63
106	15.6	13.5	1.47	18.9	15.3	1.94	21.5	16.5	2.33	23.7	17.8	2.70	24.2	16.9	2.72	24.6	16.6	2.74	25.1	15.3	2.76
110	15.6	13.5	1.61	18.9	15.3	2.12	21.5	16.5	2.56	23.3	17.5	2.87	23.8	16.6	2.89	24.1	16.3	2.90	24.1	14.8	2.90
115	15.6	13.5	1.80	18.9	15.3	2.38	21.5	16.5	2.86	22.5	16.8	3.06	22.5	15.7	3.06	22.5	15.1	3.06	22.5	13.7	3.06
118	15.6	13.5	1.92	18.9	15.3	2.54	19.3	14.8	2.60	19.3	14.4	2.60	19.3	13.4	2.60	19.3	13.0	2.60	19.3	11.8	2.60
122	14.7	12.7	1.92	14.7	11.9	1.92	14.7	11.3	1.92	14.7	11.0	1.92	14.7	10.2	1.92	14.7	9.90	1.92	14.7	8.98	1.92

TC: Total capacity: MBH

SHC: Sensible heat capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.

Heating Capacity for Standard Condition (Tc: 115°F)

Outdoor air temp.	Indoor air temp. °FDB											
	61		65		68		70		72		75	
	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
°FDB °FWB	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW	MBH	kW
-3.64 -4.0	18.4	3.23	18.4	3.32	18.4	3.40	18.4	3.44	18.4	3.49	18.4	3.57
-1.84 -2.2	19.1	3.27	19.1	3.36	19.1	3.43	19.1	3.48	19.1	3.53	19.1	3.60
5.5 5.0	21.6	3.41	21.6	3.49	21.6	3.56	21.6	3.60	21.6	3.64	21.6	3.70
9.5 8.5	22.9	3.47	22.9	3.55	22.9	3.61	22.9	3.65	22.9	3.69	22.9	3.75
13.0 12.0	24.1	3.52	24.1	3.60	24.1	3.66	24.1	3.70	24.1	3.73	24.0	3.79
15.0 14.0	24.8	3.55	24.8	3.63	24.8	3.68	24.8	3.72	24.8	3.76	24.0	3.81
17.0 15.5	25.4	3.57	25.4	3.65	25.4	3.70	25.4	3.74	25.4	3.77	24.0	3.71
19.0 18.0	26.3	3.61	26.3	3.68	26.3	3.73	26.3	3.76	25.8	3.80	24.0	3.57
22.0 20.0	27.0	3.63	27.0	3.70	27.0	3.75	27.0	3.79	25.8	3.79	24.0	3.46
26.0 24.0	28.4	3.68	28.4	3.74	28.2	3.79	27.0	3.78	25.8	3.57	24.0	3.26
30.0 28.0	29.8	3.72	29.8	3.78	28.2	3.77	27.0	3.57	25.8	3.38	24.0	3.09
35.0 32.0	31.2	3.76	30.0	3.82	28.2	3.57	27.0	3.39	25.8	3.20	24.0	2.93
39.0 36.0	32.4	3.80	30.0	3.67	28.2	3.39	27.0	3.22	25.8	3.05	24.0	2.79
44.0 40.0	32.4	3.83	30.0	3.49	28.2	3.23	27.0	3.07	25.8	2.90	24.0	2.67
47.0 43.0	32.4	3.71	30.0	3.37	28.2	3.12	27.0	2.96	25.8	2.81	24.0	2.58
51.0 47.0	32.4	3.54	30.0	3.22	28.2	2.99	27.0	2.84	25.8	2.69	24.0	2.47
54.0 50.0	32.4	3.42	30.0	3.12	28.2	2.89	27.0	2.75	25.8	2.60	24.0	2.40
57.0 53.0	32.4	3.32	30.0	3.02	28.2	2.80	27.0	2.66	25.8	2.53	24.0	2.32
60.0 56.0	32.4	3.21	30.0	2.93	28.2	2.72	27.0	2.59	25.8	2.45	24.0	2.26
64.0 60.0	32.4	3.09	30.0	2.82	28.2	2.62	27.0	2.49	25.8	2.36	24.0	2.18

TC: Total capacity: MBH

PI: Power input: kW

Note: 1. is shown as reference.
 2. Actual system performance may vary based on other factors such as piping losses, elevation, etc.
 3. shows rated condition.