

7. Capacity Tables

FFA09AVJU9 + RXV09AVJU9

Cooling (60 Hz, 208 V)

AFR	10.7
BF	0.18

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	3.59	2.65	0.57	3.29	2.50	0.71	2.99	2.35	0.84	2.84	2.28	0.91	2.69	2.21	0.98	2.51	2.13	1.06
16.0	22.0	3.74	2.60	0.57	3.44	2.46	0.71	3.14	2.32	0.85	2.99	2.25	0.92	2.84	2.19	0.98	2.65	2.11	1.07
18.0	25.0	3.89	2.72	0.58	3.59	2.59	0.72	3.29	2.46	0.85	3.14	2.39	0.92	2.98	2.33	0.99	2.80	2.26	1.07
19.4	26.7	3.99	2.72	0.58	3.69	2.60	0.72	3.39	2.48	0.85	3.24	2.42	0.92	3.09	2.36	0.99	2.91	2.29	1.07
22.0	30.0	4.19	2.75	0.72	3.89	2.64	0.72	3.58	2.53	0.86	3.43	2.48	0.93	3.28	2.43	1.00	3.10	2.36	1.08
24.0	32.0	4.34	2.68	0.73	4.04	2.58	0.73	3.73	2.48	0.86	3.58	2.43	0.93	3.43	2.38	1.00	3.25	2.32	1.08

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	12.25	9.05	0.57	11.22	8.54	0.71	10.19	8.03	0.84	9.68	7.79	0.91	9.16	7.54	0.98	8.55	7.25	1.06
60.8	71.6	12.76	8.87	0.57	11.73	8.39	0.71	10.70	7.92	0.85	10.19	7.69	0.92	9.67	7.46	0.98	9.06	7.19	1.07
64.4	77.0	13.27	9.27	0.58	12.24	8.82	0.72	11.21	8.38	0.85	10.70	8.17	0.92	10.18	7.96	0.99	9.57	7.70	1.07
67.0	80.0	13.63	9.29	0.58	12.60	8.87	0.72	11.57	8.45	0.85	11.00	8.25	0.92	10.54	8.05	0.99	9.92	7.81	1.07
71.6	86.0	14.29	9.40	0.72	13.26	9.01	0.72	12.23	8.64	0.86	11.72	8.46	0.93	11.20	8.28	1.00	10.58	8.06	1.08
75.2	89.6	14.80	9.14	0.73	13.77	8.79	0.73	12.74	8.45	0.86	12.23	8.28	0.93	11.71	8.12	1.00	11.09	7.92	1.08

Heating (60 Hz, 208 V)

AFR	11.6
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		10 / (15)		18 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		2.22	1.10	2.71	1.12	3.20	1.14	3.69	1.16	4.28	1.19	4.68	1.23	5.46	1.31
21.1		2.05	1.14	2.54	1.16	3.03	1.18	3.52	1.20	4.11	1.22	4.50	1.26	5.29	1.34
22.0		2.03	1.15	2.52	1.16	3.01	1.18	3.50	1.20	4.08	1.22	4.48	1.26	5.26	1.35
24.0		1.97	1.16	2.46	1.18	2.95	1.19	3.44	1.21	4.03	1.24	4.42	1.28	5.20	1.36
25.0		1.95	1.16	2.43	1.18	2.92	1.20	3.41	1.22	4.00	1.24	4.39	1.28	5.17	1.36
27.0		1.89	1.18	2.38	1.19	2.87	1.21	3.36	1.23	3.94	1.25	4.33	1.29	5.12	1.37

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		50 / (59)		64 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		7.56	1.10	9.24	1.12	10.91	1.14	12.58	1.16	14.59	1.19	15.93	1.23	18.60	1.31
70.0		7.00	1.14	8.67	1.16	10.33	1.18	12.00	1.20	14.00	1.22	15.33	1.26	18.00	1.34
71.6		6.92	1.15	8.58	1.16	10.25	1.18	11.91	1.20	13.91	1.22	15.25	1.26	17.91	1.35
75.2		6.73	1.16	8.39	1.18	10.06	1.19	11.72	1.21	13.72	1.24	15.05	1.28	17.72	1.36
77.0		6.64	1.16	8.30	1.18	9.96	1.20	11.63	1.22	13.62	1.24	14.95	1.28	17.62	1.36
80.6		6.46	1.18	8.11	1.19	9.77	1.21	11.43	1.23	13.43	1.25	14.76	1.29	17.42	1.37

FFA12AVJU9 + RXV12AVJU9

Cooling (60 Hz, 208 V)

AFR	11.1
BF	0.09

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.32	3.15	0.79	3.96	2.97	0.98	3.60	2.79	1.16	3.41	2.70	1.26	3.23	2.61	1.35	3.02	2.51	1.08
16.0	22.0	4.50	3.09	0.79	4.14	2.92	0.98	3.78	2.75	1.17	3.59	2.67	1.26	3.41	2.59	1.36	3.20	2.49	1.08
18.0	25.0	4.68	3.22	0.80	4.32	3.06	0.99	3.96	2.90	1.17	3.77	2.83	1.27	3.59	2.75	1.36	3.37	2.66	1.08
19.4	26.7	4.81	3.23	0.80	4.44	3.07	0.99	4.08	2.93	1.18	3.90	2.85	1.27	3.72	2.78	1.37	3.50	2.70	1.08
22.0	30.0	5.04	3.26	1.00	4.68	3.12	1.00	4.32	2.99	1.19	4.13	2.92	1.28	3.95	2.86	1.37	3.73	2.78	1.08
24.0	32.0	5.22	3.16	1.00	4.86	3.04	1.00	4.49	2.92	1.19	4.31	2.86	1.29	4.13	2.80	1.38	3.91	2.73	1.08

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	14.75	10.76	0.79	13.51	10.13	0.98	12.27	9.52	1.16	11.65	9.22	1.26	11.03	8.92	1.35	10.29	8.57	1.08
60.8	71.6	15.36	10.54	0.79	14.12	9.95	0.98	12.88	9.38	1.17	12.26	9.10	1.26	11.64	8.82	1.36	10.90	8.49	1.08
64.4	77.0	15.98	10.99	0.80	14.74	10.45	0.99	13.50	9.91	1.17	12.88	9.65	1.27	12.26	9.39	1.36	11.51	9.08	1.08
67.0	80.0	16.40	11.01	0.80	15.17	10.49	0.99	13.93	9.98	1.18	13.30	9.73	1.27	12.69	9.49	1.37	11.94	9.20	1.08
71.6	86.0	17.20	11.11	1.00	15.96	10.65	1.00	14.72	10.19	1.19	14.10	9.97	1.28	13.48	9.75	1.37	12.74	9.49	1.08
75.2	89.6	17.81	10.80	1.00	16.58	10.37	1.00	15.34	9.96	1.19	14.72	9.75	1.29	14.10	9.55	1.38	13.35	9.31	1.08

Heating (60 Hz, 208 V)

AFR	12.3
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		10 / (15)		18 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		3.01	1.50	3.51	1.52	4.01	1.54	4.52	1.56	5.13	1.59	5.53	1.64	6.34	1.75
21.1		2.78	1.55	3.29	1.57	3.80	1.59	4.31	1.61	4.92	1.63	5.33	1.69	6.14	1.79
22.0		2.75	1.55	3.26	1.57	3.77	1.59	4.28	1.61	4.89	1.64	5.30	1.69	6.11	1.80
24.0		2.68	1.57	3.19	1.59	3.70	1.61	4.21	1.63	4.82	1.65	5.23	1.71	6.04	1.82
25.0		2.64	1.58	3.15	1.60	3.67	1.62	4.18	1.64	4.79	1.66	5.20	1.71	6.01	1.82
27.0		2.57	1.60	3.08	1.62	3.60	1.63	4.11	1.65	4.72	1.68	5.13	1.73	5.94	1.84

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		50 / (59)		64 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		10.26	1.50	11.98	1.52	13.70	1.54	15.43	1.56	17.51	1.59	18.89	1.64	21.67	1.75
70.0		9.50	1.55	11.24	1.57	12.98	1.59	14.71	1.61	16.80	1.63	18.19	1.69	20.97	1.79
71.6		9.39	1.55	11.13	1.57	12.87	1.59	14.61	1.61	16.70	1.64	18.09	1.69	20.87	1.80
75.2		9.14	1.57	10.89	1.59	12.63	1.61	14.37	1.63	16.46	1.65	17.86	1.71	20.64	1.82
77.0		9.01	1.58	10.76	1.60	12.51	1.62	14.26	1.64	16.35	1.66	17.74	1.71	20.53	1.82
80.6		8.76	1.60	10.52	1.62	12.27	1.63	14.02	1.65	16.12	1.68	17.51	1.73	20.30	1.84

FFA15AVJU9 + RXV15AVJU9

Cooling (60 Hz, 208 V)

AFR	11.7
BF	0.22

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	4.46	3.14	0.72	4.46	3.14	1.00	4.46	3.14	1.28	4.15	2.98	1.44	3.93	2.86	1.54	3.66	2.73	1.67
16.0	22.0	5.47	3.51	0.91	5.03	3.27	1.12	4.69	3.10	1.29	4.37	2.94	1.44	4.15	2.83	1.55	3.88	2.71	1.68
18.0	25.0	5.69	3.61	0.91	5.25	3.39	1.13	4.90	3.22	1.29	4.59	3.08	1.45	4.37	2.98	1.56	4.10	2.86	1.69
19.4	26.7	5.84	3.59	0.92	5.40	3.39	1.13	5.06	3.23	1.30	4.74	3.09	1.45	4.52	2.99	1.56	4.25	2.88	1.69
22.0	30.0	6.13	3.58	0.92	5.69	3.40	1.14	5.34	3.26	1.31	5.02	3.13	1.46	4.80	3.04	1.57	4.54	2.94	1.70
24.0	32.0	6.35	3.46	0.93	5.90	3.29	1.15	5.56	3.17	1.31	5.24	3.05	1.47	5.02	2.97	1.58	4.76	2.88	1.70

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	15.23	10.73	0.72	15.23	10.73	1.00	15.23	10.73	1.28	14.16	10.16	1.44	13.41	9.77	1.54	12.50	9.31	1.67
60.8	71.6	18.67	11.97	0.91	17.17	11.17	1.12	15.99	10.57	1.29	14.91	10.03	1.44	14.15	9.67	1.55	13.25	9.23	1.68
64.4	77.0	19.42	12.30	0.91	17.91	11.56	1.13	16.74	11.00	1.29	15.65	10.50	1.45	14.90	10.15	1.56	13.99	9.75	1.69
67.0	80.0	19.94	12.26	0.92	18.43	11.56	1.13	17.26	11.02	1.30	16.20	10.54	1.45	15.42	10.22	1.56	14.52	9.83	1.69
71.6	86.0	20.91	12.22	0.92	19.40	11.59	1.14	18.23	11.11	1.31	17.14	10.67	1.46	16.39	10.38	1.57	15.48	10.03	1.70
75.2	89.6	21.65	11.82	0.93	20.15	11.24	1.15	18.97	10.80	1.31	17.89	10.40	1.47	17.13	10.13	1.58	16.23	9.82	1.70

Heating (60 Hz, 208 V)

AFR	13.0
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		10 / (15)		18 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		3.61	1.71	3.96	1.74	4.25	1.76	4.57	1.79	4.97	1.82	5.24	1.89	5.77	2.01
21.1		3.34	1.77	3.72	1.80	4.02	1.82	4.36	1.85	4.77	1.88	5.04	1.94	5.59	2.06
22.0		3.30	1.78	3.69	1.80	3.99	1.83	4.33	1.85	4.74	1.88	5.01	1.95	5.56	2.07
24.0		3.21	1.80	3.61	1.82	3.91	1.85	4.26	1.87	4.67	1.90	4.95	1.96	5.50	2.09
25.0		3.17	1.81	3.57	1.83	3.88	1.85	4.23	1.88	4.64	1.91	4.92	1.97	5.47	2.09
27.0		3.08	1.82	3.49	1.85	3.80	1.87	4.16	1.90	4.58	1.93	4.85	1.99	5.41	2.11

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		50 / (59)		64 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		12.31	1.71	13.53	1.74	14.50	1.76	15.63	1.79	16.99	1.82	17.90	1.89	19.73	2.01
70.0		11.40	1.77	12.71	1.80	13.73	1.82	14.90	1.85	16.30	1.88	17.23	1.94	19.10	2.06
71.6		11.27	1.78	12.59	1.80	13.62	1.83	14.79	1.85	16.20	1.88	17.14	1.95	19.01	2.07
75.2		10.97	1.80	12.32	1.82	13.37	1.85	14.55	1.87	15.97	1.90	16.92	1.96	18.80	2.09
77.0		10.82	1.81	12.18	1.83	13.24	1.85	14.44	1.88	15.86	1.91	16.81	1.97	18.70	2.09
80.6		10.52	1.82	11.91	1.85	12.99	1.87	14.20	1.90	15.64	1.93	16.59	1.99	18.49	2.11

FFA18AVJU9 + RXV18AVJU9

Cooling (60 Hz, 208 V)

AFR	14.2
BF	0.24

Temp: Celsius / TC, SHC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	10			20			30			35			40			46		
°C	°C	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
14.0	20.0	5.25	3.69	0.83	5.25	3.69	1.16	5.06	3.60	1.53	4.81	3.46	1.65	4.55	3.33	1.77	4.24	3.18	1.72
16.0	22.0	6.34	4.07	1.04	5.83	3.80	1.29	5.32	3.55	1.53	5.06	3.42	1.66	4.80	3.30	1.78	4.50	3.15	1.72
18.0	25.0	6.59	4.19	1.05	6.08	3.94	1.29	5.57	3.70	1.54	5.31	3.58	1.67	5.06	3.46	1.79	4.75	3.33	1.72
19.4	26.7	6.77	4.18	1.05	6.26	3.94	1.30	5.75	3.71	1.55	5.49	3.60	1.67	5.23	3.49	1.79	4.93	3.36	1.72
22.0	30.0	7.10	4.16	1.06	6.59	3.95	1.31	6.07	3.74	1.56	5.82	3.64	1.68	5.56	3.54	1.80	5.26	3.43	1.72
24.0	32.0	7.35	4.03	1.07	6.84	3.83	1.32	6.33	3.64	1.56	6.07	3.55	1.69	5.82	3.46	1.81	5.51	3.35	1.72

Temp: Fahrenheit / TC, SHC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EDB																	
EWB	EDB	50			68			86			95			104			115		
°F	°F	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI	TC	SHC	PI
57.2	68.0	17.90	12.61	0.83	17.90	12.61	1.16	17.27	12.27	1.53	16.40	11.82	1.65	15.53	11.37	1.77	14.48	10.84	1.72
60.8	71.6	21.63	13.89	1.04	19.88	12.98	1.29	18.14	12.10	1.53	17.26	11.67	1.66	16.39	11.25	1.78	15.35	10.75	1.72
64.4	77.0	22.49	14.30	1.05	20.74	13.44	1.29	19.00	12.62	1.54	18.13	12.22	1.67	17.26	11.82	1.79	16.21	11.35	1.72
67.0	80.0	23.09	14.25	1.05	21.35	13.44	1.30	19.60	12.65	1.55	18.80	12.27	1.67	17.86	11.89	1.79	16.81	11.45	1.72
71.6	86.0	24.21	14.21	1.06	22.47	13.48	1.31	20.73	12.77	1.56	19.85	12.43	1.68	18.98	12.09	1.80	17.93	11.69	1.72
75.2	89.6	25.08	13.75	1.07	23.33	13.08	1.32	21.59	12.43	1.56	20.72	12.12	1.69	19.84	11.81	1.81	18.80	11.44	1.72

Heating (60 Hz, 208 V)

AFR	15.9
-----	------

Temp: Celsius / TC, PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		-15 / (-15)		-10 / (-9)		-5 / (-4)		0 / (1.5)		6 / (8.3)		10 / (15)		18 / (24)	
°C		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
15.0		4.81	2.05	5.23	2.06	5.66	2.07	6.10	2.08	6.63	2.10	6.98	2.17	7.70	2.31
21.1		4.45	2.12	4.91	2.13	5.36	2.14	5.82	2.15	6.36	2.15	6.72	2.23	7.45	2.37
22.0		4.40	2.13	4.86	2.14	5.32	2.15	5.77	2.15	6.32	2.16	6.68	2.23	7.41	2.38
24.0		4.29	2.15	4.75	2.16	5.22	2.17	5.68	2.17	6.23	2.18	6.60	2.25	7.33	2.40
25.0		4.23	2.17	4.70	2.17	5.17	2.18	5.63	2.18	6.19	2.19	6.56	2.26	7.29	2.41
27.0		4.11	2.19	4.60	2.19	5.07	2.20	5.54	2.21	6.10	2.21	6.47	2.28	7.21	2.42

Temp: Fahrenheit / TC: kBtu/h / PI: kW

INDOOR		OUTDOOR TEMPERATURE : EWB / (EDB)													
EDB		5 / (5)		14 / (15.8)		23 / (24.8)		32 / (34.7)		43 / (47)		50 / (59)		64 / (75.2)	
°F		TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI	TC	PI
59.0		16.42	2.05	17.88	2.06	19.37	2.07	20.88	2.08	22.72	2.10	23.95	2.17	26.42	2.31
70.0		15.20	2.12	16.77	2.13	18.34	2.14	19.91	2.15	21.80	2.15	23.06	2.23	25.57	2.37
71.6		15.02	2.13	16.61	2.14	18.19	2.15	19.77	2.15	21.66	2.16	22.93	2.23	25.45	2.38
75.2		14.62	2.15	16.25	2.16	17.85	2.17	19.45	2.17	21.36	2.18	22.63	2.25	25.17	2.40
77.0		14.42	2.17	16.06	2.17	17.69	2.18	19.29	2.18	21.21	2.19	22.49	2.26	25.03	2.41
80.6		14.02	2.19	15.70	2.19	17.35	2.20	18.98	2.21	20.91	2.21	22.20	2.28	24.75	2.42