

Amendment 001

Department of the Treasury, Bureau of the Fiscal Service
Division of Procurement

DATE: February 26, 2025
FROM: Kaitlyn Eaton, Contract Specialist
SUBJECT: **RFQ: 20342325Q00014** – AFRH-Gulfport Generator Replacement
Amendment 001

The purposes of this amendment are:

1. To provide the Government's answer to vendor questions.
2. To extend the solicitation period to Monday, March 14th at 10:00am ET.

Please find vendor submitted questions below with the Government's response to the questions.

1. **Is the Contractor to supply generators and fuel tanks?**

The Government Response:

Yes

2. **Is a provision needed in the event of a power outage while switching the systems?**

The Government Response:

It depends on the outage. AFRH can handle scheduled outages for a short periods of time such as 2 to 3 hours. We are also open to multiple outages. We do not anticipate long outages due to the nature of work in replacing a generator.

3. **Is the Contractor to turn over existing units to the owners?**

The Government Response:

No

4. Is a bid bond required for this project?

The Government Response:

Yes, a bond will be required.

5. Can flexibility be considered in the project start date to accommodate potential supply chain delays?

The Government Response:

Yes, but keep the COR informed throughout the entire process.

6. Will there be consideration for phased implementation to mitigate downtime risks?

The Government Response:

Yes

7. Can AFRH confirm all compliance and technical specifications for generator integration?

The Government Response:

Yes, the drawings and specifications are stamped, and they have been reviewed by a third party code review contractor

8. Will AFRH require full load bank testing before final acceptance?

The Government Response:

Yes, full load bank testing must be performed.

9. Are temporary load banks needed and will specifications be provided by AFRH?

The Government Response:

No, temporary load banks will not be required.