Amendment 011

Department of the Treasury, Bureau of the Fiscal Service
Division of Procurement

DATE: June 05, 2025

FROM: Kaitlyn Eaton, Contract Specialist

SUBJECT: RFQ: 20342325Q00014 – AFRH-Gulfport Generator Replacement

Amendment 011

The purpose of this amendment is:

1. To answer vendor questions.

Please find vendor submitted questions below with the Government's response to the questions.

Drawing E202 indicates that a new AC breaker, 1200AF/175AT, to be installed in the
existing paralleling switchgear. Please provide further details on how this will be
accomplished as there does not appear to be a prepared space for the installation of
an additional AC breaker.

The Government Response:

Because the existing switchgear does not have an available space for the load bank breaker, a remote breaker cabinet will be utilized. Drawings will be updated to reflect this design.