

Report for HOCL

Date:02/03/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	8.03	7.7	8.5	-
BOD	2.49	0.69	9.99	-
COD	24.26	15.54	63.33	-
TSS	17.34	16	19.38	-
Flow	13.75	0.3	66	-

No energy report available.

No water quality report available.