

Daily Environmental Report

STP - Hilton Manyata, Block A, Hotel building, 1, Outer ring road, MS Ramaiah north city, Manyata tech park, Nagavara, Bengaluru, Karnataka
(2025/11/20 to 2025/11/20)

Water Quality

| Parameter | Avg Value | Min Value | Max Value | Acceptable Max Limit |
|-----------|-----------|-----------|-----------|----------------------|
| ph | 6.75 | 6.50 | 7.00 | N/A |
| Temp | 27.92 | 27.00 | 29.00 | N/A |
| BOD | 9.87 | 7.87 | 13.56 | 10.00 |
| COD | 23.97 | 18.43 | 34.73 | 50.00 |
| TSS | 11.26 | 9.57 | 14.39 | 10.00 |

Water Quantity

| Name | Initial Reading | Final Meter Reading | Total |
|---------------------|-----------------|---------------------|-------|
| ETP outlet | 0.00 | 0.00 | 0.00 |
| STP inlet | 4117.60 | 4117.60 | 0.00 |
| STP uf outlet | 6545.50 | 6545.50 | 0.00 |
| STP softener outlet | 2475.80 | 2475.80 | 0.00 |
| STP garden outlet 1 | 1951.90 | 1951.90 | 0.00 |
| STP garden outlet 2 | 0.00 | 0.00 | 0.00 |
| STP acf outlet | 3543.70 | 3543.70 | 0.00 |

Energy Report

| Stack Name | Initial Reading | Last Reading | Total kWh |
|------------|-----------------|--------------|-----------|
| STP-energy | 646213.94 | 646651.06 | 437.13 |