## **Daily Environmental Report**

STP - Embassy Golflinks - Hilton, off Intermediate Ring Road, Embassy Golf Links Business Park, Challaghatta, Bengaluru, Karnataka 560071 (2025/10/27 to 2025/10/27)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.48	7.25	7.50	N/A
TURB	1.01	1.01	1.01	N/A
Temp	29.75	29.29	30.18	N/A
BOD	9.35	9.24	9.39	10.00
COD	45.38	44.97	45.52	50.00
TSS	9.22	9.11	9.26	10.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	56258.20	56344.00	85.80
STP outlet	13278.78	13403.57	124.79

## **Energy Report**

Stack Name	Initial Reading	Last Reading	Total kWh			
No energy data available.						