

# Daily Environmental Report

STP - Embassy Golflinks - Torrey Pines, Embassy Golf Links  
Business Park, Challaghatta, Bengaluru, Karnataka 560071  
(2025/11/14 to 2025/11/14)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.41	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.33	27.32	29.26	N/A
BOD	6.70	3.87	9.56	30.00
COD	38.87	28.25	47.73	N/A
TSS	12.08	9.79	15.94	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	14700.30	14700.30	0.00
STP outlet	339880.30	339880.30	0.00

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			