

# Daily Environmental Report

STP - Embassy Golflinks - Torrey Pines, Embassy Golf Links  
Business Park, Challaghatta, Bengaluru, Karnataka 560071  
(2025/10/27 to 2025/10/27)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.29	27.32	29.26	N/A
BOD	5.81	3.87	9.56	30.00
COD	38.60	28.25	44.61	N/A
TSS	12.41	9.79	16.87	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	13277.60	13283.00	5.40
STP outlet	331420.40	331973.50	553.10

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			