

# Daily Environmental Report

**STP - Embassy Golflinks - Pine Valley, EMBASSY GOLF LINKS  
BUSINESS PARK-1, Inner Rd, Embassy Golf Links Business Park,  
Challaghatta, Bengaluru, Karnataka 560071  
(2025/11/17 to 2025/11/17)**

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.54	27.32	29.26	N/A
BOD	6.86	3.87	9.56	30.00
COD	36.19	28.25	40.61	N/A
TSS	11.63	9.79	16.13	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	154942.60	155029.00	86.40
STP outlet	147072.50	147072.50	0.00

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			