

Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071
(2025/10/30 to 2025/10/30)

Water Quality

| Parameter | Avg Value | Min Value | Max Value | Acceptable Max Limit |
|-----------|-----------|-----------|-----------|----------------------|
| ph | 7.40 | 7.00 | 7.46 | N/A |
| TURB | 0.01 | 0.01 | 0.01 | N/A |
| Temp | 27.94 | 27.32 | 29.26 | N/A |
| BOD | 7.98 | 5.27 | 9.56 | 30.00 |
| COD | 36.38 | 28.25 | 39.73 | N/A |
| TSS | 11.45 | 9.79 | 15.48 | 100.00 |

Water Quantity

| Name | Initial Reading | Final Meter Reading | Total |
|------------|-----------------|---------------------|--------|
| STP inlet | 138226.60 | 138340.40 | 113.80 |
| STP outlet | 200005.90 | 200110.70 | 104.80 |

Energy Report

| Stack Name | Initial Reading | Last Reading | Total kWh |
|---------------------------|-----------------|--------------|-----------|
| No energy data available. | | | |