

Daily Environmental Report

**STP - Embassy Golflinks - Pine Valley, EMBASSY GOLF LINKS
BUSINESS PARK-1, Inner Rd, Embassy Golf Links Business Park,
Challaghatta, Bengaluru, Karnataka 560071
(2026/01/16 to 2026/01/16)**

Water Quality

| Parameter | Avg Value | Min Value | Max Value | Acceptable Max Limit |
|-----------|-----------|-----------|-----------|----------------------|
| ph | 7.43 | 7.00 | 7.46 | N/A |
| TURB | 0.01 | 0.01 | 0.01 | N/A |
| Temp | 28.14 | 27.32 | 29.26 | N/A |
| BOD | 5.92 | 3.87 | 9.56 | N/A |
| COD | 37.13 | 28.25 | 42.07 | N/A |
| TSS | 11.70 | 9.79 | 14.09 | N/A |

Water Quantity

| Name | Initial Reading | Final Meter Reading | Total |
|------------|-----------------|---------------------|--------|
| STP inlet | 160330.40 | 160463.30 | 132.90 |
| STP outlet | 147015.90 | 147072.50 | 56.60 |

Energy Report

| Stack Name | Initial Reading | Last Reading | Total kWh |
|---------------------------|-----------------|--------------|-----------|
| No energy data available. | | | |