

Daily Environmental Report

STP - Hilton Manyata, Block A, Hotel building, 1, Outer ring road, MS
Ramaiah north city, Manyata tech park, Nagavara, Bengaluru,
Karnataka
(2026/01/21 to 2026/01/21)

Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	6.83	6.50	7.00	N/A
Temp	27.48	27.00	29.00	N/A
BOD	8.91	7.87	13.56	N/A
COD	23.41	18.43	29.37	N/A
TSS	13.44	9.57	14.39	N/A

Water Quantity

Name	Initial Reading	Final Meter Reading	Total
ETP outlet	0.00	0.00	0.00
STP inlet	0.00	0.00	0.00
STP uf outlet	0.00	0.00	0.00
STP softener outlet	0.00	0.00	0.00
STP garden outlet 1	0.00	0.00	0.00
STP garden outlet 2	0.00	0.00	0.00
STP acf outlet	0.00	0.00	0.00

Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			