

# Report for Seafood Park (India) Ltd

Date:20/04/2025

## Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	6.72	6.5	7	-
Temp	29.34	27	30	-
BOD	7.00	2.9706	9.564	-
COD	17.80	15.434	20.4163	-
TSS	10.87	10.567	12.1421	-

No energy report available.

No water quality report available.