

Report for Hilton Manyata

Date:23/09/2025

Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	6.73	6.5	7	-
Temp	27.99	27	29	-
BOD	9.96	7.87	13.564	-
COD	20.20	18.434	26.0475	-
TSS	11.56	9.567	14.386	-
cumulatingFlow	0.00	-	-	-
flowRate	0.00	-	-	-
energy	0.00	-	-	-
voltage	0.00	-	-	-
current	0.00	-	-	-
power	0.00	-	-	-
weight	0.00	-	-	-

Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	617255.81	617985.06	729.25

Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	6552.30	6552.30	15.00
STP acf outlet	3577.10	3577.10	0.00
STP uf outlet	5750.30	5949.20	198.90
STP softener outlet	6539.30	6539.30	0.00
STP garden outlet 1	1806.00	1806.00	0.00

Station	Initial Reading	Final Reading	Consumption m3
STP garden outlet 2	0.00	0.00	0.00