

# Report for Hilton Manyata

Date:09/08/2025

## Quality Report

Parameter	Avg Value	Min Limit	Max Limit	Exceedence
ph	6.75	6.5	7	-
Temp	28.05	27	29	-
BOD	9.31	7.87	13.564	-
COD	19.48	18.434	22.6312	-
TSS	11.17	9.567	14.386	-
cumulatingFlow	0.00	-	-	-
flowRate	0.00	-	-	-
energy	0.00	-	-	-
voltage	0.00	-	-	-
current	0.00	-	-	-
power	0.00	-	-	-
weight	0.00	-	-	-

## Energy Report

Station	Initial Reading	Final Reading	Consumption kWh
STP-energy	596438.31	596913.75	475.44

## Water Quality Report

Station	Initial Reading	Final Reading	Consumption m3
ETP outlet	0.00	0.00	0.00
STP inlet	3886.80	3941.40	54.60
STP acf outlet	3577.10	3577.10	0.00
STP uf outlet	1488.60	1728.70	240.10
STP softener outlet	4183.10	4355.50	172.40
STP garden outlet 1	1737.90	1737.90	0.00

Station	Initial Reading	Final Reading	Consumption m3
STP garden outlet 2	0.00	0.00	0.00