

Daily Environmental Report

STP - Hilton Manyata, Block A, Hotel building, 1, Outer ring road, MS
Ramaiah north city, Manyata tech park, Nagavara, Bengaluru,
Karnataka
(2025/10/27 to 2025/10/27)

Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	6.66	6.50	7.00	N/A
Temp	27.66	27.00	29.00	N/A
BOD	9.09	7.46	13.56	10.00
COD	20.23	18.25	25.07	50.00
TSS	10.22	9.57	13.46	10.00

Water Quantity

Name	Initial Reading	Final Meter Reading	Total
ETP outlet	0.00	0.00	0.00
STP inlet	3002.90	3120.30	117.40
STP uf outlet	2859.20	2905.70	46.50
STP softener outlet	1432.10	1455.10	23.00
STP garden outlet 1	1870.60	1870.60	0.00
STP garden outlet 2	0.00	0.00	0.00
STP acf outlet	3543.70	3543.70	0.00

Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
STP-energy	633583.50	633914.63	331.13