

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/10/28 to 2025/10/28)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.41	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.22	27.32	29.26	N/A
BOD	5.95	3.87	9.56	30.00
COD	37.99	28.25	43.34	N/A
TSS	12.12	9.79	16.96	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	137770.10	137990.20	220.10
STP outlet	199629.90	199812.00	182.10

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			