

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/11/10 to 2025/11/10)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.14	27.32	29.26	N/A
BOD	6.25	3.87	9.56	30.00
COD	36.32	28.25	38.85	N/A
TSS	12.01	9.79	17.42	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	140136.60	140302.20	165.60
STP outlet	201687.20	201784.20	97.00

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			