

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/11/17 to 2025/11/17)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.54	27.32	29.26	N/A
BOD	6.32	3.87	9.56	30.00
COD	36.11	28.25	40.41	N/A
TSS	11.25	9.79	13.25	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	140807.70	140921.00	113.30
STP outlet	202693.40	202780.00	86.60

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			