

# Daily Environmental Report

STP - Embassy Golflinks - Torrey Pines, Embassy Golf Links  
Business Park, Challaghatta, Bengaluru, Karnataka 560071  
(2025/11/17 to 2025/11/17)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.39	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.10	27.32	29.26	N/A
BOD	5.90	3.87	9.56	30.00
COD	35.45	28.25	37.68	N/A
TSS	12.32	9.79	18.81	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	14732.30	14732.30	0.00
STP outlet	339748.10	340060.00	311.90

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			