

# Daily Environmental Report

STP - Embassy Golflinks - MLCP, 6, Embassy Golf Links Business Park, Domlur, Bengaluru, Karnataka 560071  
(2025/10/26 to 2025/10/26)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.40	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.09	27.32	29.26	N/A
BOD	7.40	3.87	9.56	30.00
COD	36.13	28.25	38.56	N/A
TSS	12.06	9.79	15.20	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	137566.90	137597.60	30.70
STP outlet	199500.90	199531.70	30.80

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			