

# Daily Environmental Report

STP - Embassy Golflinks - Torrey Pines, Embassy Golf Links  
Business Park, Challaghatta, Bengaluru, Karnataka 560071  
(2025/11/11 to 2025/11/11)

## Water Quality

Parameter	Avg Value	Min Value	Max Value	Acceptable Max Limit
ph	7.38	7.00	7.46	N/A
TURB	0.01	0.01	0.01	N/A
Temp	28.41	27.32	29.26	N/A
BOD	7.15	3.87	9.56	30.00
COD	36.54	28.25	39.63	N/A
TSS	11.40	9.79	15.29	100.00

## Water Quantity

Name	Initial Reading	Final Meter Reading	Total
STP inlet	14623.70	14676.20	52.50
STP outlet	339908.30	339908.30	0.00

## Energy Report

Stack Name	Initial Reading	Last Reading	Total kWh
No energy data available.			